

VENTILATION AUDIT REPORT

SCHOOL:	Sanctuary Point Public School (4464)
AMU REGION:	Southern NSW
STATE ELECTORATE:	South Coast
LOCAL GOVERNMENT AREA:	Shoalhaven

4464 - Sanctuary Point Public School
Site Plan (11276)














































1:1,154

Printed: 18-Aug-2021

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Interview - (10.46 SQM)	 Office (2)	
B00A - R0002 - Staff Room Annexe - (12.16 SQM)	 Office (3)	
B00A - R0003 - Principal - (16.93 SQM)	 Office (4)	
B00A - R0004 - Sick Bay - (9 SQM)	 Student Space (4)	
B00A - R0015 - Staff Room Annexe - (24.69 SQM)	 Office (6)	
B00A - R0016 - Staff Room Annexe - (12.73 SQM)	 Office (3)	
B00A - R0017 - Duplicating Workroom - (20.72 SQM)	 Office (5)	
B00A - R0018 - Clerical Office - (23.64 SQM)	 Office (5)	
B00A - R0023 - Entry Vestibule - (20.96 SQM)	Not Applicable	Circulation or storage space.
B00A - R0024 - Movement - (27.51 SQM)	Not Applicable	Circulation or storage space.
B00A - R0025 - Staff Room - (49.39 SQM)	 Office (12)	
B00A - R0026 - Staff Kitchen - (8.82 SQM)	 Office (2)	
B00B - R0002 - Practical Activities - 1hb - (16.81 SQM)	 Student Space (7)	
B00B - R0003 - Home Base - (53.42 SQM) - Teaching Space: 1	 Student Space (24)	
B00B - R0004 - Home Base - (52.8 SQM) - Teaching Space: 1	 Student Space (24)	
B00B - R0005 - Practical Activities - 1hb - (16.76 SQM)	 Student Space (7)	
B00B - R0010 - Computer Room - (11.64 SQM)	 Student Space (5)	
B00C - R0002 - Practical Activities - 1hb - (16.76 SQM)	 Student Space (7)	
B00C - R0003 - Home Base - (53.04 SQM) - Teaching Space: 1	 Student Space (24)	
B00C - R0004 - Special Programs Room - (53.27 SQM)	 Student Space (24)	
B00C - R0006 - Practical Activities - 1hb - (11.99 SQM)	 Student Space (5)	
B00D - R0002 - Practical Activities - 1hb - (15.73 SQM)	 Student Space (7)	
B00D - R0004 - Home Base - (73.96 SQM) - Teaching Space: 1	 Student Space (34)	
B00D - R0005 - Home Base - (73.8 SQM) - Teaching Space: 1	 Student Space (34)	
B00D - R0006 - Practical Activities - 1hb - (15.84 SQM)	 Student Space (7)	
B00D - R0009 - Withdrawal Space - 1hb - (12.17 SQM)	 Student Space (5)	
B00E - R0005 - Practical Activities - 1hb - (23.07 SQM)	 Student Space (10)	
B00E - R0006 - Home Base - (51.04 SQM) - Teaching Space: 1	 Student Space (23)	
B00E - R0008 - Withdrawal Space - 1hb - (5.62 SQM)	 Student Space (2)	
B00E - R0010 - Practical Activities - 1hb - (23.45 SQM)	 Student Space (10)	
B00E - R0011 - Home Base - (51.25 SQM) - Teaching Space: 1	 Student Space (23)	
B00E - R0013 - Withdrawal Space - 1hb - (5.81 SQM)	 Student Space (2)	
B00F - R0002 - Practical Activities - 1hb - (22.65 SQM)	 Student Space (10)	
B00F - R0003 - Home Base - (51.11 SQM) - Teaching Space: 1	 Student Space (23)	
B00F - R0006 - Practical Activities - 1hb - (23.21 SQM)	 Student Space (10)	
B00F - R0007 - Home Base - (50.97 SQM) - Teaching Space: 1	 Student Space (23)	
B00F - R0009 - Withdrawal Space - 1hb - (5.83 SQM)	 Student Space (2)	
B00F - R0012 - Withdrawal Space - 1hb - (5.82 SQM)	 Student Space (2)	
B00G - R0007 - Reading Area - (148.72 SQM)	 Student Space (68)	
B00H - R0001 - Canteen - (42.76 SQM)	Not Applicable	Circulation or storage space.
B00H - R0003 - Communal Space - (220.6 SQM)	 Student Space (102)	
B00H - R0004 - Raised Platform - (45.95 SQM)	Not Applicable	Circulation or storage space.
B00M - R0003 - Practical Activities - 1hb - (15.7 SQM)	 Student Space (7)	
B00M - R0004 - Home Base - (62.19 SQM) - Teaching Space: 1	 Student Space (28)	
B00M - R0007 - Withdrawal Space - 1hb - (11.82 SQM)	 Student Space (5)	
B00M - R0010 - Home Base - (62.25 SQM) - Teaching Space: 1	 Student Space (28)	
B00M - R0011 - Practical Activities - 1hb - (15.76 SQM)	 Student Space (7)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00N - R0002 - Home Base - (62.44 SQM) - Teaching Space: 1	● Student Space (28)	
B00N - R0003 - Practical Activities - 1hb - (15.7 SQM)	● Student Space (7)	
B00N - R0005 - Withdrawal Space - 1hb - (12.64 SQM)	● Student Space (5)	
B00N - R0009 - Practical Activities - 1hb - (15.8 SQM)	● Student Space (7)	
B00N - R0010 - Home Base - (62.35 SQM) - Teaching Space: 1	● Student Space (28)	
B00N - R0011 - Movement - (6.22 SQM)	Not Applicable	Circulation or storage space.
B00Q - R0001 - Practical Activities - Pre - (9.82 SQM)	● Student Space (4)	
B00U - R0001 - Practical Activities - 1hb - (19.19 SQM)	● Student Space (8)	
B00U - R0003 - Home Base - (60.39 SQM) - Teaching Space: 1	● Student Space (28)	
B00U - R0004 - Withdrawal Space - 2hb - (11.75 SQM)	● Student Space (5)	
B00U - R0005 - Home Base - (60.59 SQM) - Teaching Space: 1	● Student Space (28)	
B00U - R0007 - Practical Activities - 1hb - (19.19 SQM)	● Student Space (8)	
B00U - R0013 - Practical Activities - 1hb - (19.09 SQM)	● Student Space (8)	
B00U - R0015 - Home Base - (60.53 SQM) - Teaching Space: 1	● Student Space (28)	
B00U - R0016 - Withdrawal Space - 2hb - (11.71 SQM)	● Student Space (5)	
B00U - R0017 - Home Base - (60.51 SQM) - Teaching Space: 1	● Student Space (28)	
B00U - R0019 - Practical Activities - 1hb - (19.26 SQM)	● Student Space (8)	
B00V - R0001 - Practical Activities - 1hb - (20.13 SQM)	● Student Space (9)	
B00V - R0002 - Withdrawal Space - 1hb - (9.02 SQM)	● Student Space (4)	
B00V - R0004 - Home Base - (55.43 SQM) - Teaching Space: 1	● Student Space (25)	
NS 100 13719 - NS 100 13719 - Learning Unit - Single Primary/PAA - (76 SQM)	● Student Space (35)	
OS 601 12149 - OS 601 12149 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 14140 - OS 601 14140 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 15336 - OS 601 15336 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 15610 - OS 601 15610 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 603 10045 - OS 603 10045 - Learning Unit - Standard With P.A.A. A/C - (76 SQM)	● Student Space (35)	
OS 606 15306 - OS 606 15306 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	● Student Space (35)	