

VENTILATION AUDIT REPORT

SCHOOL:	Sandy Beach Public School (4557)
AMU REGION:	North Coast
STATE ELECTORATE:	Coffs Harbour
LOCAL GOVERNMENT AREA:	Coffs Harbour

4557 - Sandy Beach Public School
Site Plan (11278)



1:1,713

Printed: 23-Apr-2021

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Staff Room Annexe - (19.91 SQM)	Office (4)	
B00A - R0002 - Staff Room - (47.15 SQM)	Office (11)	
B00A - R0005 - Interview - (12.18 SQM)	Office (3)	
B00A - R0006 - Movement - (16.84 SQM)	Not Applicable	Circulation or storage space.
B00A - R0007 - Principal - (17.09 SQM)	Office (4)	
B00A - R0008 - Duplicating Workroom - (20.73 SQM)	Office (5)	
B00A - R0010 - Clerical Office - (13.16 SQM)	Office (3)	
B00A - R0011 - Entry Vestibule - (18.12 SQM)	Not Applicable	Circulation or storage space.
B00A - R0012 - Deputy Principal - (11.81 SQM)	Office (2)	
B00A - R0013 - Movement - (20.45 SQM)	Not Applicable	Circulation or storage space.
B00A - R0014 - Sick Bay - (8.91 SQM)	Student Space (4)	
B00A - R0015 - Deputy Principal - (13.41 SQM)	Office (3)	
B00A - R0019 - Movement - (73.32 SQM)	Not Applicable	Circulation or storage space.
B00A - R0020 - Movement - (19.18 SQM)	Not Applicable	Circulation or storage space.
B00B - R0005 - Seminar/Study - (40.59 SQM)	Office (10)	
B00B - R0008 - Movement - (134.99 SQM)	Not Applicable	Circulation or storage space.
B00B - R0011 - Home Base - Pre - (116.21 SQM) - Teaching Space: 1	Student Space (53)	
B00C - R0001 - Movement - (17.32 SQM)	Not Applicable	Circulation or storage space.
B00C - R0002 - Home Base - (61.98 SQM) - Teaching Space: 1	Student Space (28)	
B00C - R0004 - Movement - (8.79 SQM)	Not Applicable	Circulation or storage space.
B00C - R0005 - Practical Activities - 1hb - (20.46 SQM)	Student Space (9)	
B00C - R0006 - Movement - (7.12 SQM)	Not Applicable	Circulation or storage space.
B00C - R0008 - Home Base - (61.9 SQM) - Teaching Space: 1	Student Space (28)	
B00C - R0009 - Withdrawal Space - 1hb - (12.1 SQM)	Student Space (5)	
B00C - R0010 - Movement - (17.32 SQM)	Not Applicable	Circulation or storage space.
B00C - R0015 - Movement - (33.76 SQM)	Not Applicable	Circulation or storage space.
B00D - R0001 - Movement - (17.4 SQM)	Not Applicable	Circulation or storage space.
B00D - R0002 - Home Base - (61.51 SQM) - Teaching Space: 1	Student Space (28)	
B00D - R0005 - Movement - (7.14 SQM)	Not Applicable	Circulation or storage space.
B00D - R0006 - Practical Activities - 1hb - (20.31 SQM)	Student Space (9)	
B00D - R0007 - Movement - (9.01 SQM)	Not Applicable	Circulation or storage space.
B00D - R0008 - Home Base - (61.74 SQM) - Teaching Space: 1	Student Space (28)	
B00D - R0010 - Withdrawal Space - 1hb - (12.15 SQM)	Student Space (5)	
B00D - R0011 - Movement - (17.32 SQM)	Not Applicable	Circulation or storage space.
B00D - R9003 - Movement - (29.75 SQM)	Not Applicable	Circulation or storage space.
B00E - R0006 - Communal Space - (150.16 SQM)	Student Space (69)	
B00E - R0009 - Raised Platform - (35.45 SQM)	Not Applicable	Circulation or storage space.
B00E - R0015 - Canteen - (27.9 SQM)	Not Applicable	Circulation or storage space.
B00E - R0019 - Movement - (121.31 SQM)	Not Applicable	Circulation or storage space.
B00E - R0020 - Movement - (26.5 SQM)	Not Applicable	Circulation or storage space.
B00E - R0021 - Movement - (6.67 SQM)	Not Applicable	Circulation or storage space.
B00F - R0001 - Movement - (17.32 SQM)	Not Applicable	Circulation or storage space.
B00F - R0002 - Home Base - (61.97 SQM) - Teaching Space: 1	Student Space (28)	
B00F - R0004 - Movement - (8.79 SQM)	Not Applicable	Circulation or storage space.
B00F - R0005 - Practical Activities - 1hb - (20.46 SQM)	Student Space (9)	
B00F - R0006 - Movement - (7.12 SQM)	Not Applicable	Circulation or storage space.
B00F - R0008 - Home Base - (61.9 SQM) - Teaching Space: 1	Student Space (28)	
B00F - R0009 - Withdrawal Space - 1hb - (12.11 SQM)	Student Space (5)	
B00F - R0010 - Movement - (17.32 SQM)	Not Applicable	Circulation or storage space.
B00G - R0001 - Movement - (17.32 SQM)	Not Applicable	Circulation or storage space.
B00G - R0002 - Home Base - (61.5 SQM) - Teaching Space: 1	Student Space (28)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00G - R0005 - Movement - (7.14 SQM)	Not Applicable	Circulation or storage space.
B00G - R0006 - Practical Activities - 1hb - (20.32 SQM)	● Student Space (9)	
B00G - R0007 - Movement - (9.01 SQM)	Not Applicable	Circulation or storage space.
B00G - R0008 - Home Base - (61.73 SQM) - Teaching Space: 1	● Student Space (28)	
B00G - R0010 - Withdrawal Space - 1hb - (12.15 SQM)	● Student Space (5)	
B00G - R0011 - Movement - (17.32 SQM)	Not Applicable	Circulation or storage space.
B00G - R9002 - Movement - (48.08 SQM)	Not Applicable	Circulation or storage space.
B00H - R0001 - Movement - (17.32 SQM)	Not Applicable	Circulation or storage space.
B00H - R0002 - Home Base - (61.99 SQM) - Teaching Space: 1	● Student Space (28)	
B00H - R0004 - Movement - (8.79 SQM)	Not Applicable	Circulation or storage space.
B00H - R0005 - Practical Activities - 1hb - (20.47 SQM)	● Student Space (9)	
B00H - R0006 - Movement - (7.12 SQM)	Not Applicable	Circulation or storage space.
B00H - R0008 - Home Base - (61.9 SQM) - Teaching Space: 1	● Student Space (28)	
B00H - R0009 - Withdrawal Space - 1hb - (12.1 SQM)	● Student Space (5)	
B00H - R0010 - Movement - (17.32 SQM)	Not Applicable	Circulation or storage space.
B00I - R0001 - Special Programs Room - (65.07 SQM)	● Student Space (30)	
B00J - R0002 - Practical Activities/Movement - 1hb - (19.01 SQM)	● Student Space (8)	
B00J - R0003 - Home Base - (60.06 SQM) - Teaching Space: 1	● Student Space (27)	
B00J - R0005 - Withdrawal Space - 1hb - (6.54 SQM)	● Student Space (3)	
B00J - R0007 - Practical Activities/Movement - 1hb - (19.24 SQM)	● Student Space (8)	
B00J - R0009 - Home Base - (61.52 SQM) - Teaching Space: 1	● Student Space (28)	
B00J - R0010 - Withdrawal Space - 2hb - (11.73 SQM)	● Student Space (5)	
B00J - R0011 - Home Base - (61.55 SQM) - Teaching Space: 1	● Student Space (28)	
B00J - R0013 - Practical Activities - 1hb - (19.2 SQM)	● Student Space (8)	
B00K - R0002 - Reading Area - (169.68 SQM)	● Student Space (78)	
OS 602 10061 - OS 602 10061 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 12508 - OS 602 12508 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	