

# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Sarah Redfern High School (8551)</b>
<b>AMU REGION:</b>	<b>South Western Sydney</b>
<b>STATE ELECTORATE:</b>	<b>Macquarie Fields</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Campbelltown</b>

8551 - Sarah Redfern High School  
Site Plan (10504)



1:2,032

Printed: 19-Sep-2020

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B001 - R0001 - Deputy Principal Office - (11.69 SQM)	Office (2)	
B001 - R0004 - Administration - Clerical - (12.39 SQM)	Office (3)	
B001 - R0005 - Administration - Executive - (12.25 SQM)	Office (3)	
B001 - R0009 - Principal Office - (26.1 SQM)	Office (6)	
B001 - R0011 - Clinic - (10.94 SQM)	Office (2)	
B001 - R0012 - Administration - Clerical - (10.42 SQM)	Office (2)	
B001 - R0014 - Deputy Principal Office - (18.63 SQM)	Office (4)	
B001 - R0020 - Movement - (22.53 SQM)	Not Applicable	Circulation or storage space.
B001 - R0021 - Administration - Clerical - (44.99 SQM)	Office (11)	
B001 - R0023 - Public Reception - (19.54 SQM)	Not Applicable	Circulation or storage space.
B001 - R0024 - Movement - (56.52 SQM)	Not Applicable	Circulation or storage space.
B001 - R0025 - Staff Study - (22.93 SQM)	Office (5)	
B001 - R1001 - General Learning Space - (50.98 SQM) - Teaching Space: 1	Student Space (23)	
B001 - R1004 - Computer Room - (13.18 SQM)	Student Space (6)	
B001 - R1005 - General Learning Space - (50.97 SQM) - Teaching Space: 1	Student Space (23)	
B001 - R1006 - Movement - (83.63 SQM)	Not Applicable	Circulation or storage space.
B001 - R1007 - Performance Workspace - (50.88 SQM) - Teaching Space: 1	Student Space (23)	
B001 - R1008 - Staff Study - (18.67 SQM)	Office (4)	
B001 - R1011 - General Learning Space - (51.69 SQM) - Teaching Space: 1	Student Space (23)	
B001 - R1013 - Staff Study - (15.88 SQM)	Office (3)	
B002 - R0001 - General Learning Space - (50.91 SQM) - Teaching Space: 1	Student Space (23)	
B002 - R0002 - General Learning Space - (51.55 SQM) - Teaching Space: 1	Student Space (23)	
B002 - R0006 - General Learning Space - (52.13 SQM) - Teaching Space: 1	Student Space (24)	
B002 - R0007 - Fitness Laboratory - (51.7 SQM)	Student Space (23)	
B002 - R0009 - Staff Study - (12.61 SQM)	Office (3)	
B002 - R0011 - Movement - (56.86 SQM)	Not Applicable	Circulation or storage space.
B002 - R0013 - Staff Study - (17.06 SQM)	Office (4)	
B002 - R1001 - General Learning Space - (50.98 SQM) - Teaching Space: 1	Student Space (23)	
B002 - R1002 - General Learning Space - (51.41 SQM) - Teaching Space: 1	Student Space (23)	
B002 - R1005 - General Learning Space - (51.84 SQM) - Teaching Space: 1	Student Space (24)	
B002 - R1006 - General Learning Space - (51.98 SQM) - Teaching Space: 1	Student Space (24)	
B002 - R1008 - Staff Study - (14.02 SQM)	Office (3)	
B002 - R1009 - Staff Study - (20.55 SQM)	Office (5)	
B002 - R1011 - Movement - (68.77 SQM)	Not Applicable	Circulation or storage space.
B002 - R1012 - Movement - (47.64 SQM)	Not Applicable	Circulation or storage space.
B002 - R1013 - Commonroom - (19.44 SQM)	Office (4)	
B003 - R0001 - General Learning Space - (51.62 SQM) - Teaching Space: 1	Student Space (23)	
B003 - R0002 - General Learning Space - (52.06 SQM) - Teaching Space: 1	Student Space (24)	
B003 - R0005 - General Learning Space - (52.49 SQM) - Teaching Space: 1	Student Space (24)	
B003 - R0006 - General Learning Space - (51.77 SQM) - Teaching Space: 1	Student Space (24)	
B003 - R0007 - Staff Study - (12.95 SQM)	Office (3)	
B003 - R0009 - Staff Study - (20.84 SQM)	Office (5)	
B003 - R0010 - Movement - (66.73 SQM)	Not Applicable	Circulation or storage space.
B004 - R0001 - Computer Learning Space - (51.62 SQM) - Teaching Space: 1	Student Space (23)	
B004 - R0002 - General Learning Space - (51.98 SQM) - Teaching Space: 1	Student Space (24)	
B004 - R0005 - Computer Learning Space - (52.56 SQM) - Teaching Space: 1	Student Space (24)	
B004 - R0006 - Computer Learning Space - (76.78 SQM) - Teaching Space: 1	Student Space (35)	
B004 - R0010 - Movement - (70.53 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B004 - R0014 - Staff Study - (18.03 SQM)	Office (4)	
B005 - R0001 - Laboratory L.S. - (101.88 SQM) - Teaching Space: 1	Student Space (47)	
B005 - R0005 - Laboratory L.S. - (104.47 SQM) - Teaching Space: 1	Student Space (48)	
B005 - R0006 - Preparation - Science - (46.48 SQM)	Not Applicable	Circulation or storage space.
B005 - R0007 - Movement - (36.24 SQM)	Not Applicable	Circulation or storage space.
B005 - R1001 - General Learning Space - (51.77 SQM) - Teaching Space: 1	Student Space (24)	
B005 - R1003 - Staff Study - (19.67 SQM)	Office (4)	
B005 - R1004 - General Learning Space - (51.12 SQM) - Teaching Space: 1	Student Space (23)	
B005 - R1005 - General Learning Space - (50.98 SQM) - Teaching Space: 1	Student Space (23)	
B005 - R1009 - Senior Learning Centre - (51.77 SQM)	Student Space (24)	
B005 - R1010 - Movement - (56.26 SQM)	Not Applicable	Circulation or storage space.
B006 - R0002 - Laboratory L.S. - (96.3 SQM) - Teaching Space: 1	Student Space (44)	
B006 - R0003 - Preparation - Science - (44.84 SQM)	Not Applicable	Circulation or storage space.
B006 - R0004 - Laboratory L.S. - (95.72 SQM) - Teaching Space: 1	Student Space (44)	
B006 - R0008 - Dark Room - (24.15 SQM)	Office (6)	
B006 - R0009 - Darkroom Space - (6.9 SQM)	Office (1)	
B007 - R0001 - Laboratory L.S. - (95.61 SQM) - Teaching Space: 1	Student Space (44)	
B007 - R0002 - Preparation - Science - (45.28 SQM)	Not Applicable	Circulation or storage space.
B007 - R0004 - Staff Study - (95.37 SQM)	Office (23)	
B007 - R1001 - Music Learning Space - (86.89 SQM) - Teaching Space: 1	Student Space (40)	
B007 - R1004 - Practice/Seminar - (12.77 SQM)	Not Applicable	Circulation or storage space.
B007 - R1005 - Staff Study - (18.89 SQM)	Office (4)	
B007 - R1007 - Music Learning Space - (63.75 SQM) - Teaching Space: 1	Student Space (29)	
B008 - R0001 - Seminar Space - (51.98 SQM)	Office (12)	
B008 - R0005 - General Learning Space - (50.41 SQM) - Teaching Space: 1	Student Space (23)	
B008 - R0006 - General Learning Space - (52.56 SQM) - Teaching Space: 1	Student Space (24)	
B008 - R0007 - Interview/Office - Type 1 - (12.25 SQM)	Office (3)	
B008 - R0011 - Movement - (51.59 SQM)	Not Applicable	Circulation or storage space.
B008 - R1001 - General Learning Space - (51.91 SQM) - Teaching Space: 1	Student Space (24)	
B008 - R1002 - General Learning Space - (52.27 SQM) - Teaching Space: 1	Student Space (24)	
B008 - R1004 - General Learning Space - (50.69 SQM) - Teaching Space: 1	Student Space (23)	
B008 - R1005 - General Learning Space - (51.84 SQM) - Teaching Space: 1	Student Space (24)	
B008 - R1006 - Staff Study - (12.22 SQM)	Office (3)	
B008 - R1009 - Staff Study - (19.43 SQM)	Office (4)	
B008 - R1010 - Movement - (70.73 SQM)	Not Applicable	Circulation or storage space.
B009 - R0001 - Student Canteen - (67.99 SQM)	Not Applicable	Circulation or storage space.
B009 - R0006 - General Assistants - (9.32 SQM)	Office (2)	
B009 - R1006 - Staff Study - (22.23 SQM)	Office (5)	
B010 - R0001 - Senior Study - (65.07 SQM)	Office (16)	
B010 - R0002 - Staff Study - (25.1 SQM)	Office (6)	
B010 - R0003 - Senior Study - (63.04 SQM)	Office (15)	
B010 - R0010 - Wood Technology Bay - (19.29 SQM)	Not Applicable	Circulation or storage space.
B010 - R0015 - Staff Study - (18.18 SQM)	Office (4)	
B010 - R0020 - Wood Technology L.S. - (87.89 SQM) - Teaching Space: 1	Student Space (40)	
B010 - R0021 - Wood Technology L.S. - (87.51 SQM) - Teaching Space: 1	Student Space (40)	
B010 - R1002 - Food Technology L.S. - (105.4 SQM) - Teaching Space: 1	Student Space (48)	
B010 - R1009 - Preparation - Materials - (20.91 SQM)	Not Applicable	Circulation or storage space.
B010 - R1012 - Food Technology L.S. - (86.16 SQM) - Teaching Space: 1	Student Space (39)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B010 - R1013 - Lecture Space - (36.15 SQM) - Teaching Space: 2	Student Space (16)	
B011 - R0004 - Staff Study - (15.17 SQM)	Office (3)	
B011 - R0005 - Art Learning Space - (62.98 SQM) - Teaching Space: 1	Student Space (29)	
B011 - R0006 - Art Learning Space - (64.01 SQM) - Teaching Space: 1	Student Space (29)	
B011 - R0011 - Workshop - (65.08 SQM)	Student Space (30)	
B011 - R0013 - Art Learning Space - (63.99 SQM) - Teaching Space: 1	Student Space (29)	
B011 - R1006 - Staff Study - (24.05 SQM)	Office (6)	
B011 - R1007 - Commonroom - (19.51 SQM)	Office (4)	
B011 - R1008 - Senior Learning Centre - (89.4 SQM)	Student Space (41)	
B011 - R1010 - Staff Study - (95.18 SQM)	Office (23)	
B011 - R1011 - Staff Kitchen - (12.62 SQM)	Office (3)	
B012 - R0001 - Materials Technology L.S. - (76.51 SQM) - Teaching Space: 1	Student Space (35)	
B012 - R0006 - Metal Technology L.S. - (116.27 SQM) - Teaching Space: 1	Student Space (53)	
B012 - R0007 - Metal Technology Bay - (10.17 SQM)	Not Applicable	Circulation or storage space.
B012 - R1001 - Textiles Technology L.S. - (65.43 SQM) - Teaching Space: 1	Student Space (30)	
B012 - R1006 - Textiles Technology L.S. - (66.68 SQM) - Teaching Space: 1	Student Space (30)	
B012 - R1007 - Staff Study - (17.83 SQM)	Office (4)	
B012 - R1009 - Movement - (26.56 SQM)	Not Applicable	Circulation or storage space.
B013 - R0005 - Staff Kitchen - (20.68 SQM)	Office (5)	
B013 - R0022 - Movement - (5.64 SQM)	Not Applicable	Circulation or storage space.
B013 - R0023 - Main Entry - (16.73 SQM)	Not Applicable	Circulation or storage space.
B013 - R0025 - Movement - (12.94 SQM)	Not Applicable	Circulation or storage space.
B013 - R0028 - Seminar - (36.87 SQM)	Office (9)	
B013 - R0029 - Senior Study - (41.68 SQM)	Office (10)	
B013 - R0030 - Main Area - (390.77 SQM)	Not Applicable	Circulation or storage space.
B013 - R1001 - Computer Learning Space - (40.97 SQM) - Teaching Space: 1	Student Space (19)	
B013 - R1002 - Movement - (5.18 SQM)	Not Applicable	Circulation or storage space.
B013 - R1006 - Study Space - (11.94 SQM)	Not Applicable	Circulation or storage space.
B013 - R1007 - Study Space - (12.56 SQM)	Not Applicable	Circulation or storage space.
B013 - R1017 - Seminar/Study - (23.84 SQM)	Office (5)	
B013 - R1018 - Main Area - (386.8 SQM)	Not Applicable	Circulation or storage space.
B013 - R1020 - Movement - (78.34 SQM)	Not Applicable	Circulation or storage space.
B013 - R1022 - Main Area - (88.41 SQM)	Not Applicable	Circulation or storage space.
B013 - R1024 - Movement - (5.88 SQM)	Not Applicable	Circulation or storage space.
B013 - R2003 - Movement - (5.18 SQM)	Not Applicable	Circulation or storage space.
B014 - R0009 - Movement - (51.52 SQM)	Not Applicable	Circulation or storage space.
B014 - R0010 - Gymnasium - (781.77 SQM)	Student Space (362)	
B014 - R0039 - Movement - (90.27 SQM)	Not Applicable	Circulation or storage space.
B014 - R1003 - Staff Kitchen - (15.93 SQM)	Office (3)	
B014 - R1004 - Commonroom - (70.25 SQM)	Office (17)	
B014 - R1005 - Commonroom - (107.27 SQM)	Office (26)	
B014 - R1015 - Movement - (71.76 SQM)	Not Applicable	Circulation or storage space.