

VENTILATION AUDIT REPORT

SCHOOL:	Sarah Redfern Public School (4509)
AMU REGION:	South Western Sydney
STATE ELECTORATE:	Macquarie Fields
LOCAL GOVERNMENT AREA:	Campbelltown

4509 - Sarah Redfern Public School
Site Plan (10504)



1:2,032

Printed: 07-Aug-2021

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Entry Vestibule - (55.12 SQM)	Not Applicable	Circulation or storage space.
B00A - R0002 - Clerical Office - (12.4 SQM)	Office (3)	
B00A - R0003 - Staff Room Annexe - (12.78 SQM)	Office (3)	
B00A - R0004 - Staff Room Annexe - (12.29 SQM)	Office (3)	
B00A - R0005 - Principal - (22.4 SQM)	Office (5)	
B00A - R0010 - Sick Bay - (8.86 SQM)	Student Space (4)	
B00A - R0011 - Sick Bay - (8.86 SQM)	Student Space (4)	
B00A - R0012 - Clerical Office - (12.26 SQM)	Office (3)	
B00A - R0013 - Staff Room - (15.26 SQM)	Office (3)	
B00A - R0014 - Movement - (14.57 SQM)	Not Applicable	Circulation or storage space.
B00A - R0017 - Duplicating Workroom - (73.84 SQM)	Office (18)	
B00A - R1001 - Practical Activities - 1hb - (12.42 SQM)	Student Space (5)	
B00A - R1002 - Home Base - (61.33 SQM) - Teaching Space: 1	Student Space (28)	
B00A - R1004 - Home Base - (64.85 SQM) - Teaching Space: 1	Student Space (30)	
B00A - R1005 - Movement - (54.16 SQM)	Not Applicable	Circulation or storage space.
B00A - R1011 - Home Base - (61.42 SQM) - Teaching Space: 1	Student Space (28)	
B00A - R1012 - Home Base - (62.83 SQM) - Teaching Space: 1	Student Space (29)	
B00A - R1013 - Practical Activities - 1hb - (11.41 SQM)	Student Space (5)	
B00B - R0001 - Practical Activities - 1hb - (12.25 SQM)	Student Space (5)	
B00B - R0002 - Home Base - (62.65 SQM) - Teaching Space: 1	Student Space (29)	
B00B - R0005 - Home Base - (60.92 SQM) - Teaching Space: 1	Student Space (28)	
B00B - R0006 - Entry Vestibule - (58.93 SQM)	Not Applicable	Circulation or storage space.
B00B - R0013 - Home Base - (63.04 SQM) - Teaching Space: 1	Student Space (29)	
B00B - R0014 - Home Base - (60.85 SQM) - Teaching Space: 1	Student Space (28)	
B00B - R0015 - Practical Activities - 1hb - (12.07 SQM)	Student Space (5)	
B00C - R0006 - Practical Activities - (12.21 SQM)	Student Space (5)	
B00C - R0007 - Movement - (20.95 SQM)	Not Applicable	Circulation or storage space.
B00C - R0022 - Movement - (40.28 SQM)	Not Applicable	Circulation or storage space.
B00C - R0025 - Home Base - (45.93 SQM) - Teaching Space: 1	Student Space (21)	
B00C - R0026 - Home Base - (47.34 SQM) - Teaching Space: 1	Student Space (21)	
B00C - R0028 - Canteen - (56.83 SQM)	Not Applicable	Circulation or storage space.
B00C - R0033 - Movement - (64.43 SQM)	Not Applicable	Circulation or storage space.
B00C - R0034 - Home Base - (45.52 SQM) - Teaching Space: 1	Student Space (21)	
B00C - R0035 - Staff Kitchen - (6.01 SQM)	Office (1)	
B00C - R1003 - Home Base - (63.32 SQM) - Teaching Space: 1	Student Space (29)	
B00C - R1004 - Home Base - (60.54 SQM) - Teaching Space: 1	Student Space (28)	
B00C - R1005 - Practical Activities - 1hb - (12.41 SQM)	Student Space (5)	
B00C - R1015 - Movement - (59.45 SQM)	Not Applicable	Circulation or storage space.
B00C - R1016 - Home Base - S - (59.97 SQM) - Teaching Space: 1	Student Space (27)	
B00C - R1018 - Practical Activities - 1hb - (12.6 SQM)	Student Space (5)	
B00C - R1019 - Home Base - (63.16 SQM) - Teaching Space: 1	Student Space (29)	
B00C - R1021 - Movement - (17.84 SQM)	Not Applicable	Circulation or storage space.
B00D - R0001 - Practical Activities - 1hb - (12.25 SQM)	Student Space (5)	
B00D - R0002 - Home Base - (60.92 SQM) - Teaching Space: 1	Student Space (28)	
B00D - R0004 - Home Base - (62.64 SQM) - Teaching Space: 1	Student Space (29)	
B00D - R0010 - Movement - (62.12 SQM)	Not Applicable	Circulation or storage space.
B00D - R0012 - Home Base - (63.02 SQM) - Teaching Space: 1	Student Space (29)	
B00D - R0014 - Home Base - (61.92 SQM) - Teaching Space: 1	Student Space (28)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00D - R0016 - Practical Activities - (12.26 SQM)	● Student Space (5)	
B00D - R0017 - Interview - (12.92 SQM)	● Office (3)	
B00D - R1003 - Practical Activities - 1hb - (12.25 SQM)	● Student Space (5)	
B00D - R1004 - Home Base - (60.92 SQM) - Teaching Space: 1	● Student Space (28)	
B00D - R1006 - Home Base - (62.64 SQM) - Teaching Space: 1	● Student Space (29)	
B00D - R1011 - Movement - (62.12 SQM)	Not Applicable	Circulation or storage space.
B00D - R1015 - Home Base - (61.92 SQM) - Teaching Space: 1	● Student Space (28)	
B00D - R1016 - Practical Activities - 1hb - (12.25 SQM)	● Student Space (5)	
B00D - R1017 - Home Base - (63.02 SQM) - Teaching Space: 1	● Student Space (29)	
B00F - R0001 - Home Base - (71.93 SQM) - Teaching Space: 1	● Student Space (33)	
B00F - R0004 - Home Base - (72.92 SQM) - Teaching Space: 1	● Student Space (33)	
B00F - R0012 - Home Base - (72.59 SQM) - Teaching Space: 1	● Student Space (33)	
B00F - R0014 - Practical Activities - (23.25 SQM)	● Student Space (10)	
B00F - R0015 - Movement - (25.34 SQM)	Not Applicable	Circulation or storage space.
B00H - R0008 - Stage - (37.72 SQM)	Not Applicable	Circulation or storage space.
B00H - R0011 - Staff Kitchen - (11.77 SQM)	● Office (2)	
B00H - R0014 - Communal Space - (228 SQM)	● Student Space (105)	
B00I - R0002 - Practical Activities - Pre - (25.55 SQM)	● Student Space (11)	
B00I - R0003 - Home Base - Pre - (67.16 SQM) - Teaching Space: 1	● Student Space (31)	
B00I - R0011 - Movement - (33.74 SQM)	Not Applicable	Circulation or storage space.
B00I - R0012 - Practical Activities - Pre - (26.93 SQM)	● Student Space (12)	
B00I - R0013 - Home Base - Pre - (66.88 SQM) - Teaching Space: 1	● Student Space (31)	
B00I - R0016 - Practical Activities - Pre - (25.51 SQM)	● Student Space (11)	