


VENTILATION AUDIT REPORT

SCHOOL:	Sawtell Public School (3042)
AMU REGION:	North Coast
STATE ELECTORATE:	Coffs Harbour
LOCAL GOVERNMENT AREA:	Coffs Harbour

3042 - Sawtell Public School
Site Plan (11901)



Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0003 - Clerical Office - (25.63 SQM)	Office (6)	
B00A - R0004 - Entry Vestibule - (12.01 SQM)	Not Applicable	Circulation or storage space.
B00A - R0005 - Movement - (5.32 SQM)	Not Applicable	Circulation or storage space.
B00A - R0006 - Duplicating Workroom - (17.61 SQM)	Office (4)	
B00A - R0007 - Movement - (13.51 SQM)	Not Applicable	Circulation or storage space.
B00A - R0008 - Interview - (8.15 SQM)	Office (2)	
B00A - R0009 - Deputy Principal - (17.98 SQM)	Office (4)	
B00A - R0010 - Principal - (14.3 SQM)	Office (3)	
B00A - R0012 - Sick Bay - (7.15 SQM)	Student Space (3)	
B00A - R0017 - Home Base - (57.93 SQM) - Teaching Space: 1	Student Space (26)	
B00A - R0018 - Practical Activities - 1hb - (14.86 SQM)	Student Space (6)	
B00A - R1005 - Reading Area - (120.12 SQM) - Teaching Space: 1	Student Space (55)	
B00A - R1009 - Home Base - (72.38 SQM) - Teaching Space: 1	Student Space (33)	
B00B - R0003 - Movement - (5.79 SQM)	Not Applicable	Circulation or storage space.
B00B - R0007 - Interview - (15.51 SQM)	Office (3)	
B00B - R0008 - Home Base - (53.65 SQM) - Teaching Space: 1	Student Space (24)	
B00B - R0009 - Practical Activities - 1hb - (18.81 SQM)	Student Space (8)	
B00B - R0017 - Special Programs Room - (36.54 SQM)	Student Space (16)	
B00B - R1002 - Practical Activities - 1hb - (13.8 SQM)	Student Space (6)	
B00B - R1003 - Home Base - (57.71 SQM) - Teaching Space: 1	Student Space (26)	
B00B - R1004 - Home Base - (57.72 SQM) - Teaching Space: 1	Student Space (26)	
B00B - R1005 - Practical Activities - 1hb - (13.8 SQM)	Student Space (6)	
B00C - R0016 - Canteen - (29.79 SQM)	Not Applicable	Circulation or storage space.
B00C - R0022 - Reading Area - (143.55 SQM)	Student Space (66)	
B00D - R0005 - Home Base - (88.73 SQM) - Teaching Space: 1	Student Space (41)	
B00D - R0006 - Home Base - (59.32 SQM) - Teaching Space: 1	Student Space (27)	
B00D - R0009 - Movement - (12.93 SQM)	Not Applicable	Circulation or storage space.
B00D - R0011 - Home Base - (58.99 SQM) - Teaching Space: 1	Student Space (27)	
B00E - R0008 - Home Base - (66.72 SQM) - Teaching Space: 1	Student Space (30)	
B00E - R0009 - Home Base - (66.61 SQM) - Teaching Space: 1	Student Space (30)	
B00F - R0003 - Withdrawal Space - 1hb - (43.97 SQM)	Student Space (20)	
B00F - R0004 - Withdrawal Space - 1hb - (38.34 SQM)	Student Space (17)	
B00F - R0005 - Withdrawal Space - 1hb - (14.79 SQM)	Student Space (6)	
B00H - R0002 - Home Base - (62.55 SQM) - Teaching Space: 1	Student Space (29)	
B00H - R0004 - Withdrawal Space - 1hb - (26.84 SQM)	Student Space (12)	
B00J - R0001 - Communal Space - (147.2 SQM)	Student Space (68)	
B00J - R0002 - Raised Platform - (59.03 SQM)	Not Applicable	Circulation or storage space.
B00J - R0016 - Movement - (7.66 SQM)	Not Applicable	Circulation or storage space.
B00J - R0017 - Movement - (11.28 SQM)	Not Applicable	Circulation or storage space.
OS 602 13671 - OS 602 13671 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	
OS 602 14278 - OS 602 14278 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	
OS 602 15496 - OS 602 15496 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	