


VENTILATION AUDIT REPORT

SCHOOL:	Schofields Public School (3046)
AMU REGION:	Western Sydney
STATE ELECTORATE:	Riverstone
LOCAL GOVERNMENT AREA:	Blacktown

3046 - Schofields Public School
Site Plan (11281)



1:1,077









Printed: 10-Jul-2021

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0028 - Canteen - (52.24 SQM)	Not Applicable	Circulation or storage space.
B00L - R0001 - Home Base - (47.54 SQM) - Teaching Space: 1	● Student Space (22)	
B00L - R0002 - Home Base - (47.71 SQM) - Teaching Space: 1	● Student Space (22)	
B00L - R0007 - Movement - (44.66 SQM)	Not Applicable	Circulation or storage space.
B00M - R0001 - Communal Space - (145.33 SQM)	● Student Space (67)	
B00M - R0002 - Raised Platform - (56.11 SQM)	Not Applicable	Circulation or storage space.
B00M - R0003 - Movement - (15.28 SQM)	Not Applicable	Circulation or storage space.
B00M - R0004 - Movement - (7.14 SQM)	Not Applicable	Circulation or storage space.
B00M - R0018 - Movement - (11.85 SQM)	Not Applicable	Circulation or storage space.
B00P - R0001 - Entry Vestibule - (18.13 SQM)	Not Applicable	Circulation or storage space.
B00P - R0002 - Interview - (12.71 SQM)	● Office (3)	
B00P - R0003 - Interview - (28.77 SQM)	● Office (7)	
B00P - R0004 - Sick Bay - (10.6 SQM)	● Student Space (4)	
B00P - R0006 - Clerical Office - (12.01 SQM)	● Office (3)	
B00P - R0007 - Principal - (16.9 SQM)	● Office (4)	
B00P - R0008 - Deputy Principal - (12.35 SQM)	● Office (3)	
B00P - R0009 - Deputy Principal - (11.57 SQM)	● Office (2)	
B00P - R0010 - Deputy Principal - (25.79 SQM)	● Office (6)	
B00P - R0011 - Staff Room - (108.12 SQM)	● Office (27)	
B00P - R0012 - Staff Kitchen - (35.75 SQM)	● Office (8)	
B00P - R0013 - Movement - (7.46 SQM)	Not Applicable	Circulation or storage space.
B00P - R0016 - Interview - (12.29 SQM)	● Office (3)	
B00P - R0017 - Clerical/Printing - (23.86 SQM)	Not Applicable	Circulation or storage space.
B00P - R0018 - Clerical Office - (44.82 SQM)	● Office (11)	
B00P - R0019 - Movement - (47.97 SQM)	Not Applicable	Circulation or storage space.
B00P - R0020 - Home Base - (65.88 SQM) - Teaching Space: 1	● Student Space (30)	
B00P - R0021 - Practical Activities - (20.04 SQM)	● Student Space (9)	
B00P - R0023 - Withdrawal Space - 1hb - (11.19 SQM)	● Student Space (5)	
B00P - R0024 - Home Base X2 - (120.22 SQM) - Teaching Space: 2	● Student Space (55)	
B00P - R0025 - Withdrawal Space - 2hb - (12.48 SQM)	● Student Space (5)	
B00P - R0026 - Practical Activities - 2hb - (54.38 SQM)	● Student Space (25)	
B00P - R0029 - Presentation Area - (57.89 SQM)	Not Applicable	Circulation or storage space.
B00P - R0030 - Home Base X2 - (116.61 SQM) - Teaching Space: 2	● Student Space (54)	
B00P - R0031 - Withdrawal Space - 2hb - (11.76 SQM)	● Student Space (5)	
B00P - R0032 - Home Base X2 - (114.28 SQM) - Teaching Space: 2	● Student Space (53)	
B00P - R0033 - Withdrawal - M - (12.81 SQM)	● Student Space (5)	
B00P - R0034 - Practical Activities - 4hb - (56.62 SQM)	● Student Space (26)	
B00P - R0037 - Presentation Area - (64.07 SQM)	Not Applicable	Circulation or storage space.
B00P - R0038 - Home Base X2 - (103.65 SQM) - Teaching Space: 2	● Student Space (48)	
B00P - R0039 - Withdrawal - M - (9.97 SQM)	● Student Space (4)	
B00P - R0040 - Home Base - (75.51 SQM) - Teaching Space: 1	● Student Space (35)	
B00P - R0041 - Withdrawal - M - (13.62 SQM)	● Student Space (6)	
B00P - R0042 - Practical Activities - 2hb - (38.51 SQM)	● Student Space (17)	
B00P - R0045 - Home Base - (72.44 SQM) - Teaching Space: 1	● Student Space (33)	
B00P - R0046 - Withdrawal - M - (14 SQM)	● Student Space (6)	
B00P - R0062 - Tiered Learning Space - (12.97 SQM)	● Student Space (6)	
B00P - R0065 - Movement - (13.89 SQM)	Not Applicable	Circulation or storage space.
B00P - R0099 - Outdoor Learning Area - (58.49 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00P - R0100 - Outdoor Learning Area - (57.74 SQM)	Not Applicable	Circulation or storage space.
B00P - R0102 - Movement - (15.49 SQM)	Not Applicable	Circulation or storage space.
B00P - R1001 - Home Base X4 - (231.25 SQM) - Teaching Space: 4	● Student Space (107)	
B00P - R1002 - Practical Activities - 2hb - (33.26 SQM)	● Student Space (15)	
B00P - R1003 - Withdrawal Space - 2hb - (9.37 SQM)	● Student Space (4)	
B00P - R1004 - Withdrawal Space - 2hb - (11.42 SQM)	● Student Space (5)	
B00P - R1006 - Presentation Area - (52.7 SQM)	Not Applicable	Circulation or storage space.
B00P - R1007 - Home Base X3 - (153.64 SQM) - Teaching Space: 3	● Student Space (71)	
B00P - R1008 - Practical Activities - 3hb - (59.84 SQM)	● Student Space (27)	
B00P - R1009 - Presentation Area - (63.21 SQM)	Not Applicable	Circulation or storage space.
B00P - R1010 - Withdrawal Space - 2hb - (10.07 SQM)	● Student Space (4)	
B00P - R1011 - Withdrawal Space - 2hb - (12.99 SQM)	● Student Space (6)	
B00P - R1017 - Home Base X3 - (148.33 SQM) - Teaching Space: 3	● Student Space (68)	
B00P - R1018 - Practical Activities - 3hb - (58.32 SQM)	● Student Space (27)	
B00P - R1019 - Presentation Area - (63.3 SQM)	Not Applicable	Circulation or storage space.
B00P - R1020 - Withdrawal Space - 2hb - (8.8 SQM)	● Student Space (4)	
B00P - R1021 - Withdrawal Space - 2hb - (11.97 SQM)	● Student Space (5)	
B00P - R1022 - Home Base X3 - (151.43 SQM) - Teaching Space: 3	● Student Space (70)	
B00P - R1023 - Practical Activities - 3hb - (50.23 SQM)	● Student Space (23)	
B00P - R1024 - Presentation Area - (66.21 SQM)	Not Applicable	Circulation or storage space.
B00P - R1025 - Withdrawal Space - 2hb - (13.66 SQM)	● Student Space (6)	
B00P - R1026 - Withdrawal Space - 2hb - (12.84 SQM)	● Student Space (5)	
B00P - R1027 - Home Base X3 - (155.05 SQM) - Teaching Space: 3	● Student Space (71)	
B00P - R1028 - Presentation Area - (66.78 SQM)	Not Applicable	Circulation or storage space.
B00P - R1029 - Withdrawal Space - 2hb - (10.16 SQM)	● Student Space (4)	
B00P - R1030 - Withdrawal Space - 2hb - (11.94 SQM)	● Student Space (5)	
B00P - R1031 - Practical Activities - 3hb - (61.43 SQM)	● Student Space (28)	
B00P - R1032 - Movement - (139.43 SQM)	Not Applicable	Circulation or storage space.
B00P - R1033 - Movement - (6.21 SQM)	Not Applicable	Circulation or storage space.
B00P - R1034 - Movement - (68.19 SQM)	Not Applicable	Circulation or storage space.
B00P - R1035 - Interview - (10.92 SQM)	● Office (2)	
B00P - R1039 - Movement - (57.31 SQM)	Not Applicable	Circulation or storage space.
B00P - R1064 - Tiered Learning Space - (8.2 SQM)	● Student Space (3)	
B00P - R1065 - Practical Activities - 2hb - (36.18 SQM)	● Student Space (16)	
OS 508 15100 - OS 508 15100 - Administration - (114 SQM)	● Office (28)	
OS 523 10392 - OS 523 10392 - Staff Study With Toilets - (76 SQM)	● Office (19)	
OS 606 14348 - OS 606 14348 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	● Student Space (35)	
OS 606 15690 - OS 606 15690 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	● Student Space (35)	
OS 606 17093 - OS 606 17093 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	● Student Space (35)	
OS 606 19245 - OS 606 19245 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	● Student Space (35)	
OS 606 19253 - OS 606 19253 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	● Student Space (35)	
OS 606 19320 - OS 606 19320 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	● Student Space (35)	
OS 606 19332 - OS 606 19332 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	● Student Space (35)	
OS 606 19334 - OS 606 19334 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	● Student Space (35)	
OS 606 19335 - OS 606 19335 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	● Student Space (35)	
OS 606 19336 - OS 606 19336 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	● Student Space (35)	
OS 606 19337 - OS 606 19337 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	● Student Space (35)	
OS 606 19339 - OS 606 19339 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	● Student Space (35)	

Entity Location	Audit Condition Classification (Capacity)	Comment
OS 606 19412 - OS 606 19412 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	 Student Space (35)	
OS 606 19413 - OS 606 19413 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	 Student Space (35)	
OS 606 19414 - OS 606 19414 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	 Student Space (35)	
OS 606 19415 - OS 606 19415 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	 Student Space (35)	
OS 606 19416 - OS 606 19416 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	 Student Space (35)	
OS 606 19418 - OS 606 19418 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	 Student Space (35)	
OS 606 19419 - OS 606 19419 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	 Student Space (35)	
OS 606 19420 - OS 606 19420 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	 Student Space (35)	