


# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Scone High School (8409)</b>
<b>AMU REGION:</b>	<b>Hunter/Central Coast</b>
<b>STATE ELECTORATE:</b>	<b>Upper Hunter</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Upper Hunter</b>

8409 - Scone High School  
Site Plan (11283)



1:2,659

Printed: 07-Nov-2020

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - General Assistants - (8 SQM)	Office (2)	
B00A - R0002 - Movement - (19.81 SQM)	Not Applicable	Circulation or storage space.
B00A - R0003 - Administration - Clerical - (19.55 SQM)	Office (4)	
B00A - R0004 - Administration - Clerical - (12.94 SQM)	Office (3)	
B00A - R0005 - Administration - Clerical - (12.79 SQM)	Office (3)	
B00A - R0006 - Deputy Principal Office - (19.55 SQM)	Office (4)	
B00A - R0007 - Commonroom - (99.19 SQM)	Office (24)	
B00A - R0008 - Interview/Office - Type 1 - (13.48 SQM)	Office (3)	
B00A - R0009 - Interview/Office - Type 1 - (13.01 SQM)	Office (3)	
B00A - R0011 - Teachers Aides - (25.98 SQM)	Office (6)	
B00A - R0012 - Duplicating Workroom - (7.84 SQM)	Office (1)	
B00A - R0013 - Clinic - Girls - (15.74 SQM)	Office (3)	
B00A - R0015 - Interview/Office - Type 1 - (13.01 SQM)	Office (3)	
B00A - R0024 - Principal Office - (19.6 SQM)	Office (4)	
B00A - R0025 - Administration - Clerical - (12.01 SQM)	Office (3)	
B00A - R0026 - Movement - (95.33 SQM)	Not Applicable	Circulation or storage space.
B00A - R1001 - Darkroom Space - (13.38 SQM)	Office (3)	
B00A - R1003 - Seminar/Technology Space - (26.09 SQM)	Office (6)	
B00A - R1004 - Design L.S. - (52.4 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1005 - General Learning Space - (53.35 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1010 - Staff Study - (25.95 SQM)	Office (6)	
B00A - R1011 - General Learning Space - (53.35 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1012 - General Learning Space - (53.72 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1013 - General Learning Space - (69.54 SQM) - Teaching Space: 1	Student Space (32)	
B00B - R0001 - Movement - (22.73 SQM)	Not Applicable	Circulation or storage space.
B00B - R0004 - Laboratory L.S. - (92.44 SQM) - Teaching Space: 1	Student Space (42)	
B00B - R0005 - Preparation - (28.92 SQM)	Not Applicable	Circulation or storage space.
B00B - R0007 - Laboratory L.S. - (92.45 SQM) - Teaching Space: 1	Student Space (42)	
B00B - R0009 - Staff Study - (12.8 SQM)	Office (3)	
B00B - R0010 - Food Technology L.S. - (66.36 SQM) - Teaching Space: 1	Student Space (30)	
B00B - R0011 - Seminar/Technology Space - (25.58 SQM)	Office (6)	
B00B - R0014 - Movement - (13.91 SQM)	Not Applicable	Circulation or storage space.
B00B - R1001 - Movement - (8.62 SQM)	Not Applicable	Circulation or storage space.
B00B - R1002 - Movement - (8.67 SQM)	Not Applicable	Circulation or storage space.
B00B - R1004 - Staff Study - (17.41 SQM)	Office (4)	
B00B - R1005 - Art Learning Space - (65.92 SQM) - Teaching Space: 1	Student Space (30)	
B00B - R1010 - Materials Technology L.S. - (65.92 SQM) - Teaching Space: 1	Student Space (30)	
B00B - R1011 - Computer Learning Space - (52.61 SQM) - Teaching Space: 1	Student Space (24)	
B00B - R1014 - Staff Study - (25.95 SQM)	Office (6)	
B00B - R1017 - Music Learning Space - (53.35 SQM) - Teaching Space: 1	Student Space (24)	
B00B - R1019 - Movement - (8.76 SQM)	Not Applicable	Circulation or storage space.
B00B - R1020 - Movement - (8.26 SQM)	Not Applicable	Circulation or storage space.
B00B - R1021 - Movement - (116.79 SQM)	Not Applicable	Circulation or storage space.
B00C - R0005 - Materials Technology L.S. - (80.39 SQM) - Teaching Space: 1	Student Space (37)	
B00C - R0008 - Materials Workshop - Type 2 - (115.41 SQM)	Student Space (53)	
B00D - R0004 - Movement - (12.39 SQM)	Not Applicable	Circulation or storage space.
B00D - R0006 - Movement - (5.96 SQM)	Not Applicable	Circulation or storage space.
B00D - R0012 - Student Canteen - (42.62 SQM)	Not Applicable	Circulation or storage space.
B00D - R0014 - Movement - (5.97 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00D - R0017 - Movement - (11.95 SQM)	Not Applicable	Circulation or storage space.
B00D - R0023 - Movement - (180.91 SQM)	Not Applicable	Circulation or storage space.
B00F - R0001 - General Learning Space - (53.72 SQM) - Teaching Space: 1	● Student Space (24)	
B00F - R0002 - General Learning Space - S/P - (52.99 SQM) - Teaching Space: 1	● Student Space (24)	
B00F - R0007 - Staff Study - (26.31 SQM)	○ Office (6)	
B00F - R0008 - General Learning Space - (52.91 SQM)	● Student Space (24)	
B00F - R0010 - Staff Study - (12.76 SQM)	○ Office (3)	
B00F - R0012 - Computer Learning Space - (53.35 SQM) - Teaching Space: 1	● Student Space (24)	
B00F - R0017 - Staff Kitchen - (12.43 SQM)	○ Office (3)	
B00G - R0001 - Movement - (19.74 SQM)	Not Applicable	Circulation or storage space.
B00G - R0003 - General Learning Space - (53.35 SQM)	● Student Space (24)	
B00G - R0004 - General Learning Space - (53.35 SQM)	● Student Space (24)	
B00G - R0005 - Art Learning Space - (52.4 SQM) - Teaching Space: 1	● Student Space (24)	
B00G - R0008 - Staff Study - (25.74 SQM)	○ Office (6)	
B00G - R0009 - Staff Study - (12.83 SQM)	○ Office (3)	
B00G - R0012 - Movement - (11.01 SQM)	Not Applicable	Circulation or storage space.
B00G - R0013 - Movement - (14.87 SQM)	Not Applicable	Circulation or storage space.
B00G - R0020 - General Learning Space - (78.64 SQM) - Teaching Space: 1	● Student Space (36)	
B00G - R0021 - Music Learning Space - (12.76 SQM) - Teaching Space: 1	● Student Space (5)	
B00G - R0022 - Music Learning Space - (12.87 SQM) - Teaching Space: 1	● Student Space (5)	
B00G - R1001 - General Learning Space - (52.41 SQM) - Teaching Space: 1	● Student Space (24)	
B00G - R1004 - General Learning Space - (52.62 SQM) - Teaching Space: 1	● Student Space (24)	
B00G - R1005 - General Learning Space - (52.63 SQM) - Teaching Space: 1	● Student Space (24)	
B00G - R1008 - Staff Study - (25.95 SQM)	○ Office (6)	
B00G - R1009 - Staff Study - (12.87 SQM)	○ Office (3)	
B00G - R1010 - Staff Study - (12.86 SQM)	○ Office (3)	
B00G - R1015 - Computer Learning Space - (52.41 SQM) - Teaching Space: 1	● Student Space (24)	
B00G - R1016 - Movement - (117.36 SQM)	Not Applicable	Circulation or storage space.
B00H - R0003 - Movement - (5.02 SQM)	Not Applicable	Circulation or storage space.
B00H - R0004 - Laboratory L.S. - (92.46 SQM) - Teaching Space: 1	● Student Space (42)	
B00H - R0005 - Growing/Breeding - (9.79 SQM)	Not Applicable	Circulation or storage space.
B00H - R0006 - Preparation - (28.77 SQM)	Not Applicable	Circulation or storage space.
B00H - R0007 - Laboratory L.S. - (92.6 SQM) - Teaching Space: 1	● Student Space (42)	
B00H - R0009 - Movement - (10.43 SQM)	Not Applicable	Circulation or storage space.
B00H - R0011 - Movement - (8.85 SQM)	Not Applicable	Circulation or storage space.
B00H - R1003 - Movement - (5.06 SQM)	Not Applicable	Circulation or storage space.
B00H - R1005 - Performance Workspace - (52.62 SQM) - Teaching Space: 1	● Student Space (24)	
B00H - R1009 - General Learning Space - (52.62 SQM) - Teaching Space: 1	● Student Space (24)	
B00H - R1010 - General Learning Space - (52.62 SQM) - Teaching Space: 1	● Student Space (24)	
B00H - R1011 - General Learning Space - (51.9 SQM) - Teaching Space: 1	● Student Space (24)	
B00H - R1013 - Movement - (82.13 SQM)	Not Applicable	Circulation or storage space.
B00I - M0001 - Seminar - (29.08 SQM)	○ Office (7)	
B00I - M0002 - Seminar - (71.24 SQM)	○ Office (17)	
B00I - R0004 - Workroom - (16.22 SQM)	○ Office (4)	
B00I - R0005 - Seminar - (55.73 SQM)	○ Office (13)	
B00I - R0007 - Main Area - (157.39 SQM)	Not Applicable	Circulation or storage space.
B00I - R0008 - Entry - (22.42 SQM)	Not Applicable	Circulation or storage space.
B00I - R0010 - Seminar - (27.08 SQM)	○ Office (6)	
B00I - R0012 - Seminar - (22.93 SQM)	○ Office (5)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00I - R0013 - Entry - (21.44 SQM)	Not Applicable	Circulation or storage space.
B00I - R0014 - Seminar - (75.94 SQM)	Office (18)	
B00I - R0015 - Staff Study - (15.02 SQM)	Office (3)	
B00I - R0016 - Entry - (10.33 SQM)	Not Applicable	Circulation or storage space.
B00I - R0017 - Seminar - (10.13 SQM)	Office (2)	
B00I - R0018 - Senior Study - (50.02 SQM)	Office (12)	
B00J - R0002 - Movement - (5.29 SQM)	Not Applicable	Circulation or storage space.
B00J - R0003 - Staff Study - (12.62 SQM)	Office (3)	
B00J - R0004 - Staff Study - (6.13 SQM)	Office (1)	
B00J - R0007 - Materials Technology L.S. - (65.77 SQM) - Teaching Space: 1	Student Space (30)	
B00J - R0009 - Staff Study - (12.79 SQM)	Office (3)	
B00J - R0011 - Movement - (12.33 SQM)	Not Applicable	Circulation or storage space.
B00J - R1001 - Laboratory L.S. - (65.78 SQM) - Teaching Space: 1	Student Space (30)	
B00J - R1002 - Preparation - (12.64 SQM)	Not Applicable	Circulation or storage space.
B00J - R1003 - General Learning Space - (52.62 SQM) - Teaching Space: 1	Student Space (24)	
B00J - R1004 - Movement - (47.83 SQM)	Not Applicable	Circulation or storage space.
B00K - R0011 - Staff Study - (12.23 SQM)	Office (3)	
B00K - R0013 - Materials Technology L.S. - (97.9 SQM) - Teaching Space: 1	Student Space (45)	
B00K - R0014 - Materials Workshop - Type 2 - (136.08 SQM)	Student Space (63)	
B00K - R0016 - Welding Area - (10.17 SQM)	Not Applicable	Circulation or storage space.
B00K - R0017 - Outdoor Workshop - (38.93 SQM)	Not Applicable	Circulation or storage space.
B00L - R0006 - Staff Study - (9.07 SQM)	Office (2)	
B00L - R0007 - Staff Study - (9.07 SQM)	Office (2)	
B00L - R0008 - Staff Kitchen - (15.7 SQM)	Office (3)	
B00L - R0014 - Stage - (65.98 SQM)	Not Applicable	Circulation or storage space.
B00L - R0015 - Movement - (53.52 SQM)	Not Applicable	Circulation or storage space.
B00L - R0016 - Multi-Purpose Space - (461.08 SQM)	Student Space (213)	