

VENTILATION AUDIT REPORT

SCHOOL:	Scotts Head Public School (3635)
AMU REGION:	North Coast
STATE ELECTORATE:	Oxley
LOCAL GOVERNMENT AREA:	Nambucca

3635 - Scotts Head Public School
Site Plan (11284)



1:911

Printed: 08-Dec-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B001 - R0003 - Withdrawal Space - 1hb - (5.99 SQM)	● Student Space (2)	
B001 - R0004 - Home Base - (62.37 SQM) - Teaching Space: 1	● Student Space (28)	
B001 - R0005 - Home Base - (62.37 SQM) - Teaching Space: 1	● Student Space (28)	
B001 - R0006 - Withdrawal Space - 1hb - (5.99 SQM)	● Student Space (2)	
B001 - R0009 - Practical Activities - 1hb - (17.71 SQM)	● Student Space (8)	
B001 - R0010 - Practical Activities - 1hb - (17.71 SQM)	● Student Space (8)	
B002 - R0003 - Reading Area - (43.81 SQM)	● Student Space (20)	
B002 - R0005 - Practical Activities - 1hb - (17.95 SQM)	● Student Space (8)	
B002 - R0006 - Special Programs Room - (43.81 SQM)	● Student Space (20)	
B002 - R0009 - Presentation Area - (103.59 SQM)	Not Applicable	Circulation or storage space.
B004 - R0002 - Canteen - (18.72 SQM)	Not Applicable	Circulation or storage space.
B005 - R0002 - Clerical Office - (19.07 SQM)	● Office (4)	
B005 - R0004 - Sick Bay - (7.68 SQM)	● Student Space (3)	
B005 - R0007 - Movement - (19.49 SQM)	Not Applicable	Circulation or storage space.
B005 - R0008 - Staff Room - (21.11 SQM)	● Office (5)	
B005 - R0009 - Staff Kitchen - (5.6 SQM)	● Office (1)	
B005 - R0011 - Principal - (17.09 SQM)	● Office (4)	
B005 - R0012 - Reading Area - (71.72 SQM)	● Student Space (33)	
OS 602 10170 - OS 602 10170 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 14356 - OS 602 14356 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 606 19065 - OS 606 19065 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	● Student Space (35)	