

# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Seaforth Public School (1104)</b>
<b>AMU REGION:</b>	<b>Northern Sydney</b>
<b>STATE ELECTORATE:</b>	<b>Manly</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Northern Beaches</b>

1104 - Seaforth Public School  
Site Plan (11717)



## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - M1001 - Withdrawal Space - 1hb - (11 SQM)	● Student Space (5)	
B00A - R0001 - Home Base - (50.73 SQM) - Teaching Space: 1	● Student Space (23)	
B00A - R0002 - Home Base - (66.44 SQM) - Teaching Space: 1	● Student Space (30)	
B00A - R0006 - Principal - (15.95 SQM)	● Office (3)	
B00A - R0025 - Movement - (7.45 SQM)	Not Applicable	Circulation or storage space.
B00A - R0030 - Interview - (12.81 SQM)	● Office (3)	
B00A - R0034 - Clerical Office - (46.91 SQM)	● Office (11)	
B00A - R0035 - Entry Vestibule - (28.57 SQM)	Not Applicable	Circulation or storage space.
B00A - R0036 - Interview - (17.22 SQM)	● Office (4)	
B00A - R0037 - Staff Kitchen - (10.66 SQM)	● Office (2)	
B00A - R0038 - Staff Room - (65.93 SQM)	● Office (16)	
B00A - R0039 - Movement - (83.24 SQM)	Not Applicable	Circulation or storage space.
B00A - R0040 - Duplicating Workroom - (13.91 SQM)	● Office (3)	
B00A - R0041 - Sick Bay - (6.05 SQM)	● Student Space (2)	
B00A - R1001 - Home Base - (47.58 SQM) - Teaching Space: 1	● Student Space (22)	
B00A - R1002 - Home Base - (62.53 SQM) - Teaching Space: 1	● Student Space (29)	
B00A - R1003 - Home Base - (46.76 SQM) - Teaching Space: 1	● Student Space (21)	
B00A - R1004 - Home Base - (46.77 SQM) - Teaching Space: 1	● Student Space (21)	
B00A - R1005 - Home Base - (47.36 SQM) - Teaching Space: 1	● Student Space (21)	
B00A - R1006 - Home Base - (53.95 SQM) - Teaching Space: 1	● Student Space (25)	
B00A - R1009 - Deputy Principal - (13.72 SQM)	● Office (3)	
B00A - R1010 - Staff Room Annexe - (11.33 SQM)	● Office (2)	
B00A - R1011 - Movement - (90.7 SQM)	Not Applicable	Circulation or storage space.
B00B - R0003 - Clerical Office - (10.31 SQM)	● Office (2)	
B00B - R0004 - Home Base - (51.68 SQM) - Teaching Space: 1	● Student Space (23)	
B00B - R0005 - Home Base - (51.68 SQM) - Teaching Space: 1	● Student Space (23)	
B00B - R0006 - Home Base - (51.68 SQM) - Teaching Space: 1	● Student Space (23)	
B00B - R0010 - Home Base - (66.68 SQM) - Teaching Space: 1	● Student Space (30)	
B00B - R0014 - Home Base - (66.97 SQM) - Teaching Space: 1	● Student Space (31)	
B00B - R0019 - Communal Space - (145.4 SQM)	● Student Space (67)	
B00B - R0020 - Raised Platform - (33.27 SQM)	Not Applicable	Circulation or storage space.
B00B - R0025 - Movement - (158.47 SQM)	Not Applicable	Circulation or storage space.
B00B - R0029 - Staff Room Annexe - (18.65 SQM)	● Office (4)	
B00B - R0030 - Entry Vestibule - (20.17 SQM)	Not Applicable	Circulation or storage space.
B00B - R0041 - Movement - (27.8 SQM)	Not Applicable	Circulation or storage space.
B00B - R0042 - Movement - (27.65 SQM)	Not Applicable	Circulation or storage space.
B00B - R0043 - Movement - (27.03 SQM)	Not Applicable	Circulation or storage space.
B00B - R0050 - Movement - (37.16 SQM)	Not Applicable	Circulation or storage space.
B00B - R0051 - Withdrawal - Pre - (13.44 SQM)	● Student Space (6)	
B00B - R0052 - Withdrawal - Pre - (13.61 SQM)	● Student Space (6)	
B00B - R0053 - Withdrawal - Pre - (55.18 SQM)	● Student Space (25)	
B00B - R0054 - Movement - (47.35 SQM)	Not Applicable	Circulation or storage space.
B00B - R1003 - Staff Room - (32.41 SQM)	● Office (8)	
B00B - R1004 - Duplicating Workroom - (12.44 SQM)	● Office (3)	
B00B - R1005 - Home Base - M - (51.4 SQM) - Teaching Space: 1	● Student Space (23)	
B00B - R1006 - Home Base - (51.53 SQM) - Teaching Space: 1	● Student Space (23)	
B00B - R1007 - Home Base - (51.41 SQM) - Teaching Space: 1	● Student Space (23)	
B00B - R1012 - Home Base - (66.68 SQM) - Teaching Space: 1	● Student Space (30)	
B00B - R1016 - Home Base - (66.97 SQM) - Teaching Space: 1	● Student Space (31)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00B - R1017 - Movement - (142.26 SQM)	Not Applicable	Circulation or storage space.
B00B - R9004 - Canteen - (26.79 SQM)	Not Applicable	Circulation or storage space.
B00B - R9005 - Movement - (88.63 SQM)	Not Applicable	Circulation or storage space.
B00B - R9010 - Movement - (5.51 SQM)	Not Applicable	Circulation or storage space.
B00C - R0003 - Staff Kitchen - (36.79 SQM)	Office (9)	
B00C - R0011 - Home Base - (57.12 SQM) - Teaching Space: 1	Student Space (26)	
B00C - R0012 - Home Base - (55.03 SQM) - Teaching Space: 1	Student Space (25)	
B00C - R0014 - Practical Activities - 1hb - (12.93 SQM)	Student Space (5)	
B00C - R0015 - Withdrawal Space - 2hb - (7.45 SQM)	Student Space (3)	
B00C - R0016 - Practical Activities - 1hb - (13.05 SQM)	Student Space (6)	
B00D - R0001 - Movement - (12.79 SQM)	Not Applicable	Circulation or storage space.
B00I - R0001 - Home Base - (54.19 SQM) - Teaching Space: 1	Student Space (25)	
B00I - R0002 - Home Base - (53.89 SQM) - Teaching Space: 1	Student Space (25)	
B00I - R0003 - Withdrawal Space - 1hb - (17.33 SQM)	Student Space (8)	
B00L - R0003 - Reading Area - (230 SQM)	Student Space (106)	
B00M - R0009 - Communal Space - (202.88 SQM)	Student Space (94)	
B00M - R0010 - Movement - (12.82 SQM)	Not Applicable	Circulation or storage space.
B00M - R0012 - Raised Platform - (61.62 SQM)	Not Applicable	Circulation or storage space.
B00M - R0013 - Movement - (6.64 SQM)	Not Applicable	Circulation or storage space.
B00N - R0001 - Canteen - (27.99 SQM)	Not Applicable	Circulation or storage space.
B00O - R0001 - Home Base - (61.09 SQM) - Teaching Space: 1	Student Space (28)	
B00O - R0002 - Home Base - (61.53 SQM) - Teaching Space: 1	Student Space (28)	
B00O - R0003 - Home Base - (61.97 SQM) - Teaching Space: 1	Student Space (28)	
B00O - R0004 - Home Base - (61.09 SQM) - Teaching Space: 1	Student Space (28)	