

VENTILATION AUDIT REPORT

SCHOOL:	Seaham Public School (3048)
AMU REGION:	Hunter/Central Coast
STATE ELECTORATE:	Port Stephens
LOCAL GOVERNMENT AREA:	Port Stephens

3048 - Seaham Public School
Site Plan (10706)



1:779

Printed: 21-Mar-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Clerical Office/Workroom - (16.94 SQM)	Office (4)	
B00A - R0004 - Staff Room - (23 SQM)	Office (5)	
B00A - R0005 - Staff Kitchen - (9.93 SQM)	Office (2)	
B00A - R0007 - Principal - (14.5 SQM)	Office (3)	
B00A - R0008 - Entry Vestibule - (10.56 SQM)	Not Applicable	Circulation or storage space.
B00A - R0009 - Movement - (5.3 SQM)	Not Applicable	Circulation or storage space.
B00A - R0010 - Clerical Office - (10.65 SQM)	Office (2)	
B00B - R0001 - Movement - (33.43 SQM)	Not Applicable	Circulation or storage space.
B00B - R0005 - Home Base - (56.88 SQM) - Teaching Space: 1	Student Space (26)	
B00B - R0006 - Movement - (6.24 SQM)	Not Applicable	Circulation or storage space.
B00C - R0001 - Entry Vestibule - (8.73 SQM)	Not Applicable	Circulation or storage space.
B00C - R0003 - Interview - (7.16 SQM)	Office (1)	
B00C - R0009 - Interview - (12.69 SQM)	Office (3)	
B00D - R0002 - Home Base - (61.15 SQM) - Teaching Space: 1	Student Space (28)	
B00D - R0003 - Practical Activities - 1hb - (16.2 SQM)	Student Space (7)	
B00D - R0004 - Movement - (34.14 SQM)	Not Applicable	Circulation or storage space.
B00D - R0005 - Practical Activities - 1hb - (16.17 SQM)	Student Space (7)	
B00D - R0006 - Home Base - (61.08 SQM) - Teaching Space: 1	Student Space (28)	
B00D - R0008 - Movement - (13.99 SQM)	Not Applicable	Circulation or storage space.
B00D - R0009 - Withdrawal Space - 1hb - (11.85 SQM)	Student Space (5)	
B00D - R0010 - Movement - (13.89 SQM)	Not Applicable	Circulation or storage space.
B00E - R0002 - Home Base - (61.16 SQM) - Teaching Space: 1	Student Space (28)	
B00E - R0003 - Practical Activities - 1hb - (16.18 SQM)	Student Space (7)	
B00E - R0004 - Movement - (34.11 SQM)	Not Applicable	Circulation or storage space.
B00E - R0005 - Practical Activities - 1hb - (16.2 SQM)	Student Space (7)	
B00E - R0006 - Home Base - (61.07 SQM) - Teaching Space: 1	Student Space (28)	
B00E - R0008 - Movement - (13.91 SQM)	Not Applicable	Circulation or storage space.
B00E - R0009 - Withdrawal Space - 1hb - (11.89 SQM)	Student Space (5)	
B00E - R0010 - Movement - (13.89 SQM)	Not Applicable	Circulation or storage space.
B00G - R0001 - Canteen - (30.41 SQM)	Not Applicable	Circulation or storage space.
B00G - R0002 - Withdrawal Space - 1hb - (14.16 SQM)	Student Space (6)	
B00G - R0006 - Movement - (37.07 SQM)	Not Applicable	Circulation or storage space.
B00I - R0001 - Practical Activities - 1hb - (18.82 SQM)	Student Space (8)	
B00I - R0003 - Home Base - (60.12 SQM) - Teaching Space: 1	Student Space (27)	
B00I - R0004 - Withdrawal Space - 2hb - (11.75 SQM)	Student Space (5)	
B00I - R0005 - Practical Activities - 1hb - (18.84 SQM)	Student Space (8)	
B00I - R0007 - Home Base - (60.2 SQM) - Teaching Space: 1	Student Space (27)	
B00I - R0009 - Movement - (8.49 SQM)	Not Applicable	Circulation or storage space.
B00I - R0011 - Movement - (39.28 SQM)	Not Applicable	Circulation or storage space.
B00J - R0001 - Movement - (23.92 SQM)	Not Applicable	Circulation or storage space.
B00J - R0002 - Reading Area - (166.45 SQM)	Student Space (77)	
B00K - R0002 - Communal Space - (147.38 SQM)	Student Space (68)	
B00K - R0003 - Movement - (5.55 SQM)	Not Applicable	Circulation or storage space.
B00K - R0004 - Raised Platform - (62.01 SQM)	Not Applicable	Circulation or storage space.
B00K - R0006 - Movement - (10.43 SQM)	Not Applicable	Circulation or storage space.
OS 603 16819 - OS 603 16819 - Learning Unit - Standard With P.A.A. A/C - (76 SQM)	Student Space (35)	
OS 606 15164 - OS 606 15164 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	Student Space (35)	