


VENTILATION AUDIT REPORT

SCHOOL:	Seven Hills High School (8231)
AMU REGION:	Western Sydney
STATE ELECTORATE:	Seven Hills
LOCAL GOVERNMENT AREA:	Blacktown

8231 - Seven Hills High School
Site Plan (12854)



1:1,674

Printed: 21-Mar-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0017 - Interview/Meeting - (14.58 SQM)	Office (3)	
B00A - R0018 - Public Reception - (36 SQM)	Not Applicable	Circulation or storage space.
B00A - R0019 - Administration - Clerical - (48.2 SQM)	Office (12)	
B00A - R0021 - Movement - (44.87 SQM)	Not Applicable	Circulation or storage space.
B00A - R0022 - Interview/Meeting - (10.14 SQM)	Office (2)	
B00A - R0025 - Staff Kitchen - (10.44 SQM)	Office (2)	
B00A - R0027 - Deputy Principal Office - (15.88 SQM)	Office (3)	
B00A - R0028 - Deputy Principal Office - (15.57 SQM)	Office (3)	
B00A - R0029 - Principal Office - (18.57 SQM)	Office (4)	
B00A - R0031 - Student Waiting - (12.33 SQM)	Not Applicable	Circulation or storage space.
B00B - R0001 - Movement - (24.71 SQM)	Not Applicable	Circulation or storage space.
B00B - R0003 - Movement - (24.23 SQM)	Not Applicable	Circulation or storage space.
B00B - R0004 - Staff Study - (18.64 SQM)	Office (4)	
B00B - R0006 - Computer Learning Space - (54.14 SQM) - Teaching Space: 1	Student Space (25)	
B00B - R0007 - Preparation - (9.1 SQM)	Not Applicable	Circulation or storage space.
B00B - R0008 - Preparation - (15.93 SQM)	Not Applicable	Circulation or storage space.
B00B - R0009 - Performance Workspace - (93.08 SQM) - Teaching Space: 1	Student Space (43)	
B00B - R0010 - Movement - (28.4 SQM)	Not Applicable	Circulation or storage space.
B00B - R1001 - Movement - (5.85 SQM)	Not Applicable	Circulation or storage space.
B00B - R1002 - Movement - (15.1 SQM)	Not Applicable	Circulation or storage space.
B00B - R1005 - Staff Study - (19.07 SQM)	Office (4)	
B00B - R1006 - Staff Study - (52.22 SQM)	Office (13)	
B00B - R1010 - Music Learning Space - (73.87 SQM) - Teaching Space: 1	Student Space (34)	
B00B - R1012 - Movement - (40.83 SQM)	Not Applicable	Circulation or storage space.
B00C - R0001 - Laboratory L.S. - (94.4 SQM) - Teaching Space: 1	Student Space (43)	
B00C - R0002 - Preparation - (24.36 SQM)	Not Applicable	Circulation or storage space.
B00C - R0003 - Staff Room - (14.27 SQM)	Office (3)	
B00C - R0005 - Staff Room - (42.61 SQM)	Office (10)	
B00C - R0006 - Withdrawal Space - 1hb - (65.18 SQM)	Student Space (30)	
B00C - R0007 - Withdrawal Space - 1hb - (65.18 SQM)	Student Space (30)	
B00C - R0008 - General Learning Space - (65.18 SQM) - Teaching Space: 1	Student Space (30)	
B00C - R0009 - General Learning Space - (65.18 SQM) - Teaching Space: 1	Student Space (30)	
B00C - R0010 - General Learning Space - (65.18 SQM) - Teaching Space: 1	Student Space (30)	
B00C - R0011 - Staff Room - (9.23 SQM)	Office (2)	
B00C - R0012 - Staff Room - (9.23 SQM)	Office (2)	
B00C - R0013 - Seminar - Type 1 - (18.71 SQM)	Office (4)	
B00C - R0015 - Movement - (20.66 SQM)	Not Applicable	Circulation or storage space.
B00C - R0018 - Movement - (19.07 SQM)	Not Applicable	Circulation or storage space.
B00C - R0019 - Movement - (106.16 SQM)	Not Applicable	Circulation or storage space.
B00C - R1001 - Design L.S. - (58.43 SQM) - Teaching Space: 1	Student Space (27)	
B00C - R1003 - Design L.S. - (51.85 SQM) - Teaching Space: 1	Student Space (24)	
B00C - R1006 - Music Learning Space - (64.82 SQM) - Teaching Space: 1	Student Space (30)	
B00C - R1007 - General Learning Space - (51.86 SQM) - Teaching Space: 1	Student Space (24)	
B00C - R1008 - General Learning Space - (51.86 SQM) - Teaching Space: 1	Student Space (24)	
B00C - R1009 - General Learning Space - (51.86 SQM) - Teaching Space: 1	Student Space (24)	
B00C - R1010 - Computer Learning Space - (65.18 SQM) - Teaching Space: 1	Student Space (30)	
B00C - R1011 - General Learning Space - (38.53 SQM) - Teaching Space: 1	Student Space (17)	
B00C - R1012 - Computer Learning Space - (38.53 SQM) - Teaching Space: 1	Student Space (17)	
B00C - R1013 - Staff Study - (38.89 SQM)	Office (9)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00C - R1016 - Movement - (5.12 SQM)	Not Applicable	Circulation or storage space.
B00C - R1017 - Movement - (18.77 SQM)	Not Applicable	Circulation or storage space.
B00C - R1018 - Movement - (112.5 SQM)	Not Applicable	Circulation or storage space.
B00D - R0001 - Performance Workspace - (114.26 SQM) - Teaching Space: 1	● Student Space (53)	
B00D - R0002 - Interview/Office - Type 1 - (11.04 SQM)	○ Office (2)	
B00D - R0003 - Interview/Office - Type 1 - (13.63 SQM)	○ Office (3)	
B00D - R0004 - Staff Room - (65.27 SQM)	○ Office (16)	
B00D - R0005 - Interview/Office - Type 1 - (10.56 SQM)	○ Office (2)	
B00D - R0006 - Interview/Office - Type 1 - (10.77 SQM)	○ Office (2)	
B00D - R0007 - Movement - (30.55 SQM)	Not Applicable	Circulation or storage space.
B00D - R0009 - Movement - (24 SQM)	Not Applicable	Circulation or storage space.
B00D - R0011 - Movement - (24.41 SQM)	Not Applicable	Circulation or storage space.
B00D - R0013 - Movement - (5.8 SQM)	Not Applicable	Circulation or storage space.
B00D - R1001 - Art Learning Space - (85.08 SQM) - Teaching Space: 1	● Student Space (39)	
B00D - R1004 - General Learning Space - (51.87 SQM) - Teaching Space: 1	● Student Space (24)	
B00D - R1005 - Staff Study - (51.87 SQM)	○ Office (12)	
B00D - R1008 - Movement - (34.46 SQM)	Not Applicable	Circulation or storage space.
B00D - R1009 - Movement - (6.24 SQM)	Not Applicable	Circulation or storage space.
B00D - R1010 - Movement - (15.26 SQM)	Not Applicable	Circulation or storage space.
B00D - R1011 - Movement - (5.37 SQM)	Not Applicable	Circulation or storage space.
B00E - R0001 - Food Technology L.S. - (65.64 SQM) - Teaching Space: 1	● Student Space (30)	
B00E - R0003 - Preparation - (12.5 SQM)	Not Applicable	Circulation or storage space.
B00E - R0005 - Food Technology L.S. - (91.48 SQM) - Teaching Space: 1	● Student Space (42)	
B00E - R0008 - Food/Research Space - (22.26 SQM)	Not Applicable	Circulation or storage space.
B00E - R0009 - Staff Study - (18.73 SQM)	○ Office (4)	
B00E - R0011 - Study Space - (25.06 SQM)	Not Applicable	Circulation or storage space.
B00E - R0012 - Movement - (52 SQM)	Not Applicable	Circulation or storage space.
B00E - R0013 - Movement - (204 SQM)	Not Applicable	Circulation or storage space.
B00E - R0015 - Student Canteen - (58.57 SQM)	Not Applicable	Circulation or storage space.
B00E - R0022 - Duplicating Workroom - (64.46 SQM)	○ Office (16)	
B00E - R0023 - Movement - (19.04 SQM)	Not Applicable	Circulation or storage space.
B00E - R0025 - Movement - (24.03 SQM)	Not Applicable	Circulation or storage space.
B00E - R0026 - Movement - (53.61 SQM)	Not Applicable	Circulation or storage space.
B00E - R1001 - General Learning Space - (65.65 SQM) - Teaching Space: 1	● Student Space (30)	
B00E - R1005 - Design L.S. - (64.83 SQM) - Teaching Space: 1	● Student Space (30)	
B00E - R1007 - Movement - (24.67 SQM)	Not Applicable	Circulation or storage space.
B00E - R1008 - General Learning Space - (51.86 SQM) - Teaching Space: 1	● Student Space (24)	
B00E - R1009 - General Learning Space - (51.87 SQM) - Teaching Space: 1	● Student Space (24)	
B00E - R1010 - Interview/Office - Type 1 - (19.63 SQM)	○ Office (4)	
B00E - R1013 - Interview/Office - Type 1 - (21.79 SQM)	○ Office (5)	
B00E - R1016 - Commonroom - (78.16 SQM)	○ Office (19)	
B00E - R1017 - Staff Study - (19.13 SQM)	○ Office (4)	
B00E - R1020 - Movement - (87.61 SQM)	Not Applicable	Circulation or storage space.
B00E - R1021 - Movement - (15.31 SQM)	Not Applicable	Circulation or storage space.
B00E - R1022 - Movement - (5.81 SQM)	Not Applicable	Circulation or storage space.
B00E - R1023 - Gymnasium - (104.74 SQM)	● Student Space (48)	
B00F - R0001 - Workshop Area - (54.79 SQM)	● Student Space (25)	
B00F - R0002 - Welding Area - (13.25 SQM)	Not Applicable	Circulation or storage space.
B00F - R0003 - Materials Technology L.S. - (72.27 SQM) - Teaching Space: 1	● Student Space (33)	
B00F - R0004 - Metal Technology Bay - (21.77 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00F - R0009 - Design/Technology L.S. - (72.29 SQM) - Teaching Space: 1	● Student Space (33)	
B00F - R0010 - Movement - (7.18 SQM)	Not Applicable	Circulation or storage space.
B00F - R0012 - Movement - (8.12 SQM)	Not Applicable	Circulation or storage space.
B00F - R0013 - Movement - (12.17 SQM)	Not Applicable	Circulation or storage space.
B00G - R0001 - Materials Technology L.S. - (79.25 SQM) - Teaching Space: 1	● Student Space (36)	
B00G - R0005 - Movement - (6.13 SQM)	Not Applicable	Circulation or storage space.
B00G - R0007 - Materials Technology L.S. - (78.81 SQM) - Teaching Space: 1	● Student Space (36)	
B00G - R0008 - Movement - (7.99 SQM)	Not Applicable	Circulation or storage space.
B00G - R0010 - Staff Study - (26.82 SQM)	● Office (6)	
B00G - R0012 - Movement - (9.97 SQM)	Not Applicable	Circulation or storage space.
B00K - R0001 - Staff Kitchen - (17.1 SQM)	● Office (4)	
B00K - R0002 - Movement - (21.52 SQM)	Not Applicable	Circulation or storage space.
B00K - R0007 - Multi-Purpose Space - (443.07 SQM)	● Student Space (205)	
B00K - R0008 - Movement - (6.13 SQM)	Not Applicable	Circulation or storage space.
B00K - R0009 - Stage - (90.97 SQM)	Not Applicable	Circulation or storage space.
B00K - R0010 - Movement - (6.13 SQM)	Not Applicable	Circulation or storage space.
B00K - R0011 - Movement - (9.57 SQM)	Not Applicable	Circulation or storage space.
B00L - M1002 - Seminar - (38.25 SQM)	● Office (9)	
B00L - M1003 - Main Area - (68.05 SQM)	Not Applicable	Circulation or storage space.
B00L - M1005 - Interview/Office - Type 1 - (15.2 SQM)	● Office (3)	
B00L - R0001 - Laboratory L.S. - (91.45 SQM) - Teaching Space: 1	● Student Space (42)	
B00L - R0005 - Laboratory L.S. - (91.44 SQM) - Teaching Space: 1	● Student Space (42)	
B00L - R0008 - Laboratory L.S. - (91.45 SQM) - Teaching Space: 1	● Student Space (42)	
B00L - R0009 - Staff Study - (44.47 SQM)	● Office (11)	
B00L - R0011 - Laboratory L.S. - (91.44 SQM) - Teaching Space: 1	● Student Space (42)	
B00L - R0013 - Movement - (40.53 SQM)	Not Applicable	Circulation or storage space.
B00L - R0020 - Preparation - Science - (40.45 SQM)	Not Applicable	Circulation or storage space.
B00L - R1001 - General Learning Space - (72.66 SQM) - Teaching Space: 1	● Student Space (33)	
B00L - R1002 - Main Area - (293.67 SQM)	Not Applicable	Circulation or storage space.
B00L - R1003 - Seminar - (12.88 SQM)	● Office (3)	
B00L - R1004 - Seminar - (12.14 SQM)	● Office (3)	
B00L - R1008 - Seminar - (11.69 SQM)	● Office (2)	
B00L - R1009 - Seminar - (12.88 SQM)	● Office (3)	
B00L - R1010 - Audio Visual Workroom - (28.5 SQM)	● Student Space (13)	
B00L - R1012 - Workroom - (17.63 SQM)	● Office (4)	
B00L - R1015 - Entry - (34.25 SQM)	Not Applicable	Circulation or storage space.
B00L - R1018 - Movement - (24.7 SQM)	Not Applicable	Circulation or storage space.
B00M - R0009 - Movement - (46.77 SQM)	Not Applicable	Circulation or storage space.