

VENTILATION AUDIT REPORT

SCHOOL:	Seven Hills Public School (3931)
AMU REGION:	Western Sydney
STATE ELECTORATE:	Blacktown
LOCAL GOVERNMENT AREA:	Blacktown

3931 - Seven Hills Public School
Site Plan (11286)



1:1,084

Printed: 21-Mar-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00D - R0004 - Movement - (37.01 SQM)	Not Applicable	Circulation or storage space.
B00D - R0006 - Home Base - (54.17 SQM) - Teaching Space: 1	● Student Space (25)	
B00D - R0007 - Home Base - (54.03 SQM) - Teaching Space: 1	● Student Space (25)	
B00D - R0008 - Movement - (8.87 SQM)	Not Applicable	Circulation or storage space.
B00D - R0011 - Practical Activities - 1hb - (12.88 SQM)	● Student Space (5)	
B00D - R0012 - Movement - (38.88 SQM)	Not Applicable	Circulation or storage space.
B00D - R0013 - Practical Activities - 1hb - (13.84 SQM)	● Student Space (6)	
B00D - R0014 - Home Base - (41.22 SQM) - Teaching Space: 1	● Student Space (19)	
B00D - R0015 - Home Base - (53.88 SQM) - Teaching Space: 1	● Student Space (24)	
B00H - R0001 - Principal - (15.73 SQM)	● Office (3)	
B00H - R0002 - Movement - (16.2 SQM)	Not Applicable	Circulation or storage space.
B00H - R0007 - Clerical Office - (32.05 SQM)	● Office (8)	
B00H - R0009 - Duplicating Workroom - (32.33 SQM)	● Office (8)	
B00H - R0010 - Home Base - (64.9 SQM) - Teaching Space: 1	● Student Space (30)	
B00H - R0013 - Movement - (7.73 SQM)	Not Applicable	Circulation or storage space.
B00H - R0014 - Home Base - (65.09 SQM) - Teaching Space: 1	● Student Space (30)	
B00H - R0015 - Home Base - (65.18 SQM) - Teaching Space: 1	● Student Space (30)	
B00H - R0017 - Movement - (12.08 SQM)	Not Applicable	Circulation or storage space.
B00H - R0019 - Staff Room Annexe - (24.66 SQM)	● Office (6)	
B00H - R0020 - Deputy Principal - (7.56 SQM)	● Office (1)	
B00I - R0001 - Home Base - (66.42 SQM) - Teaching Space: 1	● Student Space (30)	
B00I - R0004 - Movement - (8.51 SQM)	Not Applicable	Circulation or storage space.
B00I - R0006 - Home Base - (65.37 SQM) - Teaching Space: 1	● Student Space (30)	
B00J - R0001 - Home Base - (57.06 SQM) - Teaching Space: 1	● Student Space (26)	
B00J - R0003 - Movement - (6.57 SQM)	Not Applicable	Circulation or storage space.
B00J - R0005 - Home Base - (57.06 SQM) - Teaching Space: 1	● Student Space (26)	
B00K - R0002 - Reading Area - (91.47 SQM)	● Student Space (42)	
B00L - R0001 - Canteen - (22.32 SQM)	Not Applicable	Circulation or storage space.
B00L - R0005 - Practical Activities - (15.96 SQM)	● Student Space (7)	
B00L - R0006 - Home Base - (57.76 SQM) - Teaching Space: 1	● Student Space (26)	