

VENTILATION AUDIT REPORT

SCHOOL:	Seven Hills West Public School (4162)
AMU REGION:	Western Sydney
STATE ELECTORATE:	Blacktown
LOCAL GOVERNMENT AREA:	Blacktown

4162 - Seven Hills West Public School
Site Plan (11288)



Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0003 - Clerical Office - (22.76 SQM)	Office (5)	
B00A - R0010 - Principal - (16.78 SQM)	Office (4)	
B00A - R0014 - Movement - (16.03 SQM)	Not Applicable	Circulation or storage space.
B00A - R0015 - Movement - (6.02 SQM)	Not Applicable	Circulation or storage space.
B00A - R0016 - Staff Kitchen - (8.17 SQM)	Office (2)	
B00A - R0017 - Staff Room - (58.77 SQM)	Office (14)	
B00A - R0018 - Entry Vestibule - (16.81 SQM)	Not Applicable	Circulation or storage space.
B00A - R0019 - Clerical Office - (10.83 SQM)	Office (2)	
B00A - R0020 - Principal - (15.23 SQM)	Office (3)	
B00B - R0001 - Home Base - M - (63.51 SQM) - Teaching Space: 1	Student Space (29)	
B00B - R0012 - Home Base - M - (64.22 SQM) - Teaching Space: 1	Student Space (29)	
B00B - R0013 - Movement - (18.94 SQM)	Not Applicable	Circulation or storage space.
B00C - R0002 - Special Programs Room - (46.93 SQM)	Student Space (21)	
B00C - R0003 - Home Base - (46.74 SQM) - Teaching Space: 1	Student Space (21)	
B00C - R0004 - Movement - (19.82 SQM)	Not Applicable	Circulation or storage space.
B00D - R0002 - Staff Kitchen - (23.2 SQM)	Office (5)	
B00D - R0005 - Movement - (20.64 SQM)	Not Applicable	Circulation or storage space.
B00E - R0004 - Practical Activities - M - 1hb - (17.53 SQM)	Student Space (8)	
B00E - R0005 - Home Base - M - (48.22 SQM) - Teaching Space: 1	Student Space (22)	
B00E - R0007 - Home Base - M - (48.4 SQM) - Teaching Space: 1	Student Space (22)	
B00E - R0008 - Practical Activities - M - 1hb - (17.26 SQM)	Student Space (8)	
B00H - R0004 - Communal Space - (132.51 SQM)	Student Space (61)	
B00H - R0009 - Movement - (8.2 SQM)	Not Applicable	Circulation or storage space.
B00J - R0001 - Home Base - (65.49 SQM) - Teaching Space: 1	Student Space (30)	
B00J - R0005 - Movement - (15.33 SQM)	Not Applicable	Circulation or storage space.
B00J - R0007 - Home Base - (65.5 SQM) - Teaching Space: 1	Student Space (30)	
B00J - R0014 - Movement - (5.28 SQM)	Not Applicable	Circulation or storage space.
B00M - R0001 - Home Base - (56.94 SQM) - Teaching Space: 1	Student Space (26)	
B00M - R0004 - Home Base - (56.94 SQM) - Teaching Space: 1	Student Space (26)	
B00M - R0005 - Movement - (6.34 SQM)	Not Applicable	Circulation or storage space.
B00N - R0001 - Home Base - (63.76 SQM) - Teaching Space: 1	Student Space (29)	
B00N - R0004 - Movement - (6.38 SQM)	Not Applicable	Circulation or storage space.
B00N - R0007 - Home Base - (63.61 SQM) - Teaching Space: 1	Student Space (29)	
B00O - R0006 - Home Base - (90.69 SQM) - Teaching Space: 1	Student Space (42)	
B00O - R0007 - Home Base - (90.99 SQM) - Teaching Space: 1	Student Space (42)	
B00P - R0004 - Home Base - Pre - (40.99 SQM) - Teaching Space: 1	Student Space (19)	
B00P - R0006 - Withdrawal - Pre - (11.92 SQM)	Student Space (5)	
B00P - R0010 - Home Base - Pre - (33.16 SQM) - Teaching Space: 1	Student Space (15)	
B00P - R0011 - Practical Activities - Pre - (34.35 SQM)	Student Space (15)	
B00P - R0015 - Movement - (24.15 SQM)	Not Applicable	Circulation or storage space.
B00Q - R0002 - Home Base - M - (61.99 SQM) - Teaching Space: 1	Student Space (28)	
B00Q - R0003 - Practical Activities - M - 1hb - (5.54 SQM)	Student Space (2)	
B00Q - R0005 - Practical Activities - E - (19.85 SQM)	Student Space (9)	
B00Q - R0008 - Practical Activities - 1hb - (5.61 SQM)	Student Space (2)	
B00Q - R0009 - Home Base - (61.95 SQM) - Teaching Space: 1	Student Space (28)	
B00Q - R0010 - Movement - (15.4 SQM)	Not Applicable	Circulation or storage space.
B00R - R0002 - Home Base - (62.32 SQM) - Teaching Space: 1	Student Space (28)	
B00R - R0003 - Practical Activities - 1hb - (5.12 SQM)	Student Space (2)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00R - R0008 - Interview - (16.87 SQM)	Office (4)	
B00R - R0010 - Practical Activities - 1hb - (11.35 SQM)	Student Space (5)	
B00R - R0011 - Home Base - (55.97 SQM) - Teaching Space: 1	Student Space (25)	
B00R - R0012 - Movement - (15.98 SQM)	Not Applicable	Circulation or storage space.
B00S - R0001 - Home Base - (56.95 SQM) - Teaching Space: 1	Student Space (26)	
B00S - R0004 - Home Base - (56.79 SQM) - Teaching Space: 1	Student Space (26)	
B00S - R0005 - Movement - (6.37 SQM)	Not Applicable	Circulation or storage space.
B00T - R0001 - Movement - (12.8 SQM)	Not Applicable	Circulation or storage space.
B00T - R0002 - Canteen - (16.81 SQM)	Not Applicable	Circulation or storage space.
B00U - R0001 - Home Base - (65.01 SQM) - Teaching Space: 1	Student Space (30)	
B00U - R0007 - Interview - (15.83 SQM)	Office (3)	
B00U - R0011 - Home Base - (65.22 SQM) - Teaching Space: 1	Student Space (30)	
B00U - R0012 - Movement - (17.75 SQM)	Not Applicable	Circulation or storage space.
B00U - R0014 - Movement - (5.45 SQM)	Not Applicable	Circulation or storage space.
B00V - R0001 - Reading Area - (158.52 SQM)	Student Space (73)	
B00V - R0003 - Movement - (11.65 SQM)	Not Applicable	Circulation or storage space.
B00W - R0001 - Communal Space - (146.9 SQM)	Student Space (68)	
B00W - R0002 - Raised Platform - (59.89 SQM)	Not Applicable	Circulation or storage space.
B00W - R0003 - Movement - (6.62 SQM)	Not Applicable	Circulation or storage space.
B00W - R0004 - Movement - (11.74 SQM)	Not Applicable	Circulation or storage space.
B00W - R0005 - Movement - (11.62 SQM)	Not Applicable	Circulation or storage space.
B00W - R0018 - Canteen - (26.35 SQM)	Not Applicable	Circulation or storage space.
OS 602 14004 - OS 602 14004 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	