

VENTILATION AUDIT REPORT

SCHOOL:	Shalvey Public School (4476)
AMU REGION:	Western Sydney
STATE ELECTORATE:	Mount Druitt
LOCAL GOVERNMENT AREA:	Blacktown

4476 - Shalvey Public School
Site Plan (11289)



1:1,121

Printed: 21-Mar-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B003 - R0014 - Movement - (119.84 SQM)	Not Applicable	Circulation or storage space.
B003 - R0015 - Practical Activities - 1hb - (18.54 SQM)	● Student Space (8)	
B003 - R0016 - Home Base - (55.85 SQM) - Teaching Space: 1	● Student Space (25)	
B003 - R0017 - Home Base - (55.28 SQM) - Teaching Space: 1	● Student Space (25)	
B003 - R0018 - Practical Activities - 1hb - (17.21 SQM)	● Student Space (7)	
B003 - R0019 - Home Base - (58.06 SQM) - Teaching Space: 1	● Student Space (26)	
B003 - R0020 - Practical Activities - 1hb - (16.4 SQM)	● Student Space (7)	
B003 - R0022 - Practical Activities - 1hb - (13.8 SQM)	● Student Space (6)	
B003 - R0023 - Home Base - (60.25 SQM) - Teaching Space: 1	● Student Space (27)	
B003 - R0024 - Practical Activities - 1hb - (14.1 SQM)	● Student Space (6)	
B003 - R0025 - Home Base - (60.64 SQM) - Teaching Space: 1	● Student Space (28)	
B003 - R1008 - Home Base - (74.05 SQM) - Teaching Space: 1	● Student Space (34)	
B003 - R1009 - Movement - (86.29 SQM)	Not Applicable	Circulation or storage space.
B003 - R1011 - Practical Activities - 1hb - (14.08 SQM)	● Student Space (6)	
B003 - R1012 - Home Base - (60.4 SQM) - Teaching Space: 1	● Student Space (28)	
B003 - R1013 - Practical Activities - 1hb - (18.8 SQM)	● Student Space (8)	
B003 - R1014 - Home Base - (55.6 SQM) - Teaching Space: 1	● Student Space (25)	
B003 - R1015 - Home Base - (55.61 SQM) - Teaching Space: 1	● Student Space (25)	
B003 - R1016 - Practical Activities - 1hb - (17.71 SQM)	● Student Space (8)	
B003 - R1017 - Home Base - (58.21 SQM) - Teaching Space: 1	● Student Space (27)	
B003 - R1018 - Practical Activities - 1hb - (16.1 SQM)	● Student Space (7)	
B004 - R0007 - Movement - (51.05 SQM)	Not Applicable	Circulation or storage space.
B004 - R0008 - Home Base - (59.92 SQM) - Teaching Space: 1	● Student Space (27)	
B004 - R0009 - Practical Activities - 1hb - (14.39 SQM)	● Student Space (6)	
B004 - R0011 - Practical Activities - 1hb - (19.41 SQM)	● Student Space (9)	
B004 - R0012 - Home Base - (53.92 SQM) - Teaching Space: 1	● Student Space (25)	
B004 - R0013 - Home Base - (54.47 SQM) - Teaching Space: 1	● Student Space (25)	
B004 - R0014 - Practical Activities - 1hb - (19.02 SQM)	● Student Space (8)	
B004 - R1006 - Movement - (51.97 SQM)	Not Applicable	Circulation or storage space.
B004 - R1007 - Home Base - (60.64 SQM) - Teaching Space: 1	● Student Space (28)	
B004 - R1008 - Practical Activities - 1hb - (13.86 SQM)	● Student Space (6)	
B004 - R1010 - Practical Activities - 1hb - (19.43 SQM)	● Student Space (9)	
B004 - R1011 - Home Base - (54.06 SQM) - Teaching Space: 1	● Student Space (25)	
B004 - R1012 - Home Base - (54.71 SQM) - Teaching Space: 1	● Student Space (25)	
B004 - R1013 - Practical Activities - 1hb - (18.78 SQM)	● Student Space (8)	
B00A - R0001 - Interview - (12.42 SQM)	● Office (3)	
B00A - R0002 - Entry Vestibule - (21.53 SQM)	Not Applicable	Circulation or storage space.
B00A - R0003 - Clerical Office - (12.01 SQM)	● Office (3)	
B00A - R0004 - Sick Bay - (8.83 SQM)	● Student Space (4)	
B00A - R0005 - Interview - (15.32 SQM)	● Office (3)	
B00A - R0006 - Clerical Office/Workroom - (11.83 SQM)	● Office (2)	
B00A - R0008 - Movement - (46.57 SQM)	Not Applicable	Circulation or storage space.
B00A - R0010 - Staff Room - (74.3 SQM)	● Office (18)	
B00A - R0011 - Staff Kitchen - (8.37 SQM)	● Office (2)	
B00A - R0014 - Duplicating Workroom - (14.87 SQM)	● Office (3)	
B00A - R0017 - Principal - (23.31 SQM)	● Office (5)	
B00A - R0018 - Interview - (16.41 SQM)	● Office (4)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0020 - Movement - (160.96 SQM)	Not Applicable	Circulation or storage space.
B00A - R1001 - Reading Area - (172.4 SQM)	● Student Space (79)	
B00A - R1002 - Reading Area - (49.11 SQM)	● Student Space (22)	
B00A - R1005 - Movement - (37.31 SQM)	Not Applicable	Circulation or storage space.
B00A - R1011 - Movement - (86.45 SQM)	Not Applicable	Circulation or storage space.
B00B - R0007 - Canteen - (29.96 SQM)	Not Applicable	Circulation or storage space.
B00B - R0014 - Movement - (189.33 SQM)	Not Applicable	Circulation or storage space.
B00B - R0015 - Communal Space - (209.38 SQM)	● Student Space (97)	
B00B - R0016 - Raised Platform - (58.57 SQM)	Not Applicable	Circulation or storage space.
B00B - R0017 - Movement - (31.52 SQM)	Not Applicable	Circulation or storage space.
B00D - R0006 - Practical Activities - 1hb - (13.44 SQM)	● Student Space (6)	
B00D - R0007 - Home Base - (82.18 SQM) - Teaching Space: 1	● Student Space (38)	
B00D - R0008 - Home Base - (81.91 SQM) - Teaching Space: 1	● Student Space (38)	
B00D - R0009 - Practical Activities - 1hb - (13.51 SQM)	● Student Space (6)	
B00D - R0011 - Movement - (40.72 SQM)	Not Applicable	Circulation or storage space.
B00I - R0001 - Practical Activities - 1hb - (19.62 SQM)	● Student Space (9)	
B00I - R0002 - Home Base - (53.98 SQM) - Teaching Space: 1	● Student Space (25)	
B00I - R0004 - Home Base - (54.06 SQM) - Teaching Space: 1	● Student Space (25)	
B00I - R0005 - Practical Activities - 1hb - (19.51 SQM)	● Student Space (9)	
B00I - R0010 - Home Base - (74.27 SQM) - Teaching Space: 1	● Student Space (34)	
B00I - R0012 - Practical Activities - 1hb - (23.66 SQM)	● Student Space (10)	
B00I - R0013 - Home Base - (75.69 SQM) - Teaching Space: 1	● Student Space (35)	
B00I - R0017 - Movement - (136.37 SQM)	Not Applicable	Circulation or storage space.
B00I - R0020 - Practical Activities - 1hb - (19.19 SQM)	● Student Space (8)	
B00I - R0021 - Home Base - (55.76 SQM) - Teaching Space: 1	● Student Space (25)	
B00I - R1008 - Interview - (12.15 SQM)	● Office (3)	
B00I - R1012 - Home Base - (54.27 SQM) - Teaching Space: 1	● Student Space (25)	
B00I - R1013 - Practical Activities - 1hb - (18.62 SQM)	● Student Space (8)	
B00I - R1014 - Movement - (143.67 SQM)	Not Applicable	Circulation or storage space.
B00I - R1016 - Home Base - (60.48 SQM) - Teaching Space: 1	● Student Space (28)	
B00I - R1017 - Practical Activities - 1hb - (18.72 SQM)	● Student Space (8)	
B00I - R1018 - Practical Activities - 1hb - (18.91 SQM)	● Student Space (8)	
B00I - R1019 - Home Base - (55.58 SQM) - Teaching Space: 1	● Student Space (25)	
B00I - R1021 - Practical Activities - 1hb - (19.63 SQM)	● Student Space (9)	
B00I - R1022 - Home Base - (53.69 SQM) - Teaching Space: 1	● Student Space (24)	
B00I - R1023 - Home Base - (54.38 SQM) - Teaching Space: 1	● Student Space (25)	
B00I - R1024 - Practical Activities - 1hb - (19.21 SQM)	● Student Space (8)	