

VENTILATION AUDIT REPORT

SCHOOL:	Shellharbour Public School (3060)
AMU REGION:	Southern NSW
STATE ELECTORATE:	Shellharbour
LOCAL GOVERNMENT AREA:	Shellharbour

3060 - Shellharbour Public School
Site Plan (10707)



1:973

Printed: 30-Mar-2021

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0004 - Withdrawal Space - 1hb - (5.93 SQM)	● Student Space (2)	
B00A - R0005 - Practical Activities - 1hb - (18.66 SQM)	● Student Space (8)	
B00A - R0006 - Home Base - (61.2 SQM) - Teaching Space: 1	● Student Space (28)	
B00A - R0007 - Practical Activities - 1hb - (18.65 SQM)	● Student Space (8)	
B00A - R0008 - Home Base - (61.2 SQM) - Teaching Space: 1	● Student Space (28)	
B00A - R0009 - Withdrawal Space - 1hb - (5.9 SQM)	● Student Space (2)	
B00A - R0012 - Movement - (31.27 SQM)	Not Applicable	Circulation or storage space.
B00A - R0016 - Withdrawal Space - 1hb - (5.9 SQM)	● Student Space (2)	
B00A - R0017 - Practical Activities - 1hb - (18.57 SQM)	● Student Space (8)	
B00A - R0018 - Home Base - (61.2 SQM) - Teaching Space: 1	● Student Space (28)	
B00A - R0019 - Practical Activities - 1hb - (18.57 SQM)	● Student Space (8)	
B00A - R0020 - Home Base - (61.2 SQM) - Teaching Space: 1	● Student Space (28)	
B00A - R0021 - Withdrawal Space - 1hb - (5.96 SQM)	● Student Space (2)	
B00A - R0023 - Movement - (30.32 SQM)	Not Applicable	Circulation or storage space.
B00A - R0025 - Movement - (5.11 SQM)	Not Applicable	Circulation or storage space.
B00B - R0011 - Raised Platform - (41.1 SQM)	Not Applicable	Circulation or storage space.
B00B - R0014 - Communal Space - (186.21 SQM)	● Student Space (86)	
B00B - R0016 - Canteen - (43.59 SQM)	Not Applicable	Circulation or storage space.
B00B - R0026 - Movement - (76.16 SQM)	Not Applicable	Circulation or storage space.
B00B - R0030 - Movement - (24.78 SQM)	Not Applicable	Circulation or storage space.
B00C - R0001 - Reading Area - (220.44 SQM)	● Student Space (102)	
B00C - R0009 - Movement - (84.74 SQM)	Not Applicable	Circulation or storage space.
B00E - R0001 - Interview - (10.85 SQM)	● Office (2)	
B00E - R0002 - Deputy Principal - (13.98 SQM)	● Office (3)	
B00E - R0003 - Entry Vestibule - (9.52 SQM)	Not Applicable	Circulation or storage space.
B00E - R0005 - Principal - (22.97 SQM)	● Office (5)	
B00E - R0007 - Staff Room Annexe - (33.18 SQM)	● Office (8)	
B00E - R0008 - Staff Room - (58.93 SQM)	● Office (14)	
B00E - R0009 - Movement - (10.07 SQM)	Not Applicable	Circulation or storage space.
B00E - R0010 - Movement - (10.19 SQM)	Not Applicable	Circulation or storage space.
B00E - R0011 - Clerical Office - (17.71 SQM)	● Office (4)	
B00E - R0013 - Movement - (5.51 SQM)	Not Applicable	Circulation or storage space.
B00E - R0014 - Sick Bay - (12.72 SQM)	● Student Space (5)	
B00E - R0021 - Movement - (5.45 SQM)	Not Applicable	Circulation or storage space.
B00E - R0023 - Home Base - (59.67 SQM) - Teaching Space: 1	● Student Space (27)	
B00E - R0026 - Movement - (7.2 SQM)	Not Applicable	Circulation or storage space.
B00E - R0028 - Home Base - (57.75 SQM) - Teaching Space: 1	● Student Space (26)	
B00E - R0031 - Special Programs Room - (48.55 SQM)	● Student Space (22)	
B00E - R0035 - Movement - (5.22 SQM)	Not Applicable	Circulation or storage space.
B00E - R0038 - Duplicating Workroom - (9.47 SQM)	● Office (2)	
B00E - R0039 - Clerical Office - (11.01 SQM)	● Office (2)	
B00E - R0040 - Deputy Principal - (14.87 SQM)	● Office (3)	
B00E - R0042 - Entry Vestibule - (11.96 SQM)	Not Applicable	Circulation or storage space.
B00E - R0043 - Movement - (12.98 SQM)	Not Applicable	Circulation or storage space.
B00F - R0001 - Home Base - (52.49 SQM) - Teaching Space: 1	● Student Space (24)	
B00F - R0003 - Home Base - (52.34 SQM) - Teaching Space: 1	● Student Space (24)	
B00F - R0004 - Seminar/Study - (15.86 SQM)	● Office (3)	
B00F - R0007 - Home Base - (53.66 SQM) - Teaching Space: 1	● Student Space (24)	
B00F - R0008 - Home Base - (53.73 SQM) - Teaching Space: 1	● Student Space (24)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00F - R0013 - Withdrawal Space - 1hb - (22.14 SQM)	● Student Space (10)	
B00F - R0014 - Home Base - (72.94 SQM) - Teaching Space: 1	● Student Space (33)	
B00F - R0015 - Movement - (84.31 SQM)	Not Applicable	Circulation or storage space.
B00G - R0003 - Home Base - (56.97 SQM) - Teaching Space: 1	● Student Space (26)	
B00G - R0004 - Home Base - (85.57 SQM) - Teaching Space: 1	● Student Space (39)	
B00G - R0008 - Movement - (39.36 SQM)	Not Applicable	Circulation or storage space.
B00H - R0004 - Practical Activities - (19.11 SQM)	● Student Space (8)	
B00H - R0005 - Practical Activities - (20.55 SQM)	● Student Space (9)	
B00H - R0006 - Home Base - (58.49 SQM) - Teaching Space: 1	● Student Space (27)	
B00H - R0008 - Withdrawal Space - 1hb - (8.77 SQM)	● Student Space (4)	
B00H - R0009 - Practical Activities - (19.11 SQM)	● Student Space (8)	
B00H - R0011 - Home Base - (61.03 SQM) - Teaching Space: 1	● Student Space (28)	
B00H - R0012 - Withdrawal Space - 2hb - (11.75 SQM)	● Student Space (5)	
B00H - R0013 - Home Base - (61.03 SQM) - Teaching Space: 1	● Student Space (28)	
B00I - R0001 - Practical Activities - (19.96 SQM)	● Student Space (9)	
B00I - R0003 - Home Base - (60.93 SQM) - Teaching Space: 1	● Student Space (28)	
B00I - R0004 - Withdrawal Space - 1hb - (11.73 SQM)	● Student Space (5)	
B00I - R0005 - Home Base - (60.93 SQM) - Teaching Space: 1	● Student Space (28)	
B00I - R0007 - Practical Activities - (19.69 SQM)	● Student Space (9)	
B00I - R0008 - Practical Activities - (20.76 SQM)	● Student Space (9)	
B00I - R0009 - Withdrawal Space - 1hb - (8.75 SQM)	● Student Space (4)	
B00I - R0011 - Home Base - (58.28 SQM) - Teaching Space: 1	● Student Space (27)	