

VENTILATION AUDIT REPORT

SCHOOL:	Sherwood Ridge Public School (4640)
AMU REGION:	Western Sydney
STATE ELECTORATE:	Castle Hill
LOCAL GOVERNMENT AREA:	The Hills

4640 - Sherwood Ridge Public School
Site Plan (13594)




















1:1,058

Printed: 24-Apr-2021

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0002 - Entry Vestibule - (16.6 SQM)	Not Applicable	Circulation or storage space.
B00A - R0003 - Movement - (8.08 SQM)	Not Applicable	Circulation or storage space.
B00A - R0004 - Clerical Office/Workroom - (57.7 SQM)	Office (14)	
B00A - R0005 - Interview - (17.01 SQM)	Office (4)	
B00A - R0007 - Deputy Principal - (12.53 SQM)	Office (3)	
B00A - R0008 - Deputy Principal - (12.62 SQM)	Office (3)	
B00A - R0009 - Staff Kitchen - (6.91 SQM)	Office (1)	
B00A - R0010 - Staff Room - (51.61 SQM)	Office (12)	
B00A - R0011 - Staff Room Annexe - (25.82 SQM)	Office (6)	
B00A - R0012 - Movement - (42.44 SQM)	Not Applicable	Circulation or storage space.
B00A - R0018 - Principal - (17.36 SQM)	Office (4)	
B00A - R0020 - Sick Bay - (9.06 SQM)	Student Space (4)	
B00A - R0021 - Interview - (13.26 SQM)	Office (3)	
B00B - R0003 - Raised Platform - (54.4 SQM)	Not Applicable	Circulation or storage space.
B00B - R0004 - Movement - (27.52 SQM)	Not Applicable	Circulation or storage space.
B00B - R0013 - Canteen - (44.22 SQM)	Not Applicable	Circulation or storage space.
B00B - R0015 - Communal Space - (198.92 SQM)	Student Space (92)	
B00B - R0022 - Movement - (8.5 SQM)	Not Applicable	Circulation or storage space.
B00C - R0002 - Practical Activities - 1hb - (19.25 SQM)	Student Space (8)	
B00C - R0004 - Home Base - (61.07 SQM) - Teaching Space: 1	Student Space (28)	
B00C - R0005 - Withdrawal Space - 2hb - (11.56 SQM)	Student Space (5)	
B00C - R0006 - Home Base - (60.42 SQM) - Teaching Space: 1	Student Space (28)	
B00C - R0007 - Practical Activities - 1hb - (19.02 SQM)	Student Space (8)	
B00C - R0010 - Practical Activities - 1hb - (19.27 SQM)	Student Space (8)	
B00C - R0012 - Home Base - (60.82 SQM) - Teaching Space: 1	Student Space (28)	
B00C - R0013 - Withdrawal Space - 2hb - (11.59 SQM)	Student Space (5)	
B00C - R0014 - Home Base - (60.79 SQM) - Teaching Space: 1	Student Space (28)	
B00C - R0016 - Practical Activities - 1hb - (19.27 SQM)	Student Space (8)	
B00D - R0004 - Special Programs Room - (31.8 SQM)	Student Space (14)	
B00D - R0010 - Reading Area - (229.35 SQM)	Student Space (106)	
B00D - R0011 - Special Programs Room - (15.75 SQM)	Student Space (7)	
B00D - R0012 - Special Programs Room - (15.72 SQM)	Student Space (7)	
B00E - R0005 - Practical Activities - 1hb - (19.25 SQM)	Student Space (8)	
B00E - R0007 - Home Base - (60.67 SQM) - Teaching Space: 1	Student Space (28)	
B00E - R0008 - Withdrawal Space - 2hb - (11.75 SQM)	Student Space (5)	
B00E - R0009 - Home Base - (60.57 SQM) - Teaching Space: 1	Student Space (28)	
B00E - R0011 - Practical Activities - 1hb - (18.88 SQM)	Student Space (8)	
B00E - R0013 - Practical Activities - 1hb - (18.88 SQM)	Student Space (8)	
B00E - R0015 - Home Base - (60.81 SQM) - Teaching Space: 1	Student Space (28)	
B00E - R0016 - Withdrawal Space - 2hb - (11.78 SQM)	Student Space (5)	
B00E - R0017 - Home Base - (60.61 SQM) - Teaching Space: 1	Student Space (28)	
B00E - R0019 - Practical Activities - 1hb - (19.2 SQM)	Student Space (8)	
B00F - R0005 - Practical Activities - 1hb - (19.16 SQM)	Student Space (8)	
B00F - R0007 - Home Base - (60.44 SQM) - Teaching Space: 1	Student Space (28)	
B00F - R0008 - Withdrawal Space - 2hb - (11.79 SQM)	Student Space (5)	
B00F - R0009 - Home Base - (60.43 SQM) - Teaching Space: 1	Student Space (28)	
B00F - R0011 - Practical Activities - 1hb - (19.07 SQM)	Student Space (8)	
B00F - R0015 - Home Base - (60.71 SQM) - Teaching Space: 1	Student Space (28)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00F - R0017 - Practical Activities - 1hb - (19.32 SQM)	 Student Space (8)	
B00F - R0018 - Withdrawal Space - 2hb - (11.78 SQM)	 Student Space (5)	
B00F - R0019 - Home Base - (60.46 SQM) - Teaching Space: 1	 Student Space (28)	
B00F - R0021 - Practical Activities - 1hb - (19.18 SQM)	 Student Space (8)	
B00G - R0002 - Practical Activities - 1hb - (19.13 SQM)	 Student Space (8)	
B00G - R0004 - Home Base - (60.62 SQM) - Teaching Space: 1	 Student Space (28)	
B00G - R0005 - Withdrawal Space - 2hb - (11.84 SQM)	 Student Space (5)	
B00G - R0006 - Home Base - (60.59 SQM) - Teaching Space: 1	 Student Space (28)	
B00G - R0008 - Practical Activities - 1hb - (18.68 SQM)	 Student Space (8)	
B00G - R0010 - Practical Activities - 1hb - (18.91 SQM)	 Student Space (8)	
B00G - R0012 - Home Base - (60.58 SQM) - Teaching Space: 1	 Student Space (28)	
B00G - R0013 - Withdrawal Space - 2hb - (11.78 SQM)	 Student Space (5)	
B00G - R0014 - Home Base - (60.57 SQM) - Teaching Space: 1	 Student Space (28)	
B00G - R0016 - Practical Activities - 1hb - (19.07 SQM)	 Student Space (8)	
B00G - R0018 - Practical Activities - 1hb - (18.77 SQM)	 Student Space (8)	
B00G - R0020 - Home Base - (60.68 SQM) - Teaching Space: 1	 Student Space (28)	
B00G - R0021 - Withdrawal Space - 2hb - (11.75 SQM)	 Student Space (5)	
B00G - R0022 - Home Base - (60.54 SQM) - Teaching Space: 1	 Student Space (28)	
B00G - R0024 - Practical Activities - 1hb - (19.16 SQM)	 Student Space (8)	
B00H - R0002 - Practical Activities - 1hb - (19.4 SQM)	 Student Space (9)	
B00H - R0004 - Home Base - (59.23 SQM) - Teaching Space: 1	 Student Space (27)	
B00H - R0005 - Withdrawal Space - 2hb - (11.36 SQM)	 Student Space (5)	
B00H - R0006 - Home Base - (59.22 SQM) - Teaching Space: 1	 Student Space (27)	
B00H - R0008 - Practical Activities - 1hb - (19.42 SQM)	 Student Space (9)	