

VENTILATION AUDIT REPORT

SCHOOL:	Shoalhaven High School (8561)
AMU REGION:	Southern NSW
STATE ELECTORATE:	South Coast
LOCAL GOVERNMENT AREA:	Shoalhaven

8561 - Shoalhaven High School
Site Plan (10687)



1:2,006

Printed: 05-Jun-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - General Learning Space - (45.94 SQM) - Teaching Space: 1	● Student Space (21)	
B00A - R0002 - General Learning Space - (47.96 SQM) - Teaching Space: 1	● Student Space (22)	
B00A - R0003 - Movement - (134.15 SQM)	Not Applicable	Circulation or storage space.
B00A - R0007 - Staff Study - (15.26 SQM)	● Office (3)	
B00A - R0008 - General Learning Space - (45.8 SQM) - Teaching Space: 1	● Student Space (21)	
B00A - R0009 - General Learning Space - (46.01 SQM) - Teaching Space: 1	● Student Space (21)	
B00A - R0010 - General Learning Space - (46.07 SQM) - Teaching Space: 1	● Student Space (21)	
B00A - R0011 - General Learning Space - (45.87 SQM) - Teaching Space: 1	● Student Space (21)	
B00A - R0016 - Ancillary Staff - (20.59 SQM)	● Office (5)	
B00A - R0018 - Deputy Principal Office - (16.41 SQM)	● Office (4)	
B00A - R0019 - Clinic - Girls - (14.21 SQM)	● Office (3)	
B00A - R0021 - Clinic - Boys - (14.87 SQM)	● Office (3)	
B00A - R0025 - Interview/Office - Type 1 - (12.18 SQM)	● Office (3)	
B00A - R0026 - Leading Teacher - (12.18 SQM)	● Office (3)	
B00A - R0027 - Principal Office - (24.07 SQM)	● Office (6)	
B00A - R0028 - Administration - Clerical - (50.32 SQM)	● Office (12)	
B00A - R0029 - Duplicating Workroom - (27.61 SQM)	● Office (6)	
B00A - R0032 - Movement - (66.97 SQM)	Not Applicable	Circulation or storage space.
B00A - R0035 - Laboratory L.S. - (79.2 SQM) - Teaching Space: 1	● Student Space (36)	
B00A - R0039 - Laboratory L.S. - (79.02 SQM) - Teaching Space: 1	● Student Space (36)	
B00A - R0041 - Preparation - (48.74 SQM)	Not Applicable	Circulation or storage space.
B00A - R0044 - Laboratory L.S. - (79.03 SQM) - Teaching Space: 1	● Student Space (36)	
B00A - R0045 - Growing/Breeding - (25.96 SQM)	Not Applicable	Circulation or storage space.
B00A - R0046 - Staff Study - (38.23 SQM)	● Office (9)	
B00A - R0047 - Teachers Aides - (15.31 SQM)	● Office (3)	
B00A - R0048 - Movement - (100.9 SQM)	Not Applicable	Circulation or storage space.
B00A - R1001 - General Learning Space - (46.16 SQM) - Teaching Space: 1	● Student Space (21)	
B00A - R1002 - General Learning Space - (47.89 SQM) - Teaching Space: 1	● Student Space (22)	
B00A - R1004 - Staff Study - (40.59 SQM)	● Office (10)	
B00A - R1007 - Laboratory L.S. - (79.02 SQM) - Teaching Space: 1	● Student Space (36)	
B00A - R1008 - Laboratory L.S. - (78.93 SQM) - Teaching Space: 1	● Student Space (36)	
B00A - R1010 - Preparation - (48.71 SQM)	Not Applicable	Circulation or storage space.
B00A - R1013 - Laboratory L.S. - (79.03 SQM) - Teaching Space: 1	● Student Space (36)	
B00A - R1016 - Commonroom - (106.71 SQM)	● Office (26)	
B00A - R1017 - Interview/Office - Type 1 - (13.13 SQM)	● Office (3)	
B00A - R1018 - General Learning Space - (45.88 SQM) - Teaching Space: 1	● Student Space (21)	
B00A - R1019 - General Learning Space - (45.81 SQM) - Teaching Space: 1	● Student Space (21)	
B00A - R1020 - General Learning Space - (46.08 SQM) - Teaching Space: 1	● Student Space (21)	
B00A - R1021 - General Learning Space - (45.8 SQM) - Teaching Space: 1	● Student Space (21)	
B00A - R1022 - Movement - (269.99 SQM)	Not Applicable	Circulation or storage space.
B00B - R0001 - Art Learning Space - (59.16 SQM) - Teaching Space: 1	● Student Space (27)	
B00B - R0002 - Art Entry/Display - (123.85 SQM)	Not Applicable	Circulation or storage space.
B00B - R0003 - Staff Study - (23.64 SQM)	● Office (5)	
B00B - R0008 - Art Learning Space - (58.92 SQM) - Teaching Space: 1	● Student Space (27)	
B00B - R0009 - Workshop - (58.85 SQM)	● Student Space (27)	
B00B - R0010 - Art Learning Space - (58.86 SQM) - Teaching Space: 1	● Student Space (27)	
B00B - R0011 - Art Learning Space - (58.61 SQM) - Teaching Space: 1	● Student Space (27)	
B00B - R0014 - Darkroom Space - (14.19 SQM)	● Office (3)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00B - R0015 - Staff Study - (29.16 SQM)	Office (7)	
B00B - R0017 - Movement - (59.24 SQM)	Not Applicable	Circulation or storage space.
B00B - R0018 - Darkroom Space - (9.72 SQM)	Office (2)	
B00B - R0020 - Wood Technology Bay - (89.67 SQM)	Not Applicable	Circulation or storage space.
B00B - R0022 - Wood Technology Bay - (30.45 SQM)	Not Applicable	Circulation or storage space.
B00B - R0024 - Materials Technology L.S. - (87.29 SQM) - Teaching Space: 1	Student Space (40)	
B00B - R0026 - Materials Technology L.S. - (89.71 SQM) - Teaching Space: 1	Student Space (41)	
B00B - R0027 - Metal Technology Bay - (31.14 SQM)	Not Applicable	Circulation or storage space.
B00B - R0028 - Materials Technology L.S. - (89.71 SQM) - Teaching Space: 1	Student Space (41)	
B00B - R0029 - Welding Area - (11.08 SQM)	Not Applicable	Circulation or storage space.
B00B - R0030 - Workshop Area - (64.01 SQM)	Student Space (29)	
B00B - R1001 - Design L.S. - (58.81 SQM) - Teaching Space: 1	Student Space (27)	
B00B - R1002 - Design L.S. - (63.33 SQM) - Teaching Space: 1	Student Space (29)	
B00B - R1003 - Seminar/Technology Space - (25.42 SQM)	Office (6)	
B00B - R1007 - Movement - (8.26 SQM)	Not Applicable	Circulation or storage space.
B00C - R0006 - Staff Study - (26.88 SQM)	Office (6)	
B00C - R0007 - Special Learning Space - (46.14 SQM) - Teaching Space: 1	Student Space (21)	
B00C - R0008 - General Learning Space - (45.95 SQM) - Teaching Space: 1	Student Space (21)	
B00C - R0009 - Study Space - (40.56 SQM)	Not Applicable	Circulation or storage space.
B00C - R0010 - General Learning Space - (45.94 SQM) - Teaching Space: 1	Student Space (21)	
B00C - R0011 - General Learning Space - (45.94 SQM) - Teaching Space: 1	Student Space (21)	
B00C - R0012 - Study Space - (40.86 SQM)	Not Applicable	Circulation or storage space.
B00C - R0013 - General Learning Space - (46.14 SQM) - Teaching Space: 1	Student Space (21)	
B00C - R0014 - General Learning Space - (46 SQM) - Teaching Space: 1	Student Space (21)	
B00C - R0020 - Interview/Office - Type 1 - (12.14 SQM)	Office (3)	
B00C - R0021 - Staff Study - (41.56 SQM)	Office (10)	
B00C - R0022 - General Learning Space - (45.81 SQM) - Teaching Space: 1	Student Space (21)	
B00C - R0023 - General Learning Space - (45.94 SQM) - Teaching Space: 1	Student Space (21)	
B00C - R0025 - Main Area - (239.51 SQM)	Not Applicable	Circulation or storage space.
B00C - R0028 - Audio Visual Workroom - (42.19 SQM)	Student Space (19)	
B00C - R0029 - Main Area - (191.72 SQM)	Not Applicable	Circulation or storage space.
B00C - R0030 - Seminar - (10.68 SQM)	Office (2)	
B00C - R0031 - Seminar - (11.01 SQM)	Office (2)	
B00C - R0032 - Seminar - (13.08 SQM)	Office (3)	
B00C - R0033 - Interview/Office - Type 1 - (9.07 SQM)	Office (2)	
B00C - R0040 - Movement - (327.74 SQM)	Not Applicable	Circulation or storage space.
B00C - R1001 - Computer Learning Space - (44.8 SQM) - Teaching Space: 1	Student Space (20)	
B00C - R1006 - Study Space - (26.66 SQM)	Not Applicable	Circulation or storage space.
B00C - R1007 - Staff Study - (46.09 SQM)	Office (11)	
B00C - R1008 - General Learning Space - (45.81 SQM) - Teaching Space: 1	Student Space (21)	
B00C - R1009 - Study Space - (40.99 SQM)	Not Applicable	Circulation or storage space.
B00C - R1010 - General Learning Space - (45.95 SQM) - Teaching Space: 1	Student Space (21)	
B00C - R1011 - General Learning Space - (45.94 SQM) - Teaching Space: 1	Student Space (21)	
B00C - R1012 - Study Space - (41.14 SQM)	Not Applicable	Circulation or storage space.
B00C - R1013 - General Learning Space - (45.94 SQM) - Teaching Space: 1	Student Space (21)	
B00C - R1014 - Computer Learning Space - (45.81 SQM) - Teaching Space: 1	Student Space (21)	
B00C - R1020 - Interview/Office - Type 1 - (12.14 SQM)	Office (3)	
B00C - R1021 - Staff Study - (41.51 SQM)	Office (10)	
B00C - R1022 - General Learning Space - (45.95 SQM) - Teaching Space: 1	Student Space (21)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00C - R1023 - Study Space - (79.61 SQM)	Not Applicable	Circulation or storage space.
B00C - R1024 - Study Space - (26.42 SQM)	Not Applicable	Circulation or storage space.
B00C - R1025 - General Learning Space - (46.01 SQM) - Teaching Space: 1	● Student Space (21)	
B00C - R1026 - Movement - (281.98 SQM)	Not Applicable	Circulation or storage space.
B00D - R0001 - Food Technology L.S. - (103.14 SQM) - Teaching Space: 1	● Student Space (47)	
B00D - R0002 - Staff Study - (29.85 SQM)	● Office (7)	
B00D - R0006 - Design L.S. - (68.36 SQM) - Teaching Space: 1	● Student Space (31)	
B00D - R0007 - Design L.S. - (68.27 SQM) - Teaching Space: 1	● Student Space (31)	
B00D - R0013 - Food Technology L.S. - (102.24 SQM) - Teaching Space: 1	● Student Space (47)	
B00D - R0016 - Preparation - Materials - (25.03 SQM)	Not Applicable	Circulation or storage space.
B00D - R0018 - Movement - (95.93 SQM)	Not Applicable	Circulation or storage space.
B00E - R0004 - Movement - (14.86 SQM)	Not Applicable	Circulation or storage space.
B00E - R0005 - Stage - (90.43 SQM)	Not Applicable	Circulation or storage space.
B00E - R0006 - Movement - (11.38 SQM)	Not Applicable	Circulation or storage space.
B00E - R0007 - Multi-Purpose Space - (462.72 SQM)	● Student Space (214)	
B00E - R0008 - Movement - (55.99 SQM)	Not Applicable	Circulation or storage space.
B00E - R0013 - General Assistants - (12.18 SQM)	● Office (3)	
B00E - R0014 - Staff Study - (25.6 SQM)	● Office (6)	
B00E - R1001 - Music Learning Space - (77.67 SQM) - Teaching Space: 1	● Student Space (36)	
B00E - R1002 - Practice/Seminar - (30.18 SQM)	Not Applicable	Circulation or storage space.
B00E - R1004 - Practice/Seminar - (25.75 SQM)	Not Applicable	Circulation or storage space.
B00E - R1005 - Music Learning Space - (61.09 SQM) - Teaching Space: 1	● Student Space (28)	
B00E - R1006 - Staff Study - (18.79 SQM)	● Office (4)	
B00E - R1007 - Movement - (38.97 SQM)	Not Applicable	Circulation or storage space.
B00F - R0001 - Student Canteen - (58.34 SQM)	Not Applicable	Circulation or storage space.
B00F - R1001 - Movement - (76.94 SQM)	Not Applicable	Circulation or storage space.
B00G - R0003 - Performance Workspace - (82.94 SQM) - Teaching Space: 1	● Student Space (38)	
B00I - R0003 - Performance Workspace - (66.43 SQM) - Teaching Space: 1	● Student Space (30)	
B00I - R0004 - Movement - (7.88 SQM)	Not Applicable	Circulation or storage space.
B00M - R0003 - Staff Study - (9.57 SQM)	● Office (2)	
B00N - R0002 - Gymnasium - (84.23 SQM)	● Student Space (39)	
B00N - R0003 - Gymnasium - (130.93 SQM)	● Student Space (60)	
B00P - R0001 - General Learning Space - Type 11 - (39.48 SQM) - Teaching Space: 1	● Student Space (18)	
B00Q - R0001 - General Assistants - (49.19 SQM)	● Office (12)	
B00R - R0001 - Public Entry - (21.57 SQM)	Not Applicable	Circulation or storage space.
B00R - R0002 - Administration - Clerical - (69.06 SQM)	● Office (17)	
B00R - R0003 - Interview/Office - Type 1 - (15.39 SQM)	● Office (3)	
B00R - R0004 - Principal Office - (20.69 SQM)	● Office (5)	
B00R - R0005 - Interview/Office - Type 1 - (13.25 SQM)	● Office (3)	
B00R - R0007 - Staff Kitchen - (10.66 SQM)	● Office (2)	
B00R - R0008 - Movement - (5.04 SQM)	Not Applicable	Circulation or storage space.
B00R - R0015 - Movement - (11.85 SQM)	Not Applicable	Circulation or storage space.
B00R - R0018 - Staff Kitchen - (7.45 SQM)	● Office (1)	
B00R - R0019 - Movement - (5.62 SQM)	Not Applicable	Circulation or storage space.
NS 210 13423 - NS 210 13423 - Home Science/Preparation Area/Laundry - (95 SQM)	● Office (23)	
OS 621 14393 - OS 621 14393 - Learning Unit Single - PWD - (95 SQM)	● Student Space (44)	