


# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Shortland Public School (3065)</b>
<b>AMU REGION:</b>	<b>Hunter/Central Coast</b>
<b>STATE ELECTORATE:</b>	<b>Wallsend</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Newcastle</b>

3065 - Shortland Public School  
Site Plan (10791)



1:1,132

Printed: 21-Mar-2020

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Staff Room - (29.3 SQM)	Office (7)	
B00A - R0004 - Duplicating Workroom - (12.4 SQM)	Office (3)	
B00A - R0007 - Sick Bay - (9.95 SQM)	Student Space (4)	
B00A - R0008 - Movement - (33.81 SQM)	Not Applicable	Circulation or storage space.
B00A - R0009 - Entry Vestibule - (7.73 SQM)	Not Applicable	Circulation or storage space.
B00A - R0011 - Clerical Office - (13.56 SQM)	Office (3)	
B00A - R0012 - Principal - (16.86 SQM)	Office (4)	
B00A - R0015 - Staff Room Annexe - (14.35 SQM)	Office (3)	
B00A - R0016 - Staff Room Annexe - (16.57 SQM)	Office (4)	
B00A - R0017 - Movement - (186.97 SQM)	Not Applicable	Circulation or storage space.
B00A - R0021 - Canteen - (21.6 SQM)	Not Applicable	Circulation or storage space.
B00A - R0026 - Movement - (113.14 SQM)	Not Applicable	Circulation or storage space.
B00A - R0030 - Home Base - (49.74 SQM) - Teaching Space: 1	Student Space (23)	
B00A - R0031 - Practical Activities - 1hb - (20.15 SQM)	Student Space (9)	
B00A - R0032 - Practical Activities - 1hb - (22.18 SQM)	Student Space (10)	
B00A - R0033 - Home Base - (49.4 SQM) - Teaching Space: 1	Student Space (22)	
B00A - R1001 - Home Base - (50.48 SQM) - Teaching Space: 1	Student Space (23)	
B00A - R1002 - Practical Activities - 1hb - (19.96 SQM)	Student Space (9)	
B00A - R1003 - Movement - (168.87 SQM)	Not Applicable	Circulation or storage space.
B00A - R1004 - Practical Activities - 1hb - (20.48 SQM)	Student Space (9)	
B00A - R1005 - Home Base - (49.66 SQM) - Teaching Space: 1	Student Space (23)	
B00A - R1006 - Home Base - (49.58 SQM) - Teaching Space: 1	Student Space (23)	
B00A - R1007 - Practical Activities - 1hb - (20.48 SQM)	Student Space (9)	
B00A - R1015 - Home Base - (49.8 SQM) - Teaching Space: 1	Student Space (23)	
B00A - R1016 - Practical Activities - 1hb - (20.58 SQM)	Student Space (9)	
B00A - R1017 - Practical Activities - 1hb - (20.87 SQM)	Student Space (9)	
B00A - R1018 - Home Base - (49.66 SQM) - Teaching Space: 1	Student Space (23)	
B00A - R1021 - Home Base - (49.58 SQM) - Teaching Space: 1	Student Space (23)	
B00A - R1022 - Practical Activities - 1hb - (21.83 SQM)	Student Space (10)	
B00A - R1023 - Practical Activities - 1hb - (20.15 SQM)	Student Space (9)	
B00A - R1024 - Home Base - (50.45 SQM) - Teaching Space: 1	Student Space (23)	
B00A - R1029 - Special Programs Room - (56.17 SQM)	Student Space (26)	
B00A - R1031 - Home Base/Practical Activities - (80.06 SQM) - Teaching Space: 1	Student Space (37)	
B00B - R0004 - Home Base - (53.7 SQM) - Teaching Space: 1	Student Space (24)	
B00B - R0005 - Home Base - (53.77 SQM) - Teaching Space: 1	Student Space (24)	
B00B - R0007 - Movement - (39.43 SQM)	Not Applicable	Circulation or storage space.
B00B - R0008 - Practical Activities - (11.11 SQM)	Student Space (5)	
B00C - R0017 - Home Base - (53.49 SQM) - Teaching Space: 1	Student Space (24)	
B00C - R0019 - Home Base - (53.42 SQM) - Teaching Space: 1	Student Space (24)	
B00C - R0025 - Movement - (29.05 SQM)	Not Applicable	Circulation or storage space.
B00C - R0031 - Movement - (65.91 SQM)	Not Applicable	Circulation or storage space.
B00C - R0033 - Practical Activities - (69.33 SQM)	Student Space (32)	
B00C - R0035 - Movement - (9.96 SQM)	Not Applicable	Circulation or storage space.
B00C - R0038 - Movement - (14.92 SQM)	Not Applicable	Circulation or storage space.
B00C - R0039 - Practical Activities - (51.87 SQM)	Student Space (24)	
B00D - R0002 - Movement - (9.83 SQM)	Not Applicable	Circulation or storage space.
B00D - R0003 - Home Base - (57.62 SQM) - Teaching Space: 1	Student Space (26)	
B00E - R0005 - Movement - (26.44 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00I - R0001 - Communal Space - (342.33 SQM)	 Student Space (158)	
B00I - R0002 - Raised Platform - (24.2 SQM)	Not Applicable	Circulation or storage space.
B00J - R0006 - Reading Area - (166.95 SQM)	 Student Space (77)	