

VENTILATION AUDIT REPORT

SCHOOL:	Singleton High School (8202)
AMU REGION:	Hunter/Central Coast
STATE ELECTORATE:	Upper Hunter
LOCAL GOVERNMENT AREA:	Singleton



8202 - Singleton High School
Site Plan (11303)



1:1,788

Printed: 30-Mar-2021

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0005 - Laboratory L.S. - (93.45 SQM) - Teaching Space: 1	● Student Space (43)	
B00A - R0006 - Preparation - (11.23 SQM)	Not Applicable	Circulation or storage space.
B00A - R0007 - Preparation - (33.3 SQM)	Not Applicable	Circulation or storage space.
B00A - R0008 - Laboratory L.S. - (91.84 SQM) - Teaching Space: 1	● Student Space (42)	
B00A - R0009 - Interview/Office - Type 1 - (14.51 SQM)	○ Office (3)	
B00A - R1002 - Staff Study - (22.9 SQM)	○ Office (5)	
B00A - R1003 - Staff Study - (52.6 SQM)	○ Office (13)	
B00A - R1006 - General Learning Space - (51.95 SQM) - Teaching Space: 1	● Student Space (24)	
B00A - R1007 - Staff Study - (22.45 SQM)	○ Office (5)	
B00A - R1010 - Movement - (129.43 SQM)	Not Applicable	Circulation or storage space.
B00A - R1013 - Performance Workshop - (97.41 SQM)	● Student Space (45)	
B00A - R2001 - Staff Study - (23.08 SQM)	○ Office (5)	
B00A - R2002 - General Learning Space - (55.24 SQM) - Teaching Space: 1	● Student Space (25)	
B00A - R2003 - General Learning Space - (55.17 SQM) - Teaching Space: 1	● Student Space (25)	
B00A - R2004 - General Learning Space - (52.31 SQM) - Teaching Space: 1	● Student Space (24)	
B00A - R2005 - General Learning Space - (52.53 SQM) - Teaching Space: 1	● Student Space (24)	
B00A - R2007 - Movement - (126.35 SQM)	Not Applicable	Circulation or storage space.
B00B - R0001 - General Learning Space - (68.21 SQM) - Teaching Space: 1	● Student Space (31)	
B00B - R0003 - Staff Study - (20.07 SQM)	○ Office (5)	
B00B - R0004 - General Learning Space - (52.38 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R0007 - General Learning Space - (56.35 SQM) - Teaching Space: 1	● Student Space (26)	
B00B - R1001 - Music Learning Space - (75.98 SQM) - Teaching Space: 1	● Student Space (35)	
B00B - R1003 - Movement - (11.74 SQM)	Not Applicable	Circulation or storage space.
B00B - R1005 - Staff Study - (29.93 SQM)	○ Office (7)	
B00B - R1006 - Practice/Seminar - (29.96 SQM)	Not Applicable	Circulation or storage space.
B00B - R1007 - Music Learning Space - (76.05 SQM) - Teaching Space: 1	● Student Space (35)	
B00B - R1009 - Movement - (48.14 SQM)	Not Applicable	Circulation or storage space.
B00C - R0007 - Interview/Office - Type 1 - (17.05 SQM)	○ Office (4)	
B00C - R0010 - Interview/Office - Type 1 - (13.25 SQM)	○ Office (3)	
B00C - R0011 - Public Entry - (13.29 SQM)	Not Applicable	Circulation or storage space.
B00C - R0012 - Movement - (13.83 SQM)	Not Applicable	Circulation or storage space.
B00C - R0022 - Movement - (8.61 SQM)	Not Applicable	Circulation or storage space.
B00C - R0033 - Movement - (16.43 SQM)	Not Applicable	Circulation or storage space.
B00C - R0036 - Movement - (6.52 SQM)	Not Applicable	Circulation or storage space.
B00C - R0037 - Movement - (22.16 SQM)	Not Applicable	Circulation or storage space.
B00C - R0039 - Deputy Principal Office - (18.79 SQM)	○ Office (4)	
B00C - R0040 - Deputy Principal Office - (25.27 SQM)	○ Office (6)	
B00C - R0041 - Movement - (8.06 SQM)	Not Applicable	Circulation or storage space.
B00C - R0043 - Movement - (12.01 SQM)	Not Applicable	Circulation or storage space.
B00C - R0045 - Principal Office - (25.8 SQM)	○ Office (6)	
B00C - R0046 - Interview/Office - Type 1 - (12.64 SQM)	○ Office (3)	
B00C - R0047 - Movement - (39.92 SQM)	Not Applicable	Circulation or storage space.
B00C - R0048 - Administration - Clerical - (89.86 SQM)	○ Office (22)	
B00C - R0049 - Staff Kitchen - (5.96 SQM)	○ Office (1)	
B00C - R0050 - Pupil Entry - (17.37 SQM)	Not Applicable	Circulation or storage space.
B00C - R0051 - Clinic - Boys - (10.75 SQM)	○ Office (2)	
B00C - R0052 - Movement - (10.64 SQM)	Not Applicable	Circulation or storage space.
B00C - R0053 - Clinic - Girls - (16.56 SQM)	○ Office (4)	
B00C - R0056 - Duplicating Workroom - (27.23 SQM)	○ Office (6)	
B00C - R0057 - Movement - (28.08 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00C - R1001 - General Learning Space - (48.39 SQM) - Teaching Space: 1	● Student Space (22)	
B00C - R1002 - Staff Study - (34.15 SQM)	○ Office (8)	
B00C - R1003 - Interview/Office - Type 1 - (5.93 SQM)	○ Office (1)	
B00C - R1004 - General Learning Space - (54.97 SQM) - Teaching Space: 1	● Student Space (25)	
B00C - R1005 - General Learning Space - (63.08 SQM) - Teaching Space: 1	● Student Space (29)	
B00C - R1006 - Movement - (7.21 SQM)	Not Applicable	Circulation or storage space.
B00C - R1010 - General Learning Space - (55.26 SQM) - Teaching Space: 1	● Student Space (25)	
B00C - R1011 - General Learning Space - (55.09 SQM) - Teaching Space: 1	● Student Space (25)	
B00C - R1012 - Movement - (12.44 SQM)	Not Applicable	Circulation or storage space.
B00C - R1013 - Interview/Office - Type 1 - (12.36 SQM)	○ Office (3)	
B00C - R1014 - General Learning Space - (55.86 SQM) - Teaching Space: 1	● Student Space (25)	
B00C - R1015 - Movement - (131.51 SQM)	Not Applicable	Circulation or storage space.
B00C - R1018 - Movement - (15.9 SQM)	Not Applicable	Circulation or storage space.
B00C - R1021 - Movement - (6.8 SQM)	Not Applicable	Circulation or storage space.
B00D - R0003 - Interview/Office - Type 1 - (16.16 SQM)	○ Office (4)	
B00D - R0004 - General Learning Space - (49.46 SQM) - Teaching Space: 1	● Student Space (22)	
B00D - R0005 - General Learning Space - (56.15 SQM) - Teaching Space: 1	● Student Space (26)	
B00D - R0006 - General Learning Space - (60.52 SQM) - Teaching Space: 1	● Student Space (28)	
B00D - R0007 - Movement - (21.93 SQM)	Not Applicable	Circulation or storage space.
B00D - R0008 - Movement - (74 SQM)	Not Applicable	Circulation or storage space.
B00D - R1002 - Staff Study - (56.74 SQM)	○ Office (14)	
B00D - R1003 - General Learning Space - (56.45 SQM) - Teaching Space: 1	● Student Space (26)	
B00D - R1004 - General Learning Space - (57.27 SQM) - Teaching Space: 1	● Student Space (26)	
B00D - R1005 - Movement - (10.23 SQM)	Not Applicable	Circulation or storage space.
B00D - R1006 - Movement - (75.77 SQM)	Not Applicable	Circulation or storage space.
B00E - R0001 - Staff Study - (23.78 SQM)	○ Office (5)	
B00E - R0002 - General Learning Space - (64.88 SQM) - Teaching Space: 1	● Student Space (30)	
B00E - R0003 - Art Learning Space - (69.6 SQM) - Teaching Space: 1	● Student Space (32)	
B00E - R1001 - General Learning Space - (53.04 SQM) - Teaching Space: 1	● Student Space (24)	
B00E - R1002 - General Learning Space - (52.46 SQM) - Teaching Space: 1	● Student Space (24)	
B00E - R1003 - General Learning Space - (52.46 SQM) - Teaching Space: 1	● Student Space (24)	
B00E - R1004 - Movement - (68.7 SQM)	Not Applicable	Circulation or storage space.
B00F - R0004 - Staff Kitchen - (7.95 SQM)	○ Office (1)	
B00F - R0005 - Commonroom - (104.56 SQM)	○ Office (26)	
B00G - R0002 - Art Learning Space - (69.81 SQM) - Teaching Space: 1	● Student Space (32)	
B00G - R0007 - Art Learning Space - (68.91 SQM) - Teaching Space: 1	● Student Space (31)	
B00H - R0004 - Art Learning Space - (46.69 SQM) - Teaching Space: 1	● Student Space (21)	
B00H - R0006 - Staff Study - (24.46 SQM)	○ Office (6)	
B00H - R0007 - Darkroom Space - (28.64 SQM)	○ Office (7)	
B00H - R0010 - Darkroom Space - (7.87 SQM)	○ Office (1)	
B00H - R0013 - Movement - (6.74 SQM)	Not Applicable	Circulation or storage space.
B00H - R0014 - General Assistants - (44.31 SQM)	○ Office (11)	
B00J - M0003 - Movement - (152.7 SQM)	Not Applicable	Circulation or storage space.
B00J - R0005 - Student Canteen - (59.06 SQM)	Not Applicable	Circulation or storage space.
B00J - R0007 - Movement - (6.77 SQM)	Not Applicable	Circulation or storage space.
B00J - R0009 - Movement - (8.97 SQM)	Not Applicable	Circulation or storage space.
B00J - R0011 - Movement - (6.91 SQM)	Not Applicable	Circulation or storage space.
B00J - R0012 - Multi-Purpose Space - (631.5 SQM)	● Student Space (292)	
B00J - R0014 - Movement - (16.18 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00J - R0015 - Movement - (14.77 SQM)	Not Applicable	Circulation or storage space.
B00J - R0023 - Stage - (109.53 SQM)	Not Applicable	Circulation or storage space.
B00J - R0024 - Movement - (14.78 SQM)	Not Applicable	Circulation or storage space.
B00J - R0026 - Movement - (8.42 SQM)	Not Applicable	Circulation or storage space.
B00J - R0034 - Movement - (10.74 SQM)	Not Applicable	Circulation or storage space.
B00J - R0036 - Movement - (148.71 SQM)	Not Applicable	Circulation or storage space.
B00J - R0038 - Movement - (8.7 SQM)	Not Applicable	Circulation or storage space.
B00K - M1003 - Main Area - (126.77 SQM)	Not Applicable	Circulation or storage space.
B00K - R0002 - Movement - (9.46 SQM)	Not Applicable	Circulation or storage space.
B00K - R0003 - Laboratory L.S. - (90.68 SQM) - Teaching Space: 1	● Student Space (42)	
B00K - R0004 - Staff Study - (48.39 SQM)	● Office (12)	
B00K - R0005 - Laboratory L.S. - (90.32 SQM) - Teaching Space: 1	● Student Space (41)	
B00K - R0006 - Interview/Office - Type 1 - (14.56 SQM)	● Office (3)	
B00K - R0007 - Movement - (7.63 SQM)	Not Applicable	Circulation or storage space.
B00K - R0011 - Laboratory L.S. - (91.07 SQM) - Teaching Space: 1	● Student Space (42)	
B00K - R0012 - Preparation - (48.63 SQM)	Not Applicable	Circulation or storage space.
B00K - R0013 - Laboratory L.S. - (90.52 SQM) - Teaching Space: 1	● Student Space (41)	
B00K - R0014 - Movement - (70.54 SQM)	Not Applicable	Circulation or storage space.
B00K - R0016 - Movement - (11.17 SQM)	Not Applicable	Circulation or storage space.
B00K - R1001 - Movement - (68.67 SQM)	Not Applicable	Circulation or storage space.
B00K - R1005 - Workroom - (21.26 SQM)	● Office (5)	
B00K - R1007 - Audio Visual Workroom - (39.53 SQM)	● Student Space (18)	
B00K - R1008 - Seminar - (12.33 SQM)	● Office (3)	
B00K - R1009 - Seminar - (15.09 SQM)	● Office (3)	
B00K - R1011 - Movement - (28.73 SQM)	Not Applicable	Circulation or storage space.
B00K - R1013 - Seminar - (14.94 SQM)	● Office (3)	
B00K - R1014 - Seminar - (12.75 SQM)	● Office (3)	
B00K - R1016 - Main Area - (397.73 SQM)	Not Applicable	Circulation or storage space.
B00N - R0002 - Workshop - (52.05 SQM)	● Student Space (24)	
B00O - R0001 - Materials Technology L.S. - (172.41 SQM) - Teaching Space: 1	● Student Space (79)	
B00O - R0002 - Design L.S. - (64.41 SQM) - Teaching Space: 1	● Student Space (29)	
B00O - R0003 - Design L.S. - (73.88 SQM) - Teaching Space: 1	● Student Space (34)	
B00O - R0004 - Design L.S. - (74.06 SQM) - Teaching Space: 1	● Student Space (34)	
B00O - R0005 - Staff Study - (46.67 SQM)	● Office (11)	
B00O - R0008 - Movement - (48.52 SQM)	Not Applicable	Circulation or storage space.
B00O - R0010 - Design L.S. - (74.09 SQM) - Teaching Space: 1	● Student Space (34)	
B00O - R0012 - Design/Technology L.S. - (74.23 SQM) - Teaching Space: 1	● Student Space (34)	
B00O - R0014 - Food Technology L.S. - (75.44 SQM) - Teaching Space: 1	● Student Space (35)	
B00O - R0016 - Food Technology L.S. - (75.58 SQM) - Teaching Space: 1	● Student Space (35)	
B00O - R0017 - Seminar/Technology Space - (38.56 SQM)	● Office (9)	
B00O - R0019 - Movement - (93.73 SQM)	Not Applicable	Circulation or storage space.
B00O - R0031 - Materials Technology L.S. - (105.37 SQM) - Teaching Space: 1	● Student Space (48)	
B00O - R0034 - Welding Area - (12.85 SQM)	Not Applicable	Circulation or storage space.
B00O - R0036 - Welding Area - (8.14 SQM)	Not Applicable	Circulation or storage space.
B00O - R0037 - Materials Technology L.S. - (164.48 SQM) - Teaching Space: 1	● Student Space (76)	
B00O - R0039 - Wood Technology Bay - (38.87 SQM)	Not Applicable	Circulation or storage space.
B00O - R0040 - Metal Technology Bay - (38.17 SQM)	Not Applicable	Circulation or storage space.
B00O - R0041 - Movement - (93.95 SQM)	Not Applicable	Circulation or storage space.
B00O - R0044 - Preparation - Materials - (17.9 SQM)	Not Applicable	Circulation or storage space.
B00O - R0046 - Food Technology L.S. - (116.87 SQM) - Teaching Space: 1	● Student Space (54)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00O - R0048 - Hospitality Space - (31.71 SQM)	● Student Space (14)	
B00O - R0052 - T.A.S. Outdoor Area - (151.66 SQM)	Not Applicable	Circulation or storage space.
B00P - R0005 - Senior Study - (107.71 SQM)	● Office (26)	
B00T - R0002 - Student Canteen - (15.44 SQM)	Not Applicable	Circulation or storage space.
B00T - R0004 - Student Canteen - (53.69 SQM)	Not Applicable	Circulation or storage space.
B0M1 - R0001 - General Learning Space - (50.57 SQM) - Teaching Space: 1	● Student Space (23)	
B0M1 - R0002 - General Learning Space - (50.63 SQM) - Teaching Space: 1	● Student Space (23)	
B0OS - R0005 - Computer Learning Space - (60.64 SQM) - Teaching Space: 1	● Student Space (28)	
B0OS - R0006 - Staff Study - (27.16 SQM)	● Office (6)	
B0OS - R0008 - Computer Learning Space - (60.72 SQM) - Teaching Space: 1	● Student Space (28)	
B0OS - R0009 - Computer Learning Space - (60.85 SQM) - Teaching Space: 1	● Student Space (28)	
B0OS - R0013 - Movement - (37.95 SQM)	Not Applicable	Circulation or storage space.
B0Q1 - R0002 - General Learning Space - (57.75 SQM) - Teaching Space: 1	● Student Space (26)	
B0Q1 - R0003 - General Learning Space - (57.73 SQM) - Teaching Space: 1	● Student Space (26)	
B0Q1 - R0004 - General Learning Space - (57.67 SQM) - Teaching Space: 1	● Student Space (26)	
B0Q1 - R0005 - General Learning Space - (57.75 SQM) - Teaching Space: 1	● Student Space (26)	
NS 120 15910 - NS 120 15910 - Learning Unit Primary Single - PWD - (76 SQM)	● Student Space (35)	
NS 210 13254 - NS 210 13254 - Home Science/Preparation Area/Laundry - (95 SQM)	● Office (23)	
NS 240 15418 - NS 240 15418 - Music Learning Space/Store - (95 SQM)	Not Applicable	Circulation or storage space.
OS 534 11002 - OS 534 11002 - Library/Group Study/Office/A V Store - (152 SQM)	● Student Space (70)	
OS 601 19724 - OS 601 19724 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 602 12173 - OS 602 12173 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 604 13097 - OS 604 13097 - Learning Unit - Single Kindergarten - (95 SQM)	● Student Space (44)	
OS 720 13255 - OS 720 13255 - Science Laboratory/Prep Room - (114 SQM)	Not Applicable	Circulation or storage space.
OS 760 11798 - OS 760 11798 - Woodwork/Store - (114 SQM)	Not Applicable	Circulation or storage space.