

VENTILATION AUDIT REPORT

SCHOOL:	Sir Joseph Banks High School (8250)
AMU REGION:	South Western Sydney
STATE ELECTORATE:	East Hills
LOCAL GOVERNMENT AREA:	Canterbury-Bankstown

8250 - Sir Joseph Banks High School
Site Plan (11882)














Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0005 - Principal Office - (19.39 SQM)	Office (4)	
B00A - R0009 - Administration - Clerical - (29.65 SQM)	Office (7)	
B00A - R0010 - Administration - Clerical - (9.65 SQM)	Office (2)	
B00A - R0013 - Public Reception - (20.38 SQM)	Not Applicable	Circulation or storage space.
B00A - R0014 - Movement - (19.59 SQM)	Not Applicable	Circulation or storage space.
B00B - M0003 - Movement - (13.31 SQM)	Not Applicable	Circulation or storage space.
B00B - R0012 - Practice/Seminar - (10.63 SQM)	Not Applicable	Circulation or storage space.
B00B - R0014 - Movement - (8.28 SQM)	Not Applicable	Circulation or storage space.
B00B - R0015 - Practice/Seminar - (9.55 SQM)	Not Applicable	Circulation or storage space.
B00B - R0017 - Movement - (10.03 SQM)	Not Applicable	Circulation or storage space.
B00B - R0021 - Multi-Purpose Space - (442.18 SQM)	Student Space (205)	
B00B - R0030 - Stage - (80.04 SQM)	Not Applicable	Circulation or storage space.
B00B - R9002 - General Assistants - (15.68 SQM)	Office (3)	
B00B - R9003 - General Assistants - (88.59 SQM)	Office (22)	
B00B - R9005 - Ancillary Staff - (14.06 SQM)	Office (3)	
B00B - R9006 - Movement - (6.17 SQM)	Not Applicable	Circulation or storage space.
B00C - R0002 - Practice/Seminar - (26.03 SQM)	Not Applicable	Circulation or storage space.
B00C - R0003 - Music Learning Space - (52.65 SQM) - Teaching Space: 1	Student Space (24)	
B00C - R0005 - Staff Study - (7.71 SQM)	Office (1)	
B00C - R0010 - Music Learning Space - (65.8 SQM) - Teaching Space: 1	Student Space (30)	
B00C - R0017 - General Learning Space - (52.57 SQM) - Teaching Space: 1	Student Space (24)	
B00C - R0019 - General Learning Space - (56.52 SQM) - Teaching Space: 1	Student Space (26)	
B00C - R0020 - Performance Workspace - (68.75 SQM) - Teaching Space: 1	Student Space (31)	
B00C - R0022 - Computer Learning Space - (52.07 SQM) - Teaching Space: 1	Student Space (24)	
B00C - R0026 - Dark Room - (26.14 SQM)	Office (6)	
B00C - R0033 - Art Learning Space - (64.02 SQM) - Teaching Space: 1	Student Space (29)	
B00C - R0035 - Art Learning Space - (57.66 SQM) - Teaching Space: 1	Student Space (26)	
B00C - R0037 - Art Learning Space - (57.68 SQM) - Teaching Space: 1	Student Space (26)	
B00C - R0039 - Tea Room - (6.06 SQM)	Not Applicable	Circulation or storage space.
B00C - R0040 - Staff Study - (19.57 SQM)	Office (4)	
B00D - R0007 - Movement - (8.61 SQM)	Not Applicable	Circulation or storage space.
B00D - R0015 - Movement - (9.57 SQM)	Not Applicable	Circulation or storage space.
B00D - R0017 - Materials Workshop - Type 2 - (70.86 SQM)	Student Space (32)	
B00D - R0021 - Wood Technology L.S. - (78.01 SQM) - Teaching Space: 1	Student Space (36)	
B00D - R0023 - Wood Technology L.S. - (77.54 SQM) - Teaching Space: 1	Student Space (35)	
B00D - R0025 - Metal Technology L.S. - (71.34 SQM) - Teaching Space: 1	Student Space (33)	
B00D - R0030 - Metal Technology L.S. - (69.8 SQM) - Teaching Space: 1	Student Space (32)	
B00E - M1001 - Interview/Office - Type 1 - (18.93 SQM)	Office (4)	
B00E - M1007 - Senior Study - (110.27 SQM)	Office (27)	
B00E - R0002 - Laboratory L.S. - (92.07 SQM) - Teaching Space: 1	Student Space (42)	
B00E - R0003 - Staff Study - (48.06 SQM)	Office (12)	
B00E - R0004 - Laboratory L.S. - (92.16 SQM) - Teaching Space: 1	Student Space (42)	
B00E - R0007 - Laboratory L.S. - (92.06 SQM) - Teaching Space: 1	Student Space (42)	
B00E - R0008 - Preparation - Science - (47.79 SQM)	Not Applicable	Circulation or storage space.
B00E - R0009 - Laboratory L.S. - (91.97 SQM) - Teaching Space: 1	Student Space (42)	
B00E - R0010 - Movement - (42.68 SQM)	Not Applicable	Circulation or storage space.
B00E - R1009 - Audio Visual Workroom - (24.92 SQM)	Student Space (11)	
B00E - R1013 - Main Area - (363.94 SQM)	Not Applicable	Circulation or storage space.
B00E - R1020 - Seminar - (25.27 SQM)	Office (6)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00E - R1021 - Seminar - (25.34 SQM)	Office (6)	
B00F - R0004 - General Learning Space - (66.83 SQM) - Teaching Space: 1	Student Space (31)	
B00F - R0005 - General Learning Space - (53.45 SQM) - Teaching Space: 1	Student Space (24)	
B00F - R0006 - General Learning Space - (66.63 SQM) - Teaching Space: 1	Student Space (30)	
B00F - R0007 - General Learning Space - (53.16 SQM) - Teaching Space: 1	Student Space (24)	
B00F - R0008 - Preparation - Science - (26.36 SQM)	Not Applicable	Circulation or storage space.
B00F - R0009 - Laboratory L.S. - (93.48 SQM) - Teaching Space: 1	Student Space (43)	
B00F - R0010 - Deputy Principal Office - (26.65 SQM)	Office (6)	
B00F - R0012 - Food Technology L.S. - (81.94 SQM) - Teaching Space: 1	Student Space (38)	
B00F - R0014 - General Learning Space - (51.26 SQM) - Teaching Space: 1	Student Space (23)	
B00F - R0015 - Tea Room - (14.02 SQM)	Not Applicable	Circulation or storage space.
B00F - R0016 - Staff Study - (25.34 SQM)	Office (6)	
B00F - R0017 - Fitness Laboratory - (89.18 SQM)	Student Space (41)	
B00F - R0030 - Deputy Principal Office - (17.21 SQM)	Office (4)	
B00F - R0031 - Food Technology L.S. - (74.09 SQM) - Teaching Space: 1	Student Space (34)	
B00F - R0034 - Preparation - Materials - (26.29 SQM)	Not Applicable	Circulation or storage space.
B00F - R0035 - Food Technology L.S. - (93.11 SQM) - Teaching Space: 1	Student Space (43)	
B00F - R0036 - Deputy Principal Office - (26.32 SQM)	Office (6)	
B00F - R0039 - Staff Study - (36.61 SQM)	Office (9)	
B00F - R0040 - General Learning Space - (66.56 SQM) - Teaching Space: 1	Student Space (30)	
B00F - R0043 - General Learning Space - (66.52 SQM) - Teaching Space: 1	Student Space (30)	
B00F - R0046 - General Learning Space - (60.19 SQM) - Teaching Space: 1	Student Space (27)	
B00F - R0047 - Staff Study - (39.3 SQM)	Office (9)	
B00F - R0048 - Tea Room - (5.14 SQM)	Not Applicable	Circulation or storage space.
B00F - R0051 - Movement - (447.28 SQM)	Not Applicable	Circulation or storage space.
B00F - R0053 - Movement - (27.79 SQM)	Not Applicable	Circulation or storage space.
B00F - R0056 - Movement - (27.78 SQM)	Not Applicable	Circulation or storage space.
B00F - R0061 - Movement - (27.77 SQM)	Not Applicable	Circulation or storage space.
B00F - R0062 - Staff Study - (37.21 SQM)	Office (9)	
B00F - R1001 - Special Learning Space - (51.86 SQM) - Teaching Space: 1	Student Space (24)	
B00F - R1006 - Special Learning Space - (53.16 SQM) - Teaching Space: 1	Student Space (24)	
B00F - R1010 - Staff Study - (53.01 SQM)	Office (13)	
B00F - R1012 - General Learning Space - (52.94 SQM) - Teaching Space: 1	Student Space (24)	
B00F - R1014 - General Learning Space - (52.94 SQM) - Teaching Space: 1	Student Space (24)	
B00F - R1015 - General Learning Space - (52.8 SQM) - Teaching Space: 1	Student Space (24)	
B00F - R1016 - Computer Learning Space - (53.02 SQM) - Teaching Space: 1	Student Space (24)	
B00F - R1019 - Computer Learning Space - (52.87 SQM) - Teaching Space: 1	Student Space (24)	
B00F - R1021 - General Learning Space - (52.94 SQM) - Teaching Space: 1	Student Space (24)	
B00F - R1026 - General Learning Space - (52.58 SQM) - Teaching Space: 1	Student Space (24)	
B00F - R1027 - General Learning Space - (53.53 SQM) - Teaching Space: 1	Student Space (24)	
B00F - R1028 - General Learning Space - (53.82 SQM) - Teaching Space: 1	Student Space (24)	
B00F - R1029 - General Learning Space - (64.12 SQM) - Teaching Space: 1	Student Space (29)	
B00F - R1032 - General Learning Space - (53.02 SQM) - Teaching Space: 1	Student Space (24)	
B00F - R1033 - General Learning Space - (52.87 SQM) - Teaching Space: 1	Student Space (24)	
B00F - R1034 - General Learning Space - (53.09 SQM) - Teaching Space: 1	Student Space (24)	
B00F - R1035 - Staff Study - (39.29 SQM)	Office (9)	
B00F - R1036 - Staff Study - (34.37 SQM)	Office (8)	
B00F - R1038 - Special Learning Space - (51.32 SQM) - Teaching Space: 1	Student Space (23)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00F - R1040 - General Learning Space - (52.87 SQM) - Teaching Space: 1	 Student Space (24)	
B00F - R1041 - Movement - (11.19 SQM)	Not Applicable	Circulation or storage space.
B00F - R1042 - Leading Teacher - (9.88 SQM)	 Office (2)	
B00F - R1043 - Interview/Office - Type 1 - (9.96 SQM)	 Office (2)	
B00F - R1045 - Tea Room - (9.53 SQM)	Not Applicable	Circulation or storage space.
B00F - R1047 - Interview/Office - Type 1 - (19.81 SQM)	 Office (4)	
B00F - R1049 - Movement - (378.68 SQM)	Not Applicable	Circulation or storage space.
B00F - R1051 - Staff Study - (52.72 SQM)	 Office (13)	
B00F - R1052 - Special Learning Space - (39.85 SQM) - Teaching Space: 1	 Student Space (18)	
B00F - R1054 - Special Learning Space - (42.34 SQM) - Teaching Space: 1	 Student Space (19)	
B00F - R1055 - Movement - (15.71 SQM)	Not Applicable	Circulation or storage space.
B00F - R1061 - Staff Study - (32.28 SQM)	 Office (8)	
B00F - R1062 - Commonroom - (79.42 SQM)	 Office (19)	
B00G - R0002 - Student Canteen - (39.91 SQM)	Not Applicable	Circulation or storage space.
B00H - R0001 - General Learning Space - (91.98 SQM) - Teaching Space: 1	 Student Space (42)	
B00H - R0002 - Seminar - Type 2 - (18.85 SQM)	 Office (4)	