

VENTILATION AUDIT REPORT

SCHOOL:	Smithfield Public School (3073)
AMU REGION:	South Western Sydney
STATE ELECTORATE:	Prospect
LOCAL GOVERNMENT AREA:	Fairfield

3073 - Smithfield Public School
Site Plan (11164)



1:1,190






Printed: 21-Mar-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0003 - Practical Activities - 1hb - (22.6 SQM)	● Student Space (10)	
B00A - R0004 - Movement - (5.82 SQM)	Not Applicable	Circulation or storage space.
B00A - R0007 - Home Base - (56.49 SQM) - Teaching Space: 1	● Student Space (26)	
B00A - R0008 - Home Base - (56.33 SQM) - Teaching Space: 1	● Student Space (26)	
B00A - R0011 - Movement - (8.58 SQM)	Not Applicable	Circulation or storage space.
B00A - R0012 - Practical Activities - (15.28 SQM)	● Student Space (7)	
B00A - R0015 - Practical Activities - 1hb - (14.87 SQM)	● Student Space (6)	
B00A - R0016 - Home Base - (70.41 SQM) - Teaching Space: 1	● Student Space (32)	
B00A - R0017 - Movement - (19.35 SQM)	Not Applicable	Circulation or storage space.
B00B - R0001 - Movement - (5.31 SQM)	Not Applicable	Circulation or storage space.
B00B - R0002 - Movement - (6.52 SQM)	Not Applicable	Circulation or storage space.
B00B - R0003 - Withdrawal Space - 1hb - (21.48 SQM)	● Student Space (9)	
B00B - R0004 - Special Programs Room - (57.38 SQM)	● Student Space (26)	
B00B - R0006 - Practical Activities - (9.72 SQM)	● Student Space (4)	
B00B - R0007 - Movement - (5.76 SQM)	Not Applicable	Circulation or storage space.
B00B - R0012 - Home Base - (57.38 SQM) - Teaching Space: 1	● Student Space (26)	
B00B - R0013 - Home Base - M - (57.37 SQM) - Teaching Space: 1	● Student Space (26)	
B00B - R0015 - Movement - (11.66 SQM)	Not Applicable	Circulation or storage space.
B00B - R0018 - Staff Room Annexe - (8.39 SQM)	● Office (2)	
B00B - R0021 - Home Base - (57.68 SQM) - Teaching Space: 1	● Student Space (26)	
B00C - R0001 - Home Base - (57.06 SQM) - Teaching Space: 1	● Student Space (26)	
B00C - R0004 - Movement - (6.34 SQM)	Not Applicable	Circulation or storage space.
B00C - R0007 - Home Base - (57.38 SQM) - Teaching Space: 1	● Student Space (26)	
B00C - R0008 - Home Base - (57.21 SQM) - Teaching Space: 1	● Student Space (26)	
B00C - R0012 - Movement - (6.2 SQM)	Not Applicable	Circulation or storage space.
B00C - R0014 - Home Base - (57.38 SQM) - Teaching Space: 1	● Student Space (26)	
B00D - R0001 - Home Base - (57.38 SQM) - Teaching Space: 1	● Student Space (26)	
B00D - R0005 - Movement - (5.21 SQM)	Not Applicable	Circulation or storage space.
B00D - R0007 - Home Base - (57.38 SQM) - Teaching Space: 1	● Student Space (26)	
B00D - R0008 - Home Base - (89.95 SQM) - Teaching Space: 1	● Student Space (41)	
B00D - R0009 - Practical Activities - (19.56 SQM)	● Student Space (9)	
B00E - R0001 - Movement - (19.33 SQM)	Not Applicable	Circulation or storage space.
B00E - R0002 - Staff Room - (107.69 SQM)	● Office (26)	
B00E - R0005 - Interview - (13.23 SQM)	● Office (3)	
B00E - R0006 - Movement - (38.88 SQM)	Not Applicable	Circulation or storage space.
B00E - R0009 - Interview - (14.61 SQM)	● Office (3)	
B00E - R0012 - Principal - (22.56 SQM)	● Office (5)	
B00E - R0013 - Deputy Principal - (13.44 SQM)	● Office (3)	
B00E - R0014 - Entry Vestibule - (17.14 SQM)	Not Applicable	Circulation or storage space.
B00E - R0015 - Movement - (11.16 SQM)	Not Applicable	Circulation or storage space.
B00E - R0016 - Duplicating Workroom - (14.91 SQM)	● Office (3)	
B00E - R0017 - Clerical Office - (15.06 SQM)	● Office (3)	
B00E - R0019 - Sick Bay - (13.66 SQM)	● Student Space (6)	
B00E - R0021 - Movement - (47.35 SQM)	Not Applicable	Circulation or storage space.
B00H - R0001 - Home Base - (63.32 SQM) - Teaching Space: 1	● Student Space (29)	
B00H - R0002 - Home Base - (51.92 SQM) - Teaching Space: 1	● Student Space (24)	
B00H - R0009 - Withdrawal Space - 1hb - (8.89 SQM)	● Student Space (4)	
B00J - R0005 - Outdoor Learning Area - (74.51 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00J - R0008 - Home Base - (84.62 SQM) - Teaching Space: 1	● Student Space (39)	
B00J - R0009 - Home Base - (56.62 SQM) - Teaching Space: 1	● Student Space (26)	
B00K - R0004 - Movement - (128.35 SQM)	Not Applicable	Circulation or storage space.
B00K - R0005 - Movement - (27.98 SQM)	Not Applicable	Circulation or storage space.
B00K - R0007 - Movement - (8.41 SQM)	Not Applicable	Circulation or storage space.
B00K - R0008 - Staff Kitchen - (10.05 SQM)	● Office (2)	
B00K - R0010 - Staff Room Annexe - (8.91 SQM)	● Office (2)	
B00K - R0011 - Home Base - E - (78.34 SQM) - Teaching Space: 1	● Student Space (36)	
B00K - R0012 - Practical Activities - E - (34.83 SQM)	● Student Space (16)	
B00L - R0004 - Canteen - (42.39 SQM)	Not Applicable	Circulation or storage space.
B00L - R0009 - Raised Platform - (96.51 SQM)	Not Applicable	Circulation or storage space.
B00L - R0016 - Communal Space - (252.28 SQM)	● Student Space (117)	
B00L - R0020 - Movement - (210.5 SQM)	Not Applicable	Circulation or storage space.
B00M - R0003 - Movement - (34.45 SQM)	Not Applicable	Circulation or storage space.
B00N - R0001 - Movement - (158.06 SQM)	Not Applicable	Circulation or storage space.
B00N - R0005 - Entry Vestibule - (13.55 SQM)	Not Applicable	Circulation or storage space.
B00N - R0008 - Reading Area - (261.59 SQM)	● Student Space (121)	
B00N - R0009 - Reading Area - (15.83 SQM)	● Student Space (7)	
B00R - R0001 - Movement - (24.02 SQM)	Not Applicable	Circulation or storage space.
B00R - R0005 - Home Base - Pre - (76.14 SQM) - Teaching Space: 1	● Student Space (35)	
B00R - R0007 - Withdrawal - Pre - (12.26 SQM)	● Student Space (5)	
B00R - R0008 - Staff Room - (12.26 SQM)	● Office (3)	
B00R - R0013 - Movement - (30.66 SQM)	Not Applicable	Circulation or storage space.
B00S - R0001 - Movement - (24.01 SQM)	Not Applicable	Circulation or storage space.
B00S - R0005 - Home Base - Pre - (76.14 SQM) - Teaching Space: 1	● Student Space (35)	
B00S - R0007 - Withdrawal - Pre - (12.25 SQM)	● Student Space (5)	
B00S - R0008 - Staff Room - (12.25 SQM)	● Office (3)	
B00S - R0013 - Movement - (30.66 SQM)	Not Applicable	Circulation or storage space.
B00T - R0002 - Movement - (14.94 SQM)	Not Applicable	Circulation or storage space.
B00W - R0001 - Practical Activities - 1hb - (18.06 SQM)	● Student Space (8)	
B00W - R0002 - Home Base - (60.35 SQM) - Teaching Space: 1	● Student Space (27)	
B00W - R0004 - Withdrawal Space - 1hb - (7.68 SQM)	● Student Space (3)	
B00W - R0005 - Practical Activities - 1hb - (19.19 SQM)	● Student Space (8)	
B00W - R0006 - Home Base - (60.62 SQM) - Teaching Space: 1	● Student Space (28)	
B00W - R0008 - Withdrawal Space - 2hb - (11.82 SQM)	● Student Space (5)	
B00W - R0009 - Practical Activities - 1hb - (19.21 SQM)	● Student Space (8)	
B00W - R0010 - Home Base - (61.13 SQM) - Teaching Space: 1	● Student Space (28)	
B00X - R0001 - Practical Activities - 1hb - (19.94 SQM)	● Student Space (9)	
B00X - R0002 - Home Base - (58.68 SQM) - Teaching Space: 1	● Student Space (27)	
B00X - R0004 - Withdrawal Space - 1hb - (7.64 SQM)	● Student Space (3)	
B00X - R0005 - Practical Activities - 1hb - (19.19 SQM)	● Student Space (8)	
B00X - R0006 - Home Base - (60.62 SQM) - Teaching Space: 1	● Student Space (28)	
B00X - R0008 - Withdrawal Space - 2hb - (11.82 SQM)	● Student Space (5)	
B00X - R0009 - Practical Activities - 1hb - (19.77 SQM)	● Student Space (9)	
B00X - R0010 - Home Base - (60.67 SQM) - Teaching Space: 1	● Student Space (28)	
OS 602 12028 - OS 602 12028 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 12162 - OS 602 12162 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 13830 - OS 602 13830 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	

Entity Location	Audit Condition Classification (Capacity)	Comment
OS 602 14605 - OS 602 14605 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 602 14773 - OS 602 14773 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 606 19280 - OS 606 19280 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	 Student Space (35)	
OS 606 19282 - OS 606 19282 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	 Student Space (35)	
OS 751 15283 - OS 751 15283 - Learning Unit - ESL - (76 SQM)	 Student Space (35)	