

# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Smithfield West Public School (4355)</b>
<b>AMU REGION:</b>	<b>South Western Sydney</b>
<b>STATE ELECTORATE:</b>	<b>Prospect</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Fairfield</b>

4355 - Smithfield West Public School  
Site Plan (11306)



1:962

Printed: 12-Jun-2021

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B001 - R0005 - Home Base - (56.63 SQM) - Teaching Space: 1	 Student Space (26)	
B001 - R0012 - Home Base - (56.48 SQM) - Teaching Space: 1	 Student Space (26)	
B001 - R0019 - Interview - (18.66 SQM)	 Office (4)	
B001 - R0025 - Movement - (12.14 SQM)	Not Applicable	Circulation or storage space.
B001 - R0030 - Practical Activities - 1hb - (12.63 SQM)	 Student Space (5)	
B001 - R0031 - Home Base - (54.91 SQM) - Teaching Space: 1	 Student Space (25)	
B001 - R0033 - Practical Activities/Movement - 2hb - (17.83 SQM)	 Student Space (8)	
B001 - R0034 - Home Base - (58.34 SQM) - Teaching Space: 1	 Student Space (27)	
B001 - R0036 - Practical Activities - 1hb - (9.37 SQM)	 Student Space (4)	
B001 - R0040 - Staff Kitchen - (5.68 SQM)	 Office (1)	
B001 - R0042 - Shared Study Space - (20.26 SQM)	 Office (5)	
B002 - R0013 - Outdoor Learning Area - (79.6 SQM)	Not Applicable	Circulation or storage space.
B002 - R0014 - Practical Activities - 1hb - (12.05 SQM)	 Student Space (5)	
B002 - R0015 - Home Base - (68.22 SQM) - Teaching Space: 1	 Student Space (31)	
B002 - R0017 - Home Base - (70.79 SQM) - Teaching Space: 1	 Student Space (32)	
B002 - R0020 - Practical Activities - 1hb - (16.41 SQM)	 Student Space (7)	
B003 - R0009 - Movement - (8.09 SQM)	Not Applicable	Circulation or storage space.
B003 - R0013 - Practical Activities - 1hb - (8.31 SQM)	 Student Space (3)	
B003 - R0014 - Home Base - (71.72 SQM) - Teaching Space: 1	 Student Space (33)	
B003 - R0015 - Home Base - (69.43 SQM) - Teaching Space: 1	 Student Space (32)	
B003 - R0016 - Practical Activities - 1hb - (10.31 SQM)	 Student Space (4)	
B004 - R0002 - Entry Vestibule - (11.62 SQM)	Not Applicable	Circulation or storage space.
B004 - R0003 - Clerical Office - (11.2 SQM)	 Office (2)	
B004 - R0004 - Sick Bay - (7.68 SQM)	 Student Space (3)	
B004 - R0008 - Entry Vestibule - (10.6 SQM)	Not Applicable	Circulation or storage space.
B004 - R0009 - Duplicating Workroom - (35.12 SQM)	 Office (8)	
B004 - R0010 - Interview - (9.55 SQM)	 Office (2)	
B004 - R0013 - Staff Room Annexe - (14.57 SQM)	 Office (3)	
B004 - R0014 - Staff Room Annexe - (14.61 SQM)	 Office (3)	
B004 - R0019 - Principal - (17.35 SQM)	 Office (4)	
B004 - R0020 - Movement - (14.35 SQM)	Not Applicable	Circulation or storage space.
B005 - R0018 - Practical Activities - 1hb - (10.79 SQM)	 Student Space (5)	
B005 - R0019 - Home Base - (61.45 SQM) - Teaching Space: 1	 Student Space (28)	
B005 - R0020 - Home Base - (71.27 SQM) - Teaching Space: 1	 Student Space (33)	
B005 - R0021 - Special Programs Room - (123.07 SQM)	 Student Space (57)	
B005 - R0022 - Staff Kitchen - (13.92 SQM)	 Office (3)	
B005 - R0023 - Staff Room - (100.31 SQM)	 Office (25)	
B006 - R0006 - Home Base - (57.05 SQM) - Teaching Space: 1	 Student Space (26)	
B006 - R0014 - Home Base - (57.05 SQM) - Teaching Space: 1	 Student Space (26)	
B006 - R0021 - Practical Activities - 1hb - (10.62 SQM)	 Student Space (4)	
B006 - R0022 - Home Base - (53.03 SQM) - Teaching Space: 1	 Student Space (24)	
B006 - R0024 - Practical Activities/Movement - 2hb - (13.07 SQM)	 Student Space (6)	
B006 - R0025 - Home Base - (53.15 SQM) - Teaching Space: 1	 Student Space (24)	
B006 - R0027 - Practical Activities - 1hb - (10.96 SQM)	 Student Space (5)	
B007 - R0006 - Home Base - (57.14 SQM) - Teaching Space: 1	 Student Space (26)	
B007 - R0014 - Home Base - (57.53 SQM) - Teaching Space: 1	 Student Space (26)	
B007 - R0020 - Practical Activities - 1hb - (10.19 SQM)	 Student Space (4)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B007 - R0021 - Home Base - (56.23 SQM) - Teaching Space: 1	 Student Space (26)	
B007 - R0022 - Practical Activities/Movement - 2hb - (15.73 SQM)	 Student Space (7)	
B007 - R0023 - Home Base - (55.64 SQM) - Teaching Space: 1	 Student Space (25)	
B007 - R0024 - Practical Activities - 1hb - (10.85 SQM)	 Student Space (5)	
B00B - R0003 - Special Programs Room - (39.93 SQM)	 Student Space (18)	
B00B - R0009 - Movement - (11.03 SQM)	Not Applicable	Circulation or storage space.
B00B - R0014 - Reading Area - (226.61 SQM)	 Student Space (105)	
B00C - R0001 - Staff Room Annexe - (17.67 SQM)	 Office (4)	
B00C - R0004 - Outdoor Learning Area - (13.52 SQM)	Not Applicable	Circulation or storage space.
B00D - R0001 - Communal Space - (201.29 SQM)	 Student Space (93)	
B00D - R0002 - Raised Platform - (63.79 SQM)	Not Applicable	Circulation or storage space.
B00D - R0015 - Movement - (28.6 SQM)	Not Applicable	Circulation or storage space.
B00D - R0016 - Movement - (6.83 SQM)	Not Applicable	Circulation or storage space.
B00E - R0001 - Canteen - (43.88 SQM)	Not Applicable	Circulation or storage space.