

VENTILATION AUDIT REPORT

SCHOOL:	Smithtown Public School (3075)
AMU REGION:	North Coast
STATE ELECTORATE:	Oxley
LOCAL GOVERNMENT AREA:	Kempsey

3075 - Smithtown Public School
Site Plan (12426)



1:822

Printed: 21-Mar-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Movement - (6.91 SQM)	Not Applicable	Circulation or storage space.
B00A - R0005 - Staff Room - (33.5 SQM)	Office (8)	
B00A - R0008 - Canteen - (13.55 SQM)	Not Applicable	Circulation or storage space.
B00A - R0012 - Clerical Office - (22.06 SQM)	Office (5)	
B00B - R0001 - Practical Activities - 1hb - (69.48 SQM)	Student Space (32)	
B00B - R0003 - Home Base - (53.67 SQM) - Teaching Space: 1	Student Space (24)	
B00B - R0012 - Principal - (12 SQM)	Office (3)	
B00B - R0013 - Sick Bay - (5.38 SQM)	Student Space (2)	
B00B - R0018 - Home Base - (94.24 SQM) - Teaching Space: 1	Student Space (43)	
B00C - R0003 - Home Base - (48.76 SQM) - Teaching Space: 1	Student Space (22)	
B00H - R0001 - Staff Room Annexe - (6.65 SQM)	Office (1)	
B00H - R0002 - Movement - (8.21 SQM)	Not Applicable	Circulation or storage space.
B00H - R0004 - Withdrawal Space - 1hb - (13.83 SQM)	Student Space (6)	
B00H - R0005 - Home Base - (56.17 SQM) - Teaching Space: 1	Student Space (26)	
B00I - R0002 - Outdoor Learning Area - (8.37 SQM)	Not Applicable	Circulation or storage space.
B00J - R0002 - Practical Activities - 1hb - (19.39 SQM)	Student Space (8)	
B00J - R0004 - Home Base - (58.86 SQM) - Teaching Space: 1	Student Space (27)	
B00J - R0005 - Withdrawal Space - 2hb - (10.69 SQM)	Student Space (4)	
B00J - R0006 - Home Base - (58.76 SQM) - Teaching Space: 1	Student Space (27)	
B00J - R0008 - Practical Activities - 1hb - (19.39 SQM)	Student Space (8)	