


VENTILATION AUDIT REPORT

SCHOOL:	South Coogee Public School (3703)
AMU REGION:	Sydney
STATE ELECTORATE:	Coogee
LOCAL GOVERNMENT AREA:	Randwick

3703 - South Coogee Public School
Site Plan (12458)



1:830

Printed: 10-Apr-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0006 - Home Base - (56.69 SQM) - Teaching Space: 1	● Student Space (26)	
B00A - R0010 - Movement - (31.64 SQM)	Not Applicable	Circulation or storage space.
B00A - R0011 - Home Base - (57.75 SQM) - Teaching Space: 1	● Student Space (26)	
B00A - R0014 - Home Base - (57.12 SQM) - Teaching Space: 1	● Student Space (26)	
B00A - R0017 - Movement - (18.94 SQM)	Not Applicable	Circulation or storage space.
B00A - R0019 - Home Base - (47.77 SQM) - Teaching Space: 1	● Student Space (22)	
B00A - R0026 - Staff Room - (47.63 SQM)	● Office (11)	
B00A - R0035 - Interview - (12.53 SQM)	● Office (3)	
B00A - R0036 - Movement - (11.16 SQM)	Not Applicable	Circulation or storage space.
B00A - R0042 - Movement - (7.34 SQM)	Not Applicable	Circulation or storage space.
B00A - R0044 - Staff Kitchen - (8.65 SQM)	● Office (2)	
B00A - R0045 - Movement - (70.77 SQM)	Not Applicable	Circulation or storage space.
B00A - R0057 - Entry Vestibule - (16.9 SQM)	Not Applicable	Circulation or storage space.
B00A - R0058 - Clerical Office - (20.15 SQM)	● Office (5)	
B00A - R0059 - Movement - (38.93 SQM)	Not Applicable	Circulation or storage space.
B00A - R0063 - Movement - (10.47 SQM)	Not Applicable	Circulation or storage space.
B00A - R0064 - Clerical Office - (25.19 SQM)	● Office (6)	
B00A - R0069 - Principal - (19.46 SQM)	● Office (4)	
B00A - R0072 - Clerical Office - (24.51 SQM)	● Office (6)	
B00A - R0073 - Sick Bay - (6.06 SQM)	● Student Space (2)	
B00A - R0074 - Clerical Office/Workroom - (10.45 SQM)	● Office (2)	
B00A - R0081 - Practical Activities/Movement - 1hb - (32.66 SQM)	● Student Space (15)	
B00A - R0082 - Movement - (569.65 SQM)	Not Applicable	Circulation or storage space.
B00A - R0083 - Staff Kitchen - (11.82 SQM)	● Office (2)	
B00A - R0084 - Movement - (109.17 SQM)	Not Applicable	Circulation or storage space.
B00A - R0088 - Home Base - (67.59 SQM) - Teaching Space: 1	● Student Space (31)	
B00A - R0089 - Movement - (40.05 SQM)	Not Applicable	Circulation or storage space.
B00A - R0090 - Home Base - (47.1 SQM) - Teaching Space: 1	● Student Space (21)	
B00A - R0095 - Staff Room Annexe - (24.87 SQM)	● Office (6)	
B00A - R0096 - Staff Room - (109.41 SQM)	● Office (27)	
B00A - R0098 - Reading Area - (256.05 SQM)	● Student Space (118)	
B00A - R0099 - Movement - (100.35 SQM)	Not Applicable	Circulation or storage space.
B00A - R0100 - Movement - (31.82 SQM)	Not Applicable	Circulation or storage space.
B00A - R0101 - Movement - (12.1 SQM)	Not Applicable	Circulation or storage space.
B00A - R0103 - Movement - (90.35 SQM)	Not Applicable	Circulation or storage space.
B00A - R1001 - Movement - (87.31 SQM)	Not Applicable	Circulation or storage space.
B00A - R1003 - Home Base - (66.61 SQM) - Teaching Space: 1	● Student Space (30)	
B00A - R1004 - Home Base - (66.61 SQM) - Teaching Space: 1	● Student Space (30)	
B00A - R1005 - Home Base - (66.93 SQM) - Teaching Space: 1	● Student Space (31)	
B00A - R2002 - Movement - (67.47 SQM)	Not Applicable	Circulation or storage space.
B00A - R2003 - Home Base - (60.51 SQM) - Teaching Space: 1	● Student Space (28)	
B00A - R2004 - Home Base - (60.51 SQM) - Teaching Space: 1	● Student Space (28)	
B00A - R2005 - Home Base - (60.52 SQM) - Teaching Space: 1	● Student Space (28)	
B00A - R2007 - Movement - (11.14 SQM)	Not Applicable	Circulation or storage space.
B00B - R0001 - Movement - (62.25 SQM)	Not Applicable	Circulation or storage space.
B00B - R0006 - Canteen - (26.07 SQM)	Not Applicable	Circulation or storage space.
B00B - R0013 - Movement - (34.79 SQM)	Not Applicable	Circulation or storage space.
B00B - R1001 - Movement - (75.98 SQM)	Not Applicable	Circulation or storage space.
B00B - R1004 - Home Base - (56.97 SQM) - Teaching Space: 1	● Student Space (26)	
B00B - R1006 - Movement - (6.62 SQM)	Not Applicable	Circulation or storage space.
B00B - R1007 - Home Base - (57.21 SQM) - Teaching Space: 1	● Student Space (26)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00B - R1009 - Movement - (13.97 SQM)	Not Applicable	Circulation or storage space.
B00B - R1011 - Home Base - (56.81 SQM) - Teaching Space: 1	● Student Space (26)	
B00C - R0023 - Practical Activities - 1hb - (65.74 SQM)	● Student Space (30)	
B00C - R0024 - Home Base - (52.54 SQM) - Teaching Space: 1	● Student Space (24)	
B00C - R0027 - Movement - (25.47 SQM)	Not Applicable	Circulation or storage space.
B00C - R0035 - Movement - (24.32 SQM)	Not Applicable	Circulation or storage space.
B00C - R0039 - Home Base - (83.03 SQM) - Teaching Space: 1	● Student Space (38)	
B00C - R0040 - Home Base - (84.14 SQM) - Teaching Space: 1	● Student Space (39)	
B00C - R0041 - Movement - (58.75 SQM)	Not Applicable	Circulation or storage space.
B00C - R0042 - Movement - (14.78 SQM)	Not Applicable	Circulation or storage space.
B00C - R0043 - Movement - (65.95 SQM)	Not Applicable	Circulation or storage space.
B00D - R0001 - Movement - (59.3 SQM)	Not Applicable	Circulation or storage space.
B00D - R0002 - Home Base - (57.18 SQM) - Teaching Space: 1	● Student Space (26)	
B00D - R0004 - Movement - (14.09 SQM)	Not Applicable	Circulation or storage space.
B00D - R0005 - Home Base - (57.26 SQM) - Teaching Space: 1	● Student Space (26)	
B00D - R0007 - Movement - (10.29 SQM)	Not Applicable	Circulation or storage space.
B00D - R0011 - Home Base - (56.71 SQM) - Teaching Space: 1	● Student Space (26)	
B00D - R0013 - Movement - (6.48 SQM)	Not Applicable	Circulation or storage space.
B00D - R0014 - Movement - (7.41 SQM)	Not Applicable	Circulation or storage space.
B00D - R1001 - Movement - (76.89 SQM)	Not Applicable	Circulation or storage space.
B00D - R1002 - Home Base - (57.11 SQM) - Teaching Space: 1	● Student Space (26)	
B00D - R1004 - Movement - (13.75 SQM)	Not Applicable	Circulation or storage space.
B00D - R1005 - Home Base - (57.6 SQM) - Teaching Space: 1	● Student Space (26)	
B00D - R1009 - Home Base - (56.65 SQM) - Teaching Space: 1	● Student Space (26)	
B00D - R1011 - Movement - (6.51 SQM)	Not Applicable	Circulation or storage space.
B00D - R1012 - Movement - (7.41 SQM)	Not Applicable	Circulation or storage space.
B00E - R0001 - Communal Space - (200.05 SQM)	● Student Space (92)	
B00E - R0002 - Raised Platform - (55.79 SQM)	Not Applicable	Circulation or storage space.
B00E - R0017 - Movement - (6.82 SQM)	Not Applicable	Circulation or storage space.
B00E - R0018 - Movement - (12.93 SQM)	Not Applicable	Circulation or storage space.
B00E - R0019 - Movement - (17.25 SQM)	Not Applicable	Circulation or storage space.
OS 606 19180 - OS 606 19180 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	● Student Space (35)	