

VENTILATION AUDIT REPORT

SCHOOL:	South Sydney High School (8545)
AMU REGION:	Sydney
STATE ELECTORATE:	Maroubra
LOCAL GOVERNMENT AREA:	Randwick

8545 - South Sydney High School
Site Plan (12430)



Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - General Learning Space - (63.3 SQM) - Teaching Space: 1	● Student Space (29)	
B00A - R0002 - General Assistants - (16.16 SQM)	● Office (4)	
B00A - R0003 - Staff Study - (22.04 SQM)	● Office (5)	
B00A - R0006 - General Learning Space - (51.08 SQM) - Teaching Space: 1	● Student Space (23)	
B00A - R0007 - General Learning Space - (51.2 SQM) - Teaching Space: 1	● Student Space (23)	
B00A - R0009 - Movement - (46.42 SQM)	Not Applicable	Circulation or storage space.
B00A - R1001 - General Learning Space - (69.26 SQM) - Teaching Space: 1	● Student Space (32)	
B00A - R1002 - Movement - (18.2 SQM)	Not Applicable	Circulation or storage space.
B00A - R1003 - Music Learning Space - (83.4 SQM) - Teaching Space: 1	● Student Space (38)	
B00A - R1009 - Music Learning Space - (69.05 SQM) - Teaching Space: 1	● Student Space (32)	
B00A - R1010 - Movement - (24.93 SQM)	Not Applicable	Circulation or storage space.
B00B - R0001 - General Learning Space - (52.23 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R0002 - General Learning Space - (52.14 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R0003 - General Learning Space - (52.12 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R0006 - General Learning Space - (52.1 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R0007 - General Learning Space - (52.21 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R0008 - General Learning Space - (52.1 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R0009 - General Learning Space - (51.96 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R0010 - Movement - (170.88 SQM)	Not Applicable	Circulation or storage space.
B00B - R0011 - Movement - (29.57 SQM)	Not Applicable	Circulation or storage space.
B00B - R1004 - General Learning Space - (46.16 SQM) - Teaching Space: 1	● Student Space (21)	
B00B - R1007 - Staff Study - (44.02 SQM)	● Office (11)	
B00B - R1009 - Staff Study - (13.03 SQM)	● Office (3)	
B00B - R1010 - Computer Learning Space - (52.45 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R1011 - General Learning Space - (52.36 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R1012 - General Learning Space - (52.23 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R1013 - General Learning Space - (52.33 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R1014 - Movement - (121.77 SQM)	Not Applicable	Circulation or storage space.
B00B - R1015 - Movement - (34.68 SQM)	Not Applicable	Circulation or storage space.
B00B - R1016 - Movement - (28.81 SQM)	Not Applicable	Circulation or storage space.
B00C - R0001 - Movement - (145.77 SQM)	Not Applicable	Circulation or storage space.
B00C - R0002 - General Learning Space - (52.41 SQM) - Teaching Space: 1	● Student Space (24)	
B00C - R0003 - Staff Kitchen - (15.69 SQM)	● Office (3)	
B00C - R0004 - Commonroom - (89.32 SQM)	● Office (22)	
B00C - R0005 - Staff Study - (28.64 SQM)	● Office (7)	
B00C - R0012 - Clinic - Boys - (10.55 SQM)	● Office (2)	
B00C - R0013 - Leading Teacher - (11.33 SQM)	● Office (2)	
B00C - R0014 - Movement - (6.72 SQM)	Not Applicable	Circulation or storage space.
B00C - R0017 - General Learning Space - (60.38 SQM) - Teaching Space: 1	● Student Space (28)	
B00C - R0018 - General Learning Space - (60.63 SQM) - Teaching Space: 1	● Student Space (28)	
B00C - R0019 - General Learning Space - (60.62 SQM) - Teaching Space: 1	● Student Space (28)	
B00C - R0020 - General Learning Space - (60.62 SQM) - Teaching Space: 1	● Student Space (28)	
B00C - R0021 - Movement - (12.46 SQM)	Not Applicable	Circulation or storage space.
B00C - R1001 - Movement - (128.28 SQM)	Not Applicable	Circulation or storage space.
B00C - R1002 - Computer Learning Space - (52.44 SQM) - Teaching Space: 1	● Student Space (24)	
B00C - R1004 - General Learning Space - (58.32 SQM) - Teaching Space: 1	● Student Space (27)	
B00C - R1005 - Staff Study - (30.56 SQM)	● Office (7)	
B00C - R1006 - Staff Study - (28.72 SQM)	● Office (7)	
B00C - R1010 - Staff Study - (10.29 SQM)	● Office (2)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00C - R1013 - Staff Study - (15.51 SQM)	Office (3)	
B00C - R1016 - Interview/Office - Type 1 - (13.16 SQM)	Office (3)	
B00C - R1018 - Computer Learning Space - (114.62 SQM) - Teaching Space: 1	Student Space (53)	
B00C - R1021 - General Learning Space - (63.97 SQM) - Teaching Space: 1	Student Space (29)	
B00D - R0002 - Duplicating Workroom - (15.39 SQM)	Office (3)	
B00D - R0003 - Leading Teacher - (12.63 SQM)	Office (3)	
B00D - R0004 - Administration - Clerical - (13.03 SQM)	Office (3)	
B00D - R0005 - Principal Office - (27.53 SQM)	Office (6)	
B00D - R0012 - Administration - Clerical - (34.35 SQM)	Office (8)	
B00D - R0013 - Administration - Clerical - (26.94 SQM)	Office (6)	
B00D - R0014 - Clinic - Girls - (14.02 SQM)	Office (3)	
B00D - R0018 - Deputy Principal Office - (21.78 SQM)	Office (5)	
B00D - R0019 - Movement - (39.29 SQM)	Not Applicable	Circulation or storage space.
B00D - R0022 - Interview/Office - Type 1 - (13.36 SQM)	Office (3)	
B00D - R0023 - Movement - (22.33 SQM)	Not Applicable	Circulation or storage space.
B00D - R0026 - Movement - (10.76 SQM)	Not Applicable	Circulation or storage space.
B00D - R0027 - Public Reception - (80.46 SQM)	Not Applicable	Circulation or storage space.
B00D - R0031 - Movement - (88.82 SQM)	Not Applicable	Circulation or storage space.
B00D - R0032 - Movement - (44.67 SQM)	Not Applicable	Circulation or storage space.
B00E - R0007 - Multi-Purpose Space - (298.77 SQM)	Student Space (138)	
B00E - R0008 - General Assistants - (7.89 SQM)	Office (1)	
B00E - R0014 - Stage - (56.99 SQM)	Not Applicable	Circulation or storage space.
B00F - R0001 - General Learning Space - (61.94 SQM) - Teaching Space: 1	Student Space (28)	
B00F - R0003 - General Learning Space - (52.12 SQM) - Teaching Space: 1	Student Space (24)	
B00F - R0004 - General Learning Space - (50.94 SQM) - Teaching Space: 1	Student Space (23)	
B00F - R0011 - Movement - (17.01 SQM)	Not Applicable	Circulation or storage space.
B00F - R0014 - Movement - (19.5 SQM)	Not Applicable	Circulation or storage space.
B00F - R0015 - Movement - (10.86 SQM)	Not Applicable	Circulation or storage space.
B00F - R0016 - Laboratory L.S. - (83.68 SQM) - Teaching Space: 1	Student Space (38)	
B00F - R0017 - Preparation - (25.04 SQM)	Not Applicable	Circulation or storage space.
B00F - R0019 - Laboratory L.S. - (79.53 SQM) - Teaching Space: 1	Student Space (36)	
B00F - R0025 - Movement - (203.1 SQM)	Not Applicable	Circulation or storage space.
B00F - R0027 - Movement - (101.19 SQM)	Not Applicable	Circulation or storage space.
B00F - R0028 - Laboratory L.S. - (75.99 SQM) - Teaching Space: 1	Student Space (35)	
B00F - R1001 - Staff Study - (52.91 SQM)	Office (13)	
B00F - R1002 - General Learning Space - (50.88 SQM) - Teaching Space: 1	Student Space (23)	
B00F - R1003 - General Learning Space - (50.04 SQM) - Teaching Space: 1	Student Space (23)	
B00F - R1004 - General Learning Space - (49.21 SQM) - Teaching Space: 1	Student Space (22)	
B00F - R1005 - General Learning Space - (34.26 SQM) - Teaching Space: 1	Student Space (15)	
B00F - R1006 - General Learning Space - (50.19 SQM) - Teaching Space: 1	Student Space (23)	
B00F - R1009 - Staff Study - (17.69 SQM)	Office (4)	
B00F - R1010 - General Learning Space - (58.6 SQM) - Teaching Space: 1	Student Space (27)	
B00F - R1013 - General Learning Space - (50.04 SQM) - Teaching Space: 1	Student Space (23)	
B00F - R1014 - Interview/Office - Type 1 - (25.54 SQM)	Office (6)	
B00F - R1015 - General Learning Space - (74.53 SQM) - Teaching Space: 1	Student Space (34)	
B00F - R1024 - Movement - (243.81 SQM)	Not Applicable	Circulation or storage space.
B00G - R0002 - Staff Study - (22.1 SQM)	Office (5)	
B00G - R0004 - Art Learning Space - (80.68 SQM) - Teaching Space: 1	Student Space (37)	
B00G - R0006 - Art Learning Space - (58.4 SQM) - Teaching Space: 1	Student Space (27)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00G - R0007 - Art Learning Space - (57.61 SQM) - Teaching Space: 1	● Student Space (26)	
B00G - R0008 - Movement - (39.02 SQM)	Not Applicable	Circulation or storage space.
B00H - R0001 - Materials Technology L.S. - (129.46 SQM) - Teaching Space: 1	● Student Space (60)	
B00H - R0002 - Welding Area - (9.09 SQM)	Not Applicable	Circulation or storage space.
B00H - R0004 - Materials Technology L.S. - (103.74 SQM) - Teaching Space: 1	● Student Space (48)	
B00H - R0008 - Staff Study - (21.88 SQM)	● Office (5)	
B00H - R0012 - Design L.S. - (50.04 SQM) - Teaching Space: 1	● Student Space (23)	
B00H - R0013 - Staff Study - (26.63 SQM)	● Office (6)	
B00H - R0016 - Design L.S. - (51.06 SQM) - Teaching Space: 1	● Student Space (23)	
B00H - R0017 - Art Learning Space - (50.04 SQM) - Teaching Space: 1	● Student Space (23)	
B00H - R0021 - Materials Technology L.S. - (103.31 SQM) - Teaching Space: 1	● Student Space (47)	
B00H - R0024 - Materials Technology L.S. - (129.52 SQM) - Teaching Space: 1	● Student Space (60)	
B00H - R0025 - Movement - (130.47 SQM)	Not Applicable	Circulation or storage space.
B00H - R0026 - Movement - (117.49 SQM)	Not Applicable	Circulation or storage space.
B00J - R0004 - Staff Study - (19.84 SQM)	● Office (4)	
B00J - R0005 - Movement - (15.88 SQM)	Not Applicable	Circulation or storage space.
B00J - R0006 - Design L.S. - (64.85 SQM) - Teaching Space: 1	● Student Space (30)	
B00J - R0010 - Design L.S. - (74.82 SQM) - Teaching Space: 1	● Student Space (34)	
B00J - R0011 - Food Technology L.S. - (102.83 SQM) - Teaching Space: 1	● Student Space (47)	
B00J - R0014 - Food/Research Space - (10.83 SQM)	Not Applicable	Circulation or storage space.
B00J - R0016 - Food Technology L.S. - (97.91 SQM) - Teaching Space: 1	● Student Space (45)	
B00J - R0021 - Movement - (21.52 SQM)	Not Applicable	Circulation or storage space.
B00J - R0024 - Movement - (95.24 SQM)	Not Applicable	Circulation or storage space.
B00J - R0025 - Movement - (215.72 SQM)	Not Applicable	Circulation or storage space.
B00J - R0026 - Staff Study - (47.83 SQM)	● Office (11)	
B00K - R0001 - Multi-Purpose Space - (463.59 SQM)	● Student Space (215)	
B00K - R0002 - Movement - (61.4 SQM)	Not Applicable	Circulation or storage space.
B00K - R0007 - Movement - (18.37 SQM)	Not Applicable	Circulation or storage space.
B00K - R0012 - Movement - (9.99 SQM)	Not Applicable	Circulation or storage space.
B00K - R0016 - Movement - (41.05 SQM)	Not Applicable	Circulation or storage space.
B00K - R0017 - Movement - (208.04 SQM)	Not Applicable	Circulation or storage space.
B00L - M1001 - Study Space - (36.45 SQM)	Not Applicable	Circulation or storage space.
B00L - M1002 - Movement - (41.45 SQM)	Not Applicable	Circulation or storage space.
B00L - R0001 - Laboratory L.S. - (93.07 SQM) - Teaching Space: 1	● Student Space (43)	
B00L - R0002 - Preparation - (36.71 SQM)	Not Applicable	Circulation or storage space.
B00L - R0003 - Movement - (73.24 SQM)	Not Applicable	Circulation or storage space.
B00L - R0006 - Staff Study - (28.81 SQM)	● Office (7)	
B00L - R0007 - Laboratory L.S. - (92.22 SQM) - Teaching Space: 1	● Student Space (42)	
B00L - R0008 - Preparation - (54.93 SQM)	Not Applicable	Circulation or storage space.
B00L - R0009 - Laboratory L.S. - (93.86 SQM) - Teaching Space: 1	● Student Space (43)	
B00L - R0010 - Movement - (25.81 SQM)	Not Applicable	Circulation or storage space.
B00L - R1001 - Main Area - (302.96 SQM)	Not Applicable	Circulation or storage space.
B00L - R1002 - Seminar - (34.29 SQM)	● Office (8)	
B00L - R1003 - Audio Visual Workroom - (44.54 SQM)	● Student Space (20)	
B00L - R1005 - Tiered Learning Area - (25.86 SQM)	● Student Space (11)	
B00L - R1006 - Seminar - (10.23 SQM)	● Office (2)	
B00L - R1007 - Seminar - (10.61 SQM)	● Office (2)	
B00L - R1008 - Workroom - (37.38 SQM)	● Office (9)	
B00L - R1010 - Senior Study - (67.23 SQM)	● Office (16)	
B00M - R0001 - Student Canteen - (60.15 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00M - R0004 - Movement - (82.82 SQM)	Not Applicable	Circulation or storage space.