


VENTILATION AUDIT REPORT

| | |
|-------------------------------|-------------------------------------|
| SCHOOL: | Southern Cross School (4428) |
| AMU REGION: | North Coast |
| STATE ELECTORATE: | Ballina |
| LOCAL GOVERNMENT AREA: | Ballina |

4428 - Southern Cross Public School
Site Plan (14724)



1:906

Printed: 19-Aug-2021

Ventilation Audit Key

| Category | Description |
|---|--|
|  | Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings. |
|  | Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces. |

| Entity Location | Audit Condition Classification (Capacity) | Comment |
|--|---|-------------------------------|
| B001 - R0003 - Movement - (157.45 SQM) | Not Applicable | Circulation or storage space. |
| B001 - R0005 - Home Base - (59.33 SQM) - Teaching Space: 1 | ● Student Space (27) | |
| B001 - R0006 - Practical Activities - 1hb - (16.35 SQM) | ● Student Space (7) | |
| B001 - R0007 - Withdrawal Space - 1hb - (12.4 SQM) | ● Student Space (5) | |
| B001 - R0008 - Home Base - (59.33 SQM) - Teaching Space: 1 | ● Student Space (27) | |
| B001 - R0009 - Practical Activities - 1hb - (16.78 SQM) | ● Student Space (7) | |
| B001 - R0012 - Home Base - (59.42 SQM) - Teaching Space: 1 | ● Student Space (27) | |
| B001 - R0013 - Practical Activities - 1hb - (16.71 SQM) | ● Student Space (7) | |
| B001 - R0014 - Withdrawal Space - 1hb - (12.43 SQM) | ● Student Space (5) | |
| B001 - R0015 - Home Base - (59.8 SQM) - Teaching Space: 1 | ● Student Space (27) | |
| B001 - R0016 - Practical Activities - 1hb - (16.4 SQM) | ● Student Space (7) | |
| B001 - R1001 - Movement - (112.57 SQM) | Not Applicable | Circulation or storage space. |
| B001 - R1004 - Home Base - (59.63 SQM) - Teaching Space: 1 | ● Student Space (27) | |
| B001 - R1005 - Practical Activities - 1hb - (18.5 SQM) | ● Student Space (8) | |
| B001 - R1006 - Withdrawal Space - 1hb - (12.35 SQM) | ● Student Space (5) | |
| B001 - R1007 - Home Base - (59.5 SQM) - Teaching Space: 1 | ● Student Space (27) | |
| B001 - R1008 - Practical Activities - 1hb - (16.68 SQM) | ● Student Space (7) | |
| B001 - R1011 - Home Base - (59.33 SQM) - Teaching Space: 1 | ● Student Space (27) | |
| B001 - R1012 - Practical Activities - 1hb - (16.76 SQM) | ● Student Space (7) | |
| B001 - R1013 - Withdrawal Space - 1hb - (12.3 SQM) | ● Student Space (5) | |
| B001 - R1014 - Home Base - (59.49 SQM) - Teaching Space: 1 | ● Student Space (27) | |
| B001 - R1015 - Practical Activities - 1hb - (18.45 SQM) | ● Student Space (8) | |
| B002 - R0007 - Home Base - (59.57 SQM) - Teaching Space: 1 | ● Student Space (27) | |
| B002 - R0008 - Practical Activities - 1hb - (16.38 SQM) | ● Student Space (7) | |
| B002 - R0009 - Withdrawal Space - 1hb - (12.26 SQM) | ● Student Space (5) | |
| B002 - R0010 - Home Base - (59.49 SQM) - Teaching Space: 1 | ● Student Space (27) | |
| B002 - R0011 - Practical Activities - 1hb - (16.43 SQM) | ● Student Space (7) | |
| B002 - R0013 - Movement - (114.66 SQM) | Not Applicable | Circulation or storage space. |
| B003 - R0003 - Home Base - (58.68 SQM) - Teaching Space: 1 | ● Student Space (27) | |
| B003 - R0004 - Practical Activities - 1hb - (16.28 SQM) | ● Student Space (7) | |
| B003 - R0005 - Withdrawal Space - 1hb - (12.81 SQM) | ● Student Space (5) | |
| B003 - R0006 - Home Base - (58.32 SQM) - Teaching Space: 1 | ● Student Space (27) | |
| B003 - R0007 - Practical Activities - 1hb - (16.25 SQM) | ● Student Space (7) | |
| B003 - R0010 - Home Base - (58.31 SQM) - Teaching Space: 1 | ● Student Space (27) | |
| B003 - R0011 - Practical Activities - 1hb - (16.24 SQM) | ● Student Space (7) | |
| B003 - R0012 - Withdrawal Space - 1hb - (12.7 SQM) | ● Student Space (5) | |
| B003 - R0013 - Home Base - (58.31 SQM) - Teaching Space: 1 | ● Student Space (27) | |
| B003 - R0014 - Practical Activities - 1hb - (16.21 SQM) | ● Student Space (7) | |
| B003 - R0017 - Movement - (145.61 SQM) | Not Applicable | Circulation or storage space. |
| B004 - R0001 - Movement - (149.69 SQM) | Not Applicable | Circulation or storage space. |
| B004 - R0008 - Special Programs Room - (42.42 SQM) | ● Student Space (19) | |
| B004 - R0025 - Movement - (14.5 SQM) | Not Applicable | Circulation or storage space. |
| B004 - R0026 - Clerical Office - (11.58 SQM) | ● Office (2) | |
| B004 - R0027 - Clerical Office - (100.46 SQM) | ● Office (25) | |
| B004 - R0028 - Clerical Office - (84.51 SQM) | ● Office (21) | |
| B004 - R0029 - Special Programs Room - (56.84 SQM) | ● Student Space (26) | |
| B004 - R0030 - Special Programs Room - (39.89 SQM) | ● Student Space (18) | |

| Entity Location | Audit Condition Classification (Capacity) | Comment |
|--|---|-------------------------------|
| B004 - R0031 - Staff Room - (45.41 SQM) | Office (11) | |
| B005 - R0010 - Staff Room Annexe - (12.27 SQM) | Office (3) | |
| B005 - R0011 - Staff Room Annexe - (18.95 SQM) | Office (4) | |
| B005 - R0012 - Staff Room Annexe - (12.74 SQM) | Office (3) | |
| B005 - R0013 - Staff Room Annexe - (12.53 SQM) | Office (3) | |
| B005 - R0015 - Clerical Office/Workroom - (32.27 SQM) | Office (8) | |
| B005 - R0018 - Interview - (9.19 SQM) | Office (2) | |
| B005 - R0019 - Clerical Office - (18.96 SQM) | Office (4) | |
| B005 - R0020 - Principal - (10.45 SQM) | Office (2) | |
| B005 - R0023 - Movement - (50.07 SQM) | Not Applicable | Circulation or storage space. |
| B005 - R0024 - Movement - (42.12 SQM) | Not Applicable | Circulation or storage space. |
| B006 - R0001 - Movement - (102.99 SQM) | Not Applicable | Circulation or storage space. |
| B006 - R0007 - Withdrawal Space - 1hb - (8.82 SQM) | Student Space (4) | |
| B006 - R0008 - Home Base - S - (49.43 SQM) - Teaching Space: 1 | Student Space (22) | |
| B006 - R0009 - Practical Activities - S - 1hb - (12.99 SQM) | Student Space (6) | |
| B006 - R0013 - Practical Activities - S - 1hb - (55.81 SQM) | Student Space (25) | |
| B006 - R0014 - Home Base - M - (49.36 SQM) - Teaching Space: 1 | Student Space (22) | |
| B006 - R0015 - Practical Activities - M - 1hb - (13.05 SQM) | Student Space (6) | |
| B006 - R0017 - Staff Room Annexe - (8.37 SQM) | Office (2) | |
| B006 - R0019 - Home Base - M - (62.91 SQM) - Teaching Space: 1 | Student Space (29) | |
| B006 - R0020 - Practical Activities - M - 1hb - (20.72 SQM) | Student Space (9) | |
| B006 - R0021 - Withdrawal - M - (6.28 SQM) | Student Space (2) | |
| B007 - R0003 - Canteen - (44.12 SQM) | Not Applicable | Circulation or storage space. |
| B009 - M0001 - Gymnasium - (142.56 SQM) | Student Space (66) | |
| B009 - R0001 - Movement - (29.38 SQM) | Not Applicable | Circulation or storage space. |
| B009 - R0002 - Movement - (28.47 SQM) | Not Applicable | Circulation or storage space. |
| B009 - R0008 - Movement - (11.03 SQM) | Not Applicable | Circulation or storage space. |
| B009 - R0010 - Gymnasium - (670.2 SQM) | Student Space (310) | |
| B009 - R0011 - Clerical Office - (11.64 SQM) | Office (2) | |
| B009 - R0016 - Movement - (35.09 SQM) | Not Applicable | Circulation or storage space. |
| B009 - R0017 - Multi-Purpose Space - (100.08 SQM) | Student Space (46) | |
| B009 - R0018 - Multi-Purpose Space - (100.35 SQM) | Student Space (46) | |
| B009 - R0019 - Movement - (35.03 SQM) | Not Applicable | Circulation or storage space. |
| B009 - R0021 - Movement - (15.04 SQM) | Not Applicable | Circulation or storage space. |
| B009 - R0022 - Movement - (15.04 SQM) | Not Applicable | Circulation or storage space. |
| B00A - R0002 - Entry Vestibule - (14.92 SQM) | Not Applicable | Circulation or storage space. |
| B00A - R0004 - Movement - (72.34 SQM) | Not Applicable | Circulation or storage space. |
| B00A - R0009 - Entry Vestibule - (24.85 SQM) | Not Applicable | Circulation or storage space. |
| B00A - R0030 - Special Programs Room - (70.82 SQM) | Student Space (32) | |
| B00A - R0033 - Staff Room - (23.13 SQM) | Office (5) | |
| B00A - R0036 - Movement - (5.22 SQM) | Not Applicable | Circulation or storage space. |
| B00A - R0037 - Movement - (324.95 SQM) | Not Applicable | Circulation or storage space. |
| B00A - R1001 - Seminar/Study - (12.98 SQM) | Office (3) | |
| B00A - R1002 - Seminar/Study - (13.36 SQM) | Office (3) | |
| B00A - R1003 - Seminar/Study - (50.92 SQM) | Office (12) | |
| B00A - R1004 - Movement - (230.25 SQM) | Not Applicable | Circulation or storage space. |
| B00A - R1005 - Interview - (12.41 SQM) | Office (3) | |
| B00A - R1007 - Home Base - (47.93 SQM) - Teaching Space: 1 | Student Space (22) | |

| Entity Location | Audit Condition Classification (Capacity) | Comment |
|---|---|-------------------------------|
| B00A - R1009 - Home Base - (47.21 SQM) - Teaching Space: 1 | Student Space (21) | |
| B00A - R1010 - Seminar/Study - (14.41 SQM) | Office (3) | |
| B00A - R1012 - Home Base - (47.28 SQM) - Teaching Space: 1 | Student Space (21) | |
| B00A - R1013 - Home Base - (48.08 SQM) - Teaching Space: 1 | Student Space (22) | |
| B00A - R1015 - Home Base - (47.95 SQM) - Teaching Space: 1 | Student Space (22) | |
| B00A - R1016 - Home Base - (48.02 SQM) - Teaching Space: 1 | Student Space (22) | |
| B00A - R1017 - Seminar/Study - (17.35 SQM) | Office (4) | |
| B00A - R1018 - Home Base - (48.01 SQM) - Teaching Space: 1 | Student Space (22) | |
| B00A - R1020 - Computer Room - (62.09 SQM) | Student Space (28) | |
| B00A - R1021 - Staff Room - (16.72 SQM) | Office (4) | |
| B00A - R1022 - Seminar/Study - (14.41 SQM) | Office (3) | |
| B00D - R0001 - Movement - (14.32 SQM) | Not Applicable | Circulation or storage space. |
| B00D - R0003 - Raised Platform - (33.05 SQM) | Not Applicable | Circulation or storage space. |
| B00D - R0005 - Special Programs Room - (124.89 SQM) | Student Space (57) | |
| B00D - R0015 - Movement - (81.2 SQM) | Not Applicable | Circulation or storage space. |
| B00J - R0001 - Art Learning Space - (52.44 SQM) - Teaching Space: 1 | Student Space (24) | |
| B00J - R0002 - Movement - (128.45 SQM) | Not Applicable | Circulation or storage space. |
| B00J - R0003 - Staff Room Annexe - (31.97 SQM) | Office (7) | |
| B00J - R0005 - Darkroom Space - (29.09 SQM) | Office (7) | |
| B00J - R0007 - Interview - (13.19 SQM) | Office (3) | |
| B00J - R0010 - Art Learning Space - (61.52 SQM) - Teaching Space: 1 | Student Space (28) | |
| B00J - R0011 - Workshop - (52.41 SQM) | Student Space (24) | |
| B00J - R0013 - Art Learning Space - (61.45 SQM) - Teaching Space: 1 | Student Space (28) | |
| B00K - R0002 - Commonroom - (146 SQM) | Office (36) | |
| B00K - R0003 - Interview - (11.89 SQM) | Office (2) | |
| B00M - R0001 - Practice/Seminar - (15.68 SQM) | Not Applicable | Circulation or storage space. |
| B00O - R0001 - Movement - (17.72 SQM) | Not Applicable | Circulation or storage space. |
| B00O - R0002 - Art Learning Space - (60.1 SQM) - Teaching Space: 1 | Student Space (27) | |
| B00P - R0001 - Movement - (179.17 SQM) | Not Applicable | Circulation or storage space. |
| B00P - R0007 - Movement - (11.88 SQM) | Not Applicable | Circulation or storage space. |
| B00P - R0008 - Staff Study - (23.19 SQM) | Office (5) | |
| B00P - R0009 - Duplicating Workroom - (12.98 SQM) | Office (3) | |
| B00P - R0010 - Special Programs Room - (29.18 SQM) | Student Space (13) | |
| B00P - R0011 - Staff Room Annexe - (54.44 SQM) | Office (13) | |
| B00P - R0012 - General Learning Space - (47.58 SQM) - Teaching Space: 1 | Student Space (22) | |
| B00P - R0013 - General Learning Space - (47.44 SQM) - Teaching Space: 1 | Student Space (22) | |
| B00P - R0014 - General Learning Space - (47.67 SQM) - Teaching Space: 1 | Student Space (22) | |
| B00P - R0015 - General Learning Space - (47.73 SQM) - Teaching Space: 1 | Student Space (22) | |
| B00P - R0016 - General Learning Space - (47.66 SQM) - Teaching Space: 1 | Student Space (22) | |
| B00P - R0017 - General Learning Space - (47.64 SQM) - Teaching Space: 1 | Student Space (22) | |
| B00Q - R0002 - Practice/Seminar - (26 SQM) | Not Applicable | Circulation or storage space. |
| B00Q - R0003 - Music Learning Space - (62.64 SQM) - Teaching Space: 1 | Student Space (29) | |
| B00Q - R0006 - Music Learning Space - (81.19 SQM) - Teaching Space: 1 | Student Space (37) | |
| B00Q - R0007 - Movement - (67 SQM) | Not Applicable | Circulation or storage space. |
| B00Q - R0008 - Multi Media Studio - (12.11 SQM) | Not Applicable | Circulation or storage space. |
| B00Q - R0009 - Multi Media Studio - (15.15 SQM) | Not Applicable | Circulation or storage space. |
| B00S - R0001 - Materials Technology L.S. - (177.76 SQM) - Teaching Space: 1 | Student Space (82) | |
| B010 - R0003 - Stage - (49.82 SQM) | Not Applicable | Circulation or storage space. |

| Entity Location | Audit Condition Classification (Capacity) | Comment |
|--|---|-------------------------------|
| B010 - R0006 - Communal Space - (195.51 SQM) | ● Student Space (90) | |
| B010 - R0009 - Movement - (129.93 SQM) | Not Applicable | Circulation or storage space. |
| B013 - R0011 - Reading Area - (169.24 SQM) | ● Student Space (78) | |
| B013 - R0013 - Special Programs Room - (51.26 SQM) | ● Student Space (23) | |