

VENTILATION AUDIT REPORT

SCHOOL:	Southern Cross School of Distance Education (4659)
AMU REGION:	North Coast
STATE ELECTORATE:	Ballina
LOCAL GOVERNMENT AREA:	Ballina

4659 - Southern Cross School of Distance Education
Site Plan (10163)



1:2,227

Printed: 19-Aug-2021

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B009 - M0001 - Special Programs Room - (142.56 SQM)	● Student Space (66)	
B009 - R0001 - Movement - (29.38 SQM)	Not Applicable	Circulation or storage space.
B009 - R0002 - Movement - (28.47 SQM)	Not Applicable	Circulation or storage space.
B009 - R0008 - Movement - (11.03 SQM)	Not Applicable	Circulation or storage space.
B009 - R0010 - Special Programs Room - (670.2 SQM)	● Student Space (310)	
B009 - R0011 - Clerical Office - (11.64 SQM)	● Office (2)	
B009 - R0016 - Movement - (35.09 SQM)	Not Applicable	Circulation or storage space.
B009 - R0017 - Special Programs Room - (100.08 SQM)	● Student Space (46)	
B009 - R0018 - Special Programs Room - (100.35 SQM)	● Student Space (46)	
B009 - R0019 - Movement - (35.03 SQM)	Not Applicable	Circulation or storage space.
B009 - R0021 - Movement - (15.04 SQM)	Not Applicable	Circulation or storage space.
B009 - R0022 - Movement - (15.04 SQM)	Not Applicable	Circulation or storage space.
B00A - R0002 - Entry Vestibule - (14.92 SQM)	Not Applicable	Circulation or storage space.
B00A - R0003 - Principal - (26.8 SQM)	● Office (6)	
B00A - R0004 - Movement - (72.34 SQM)	Not Applicable	Circulation or storage space.
B00A - R0005 - Clerical Office - (54.72 SQM)	● Office (13)	
B00A - R0006 - Principal - (17.73 SQM)	● Office (4)	
B00A - R0007 - Interview - (12.06 SQM)	● Office (3)	
B00A - R0008 - Staff Room - (17.69 SQM)	● Office (4)	
B00A - R0009 - Entry Vestibule - (24.85 SQM)	Not Applicable	Circulation or storage space.
B00A - R0010 - Deputy Principal - (16.33 SQM)	● Office (4)	
B00A - R0011 - Deputy Principal - (12.02 SQM)	● Office (3)	
B00A - R0012 - Interview - (13.09 SQM)	● Office (3)	
B00A - R0013 - Sick Bay - (13.95 SQM)	● Student Space (6)	
B00A - R0016 - Sick Bay - (13.95 SQM)	● Student Space (6)	
B00A - R0017 - Interview - (13.09 SQM)	● Office (3)	
B00A - R0023 - Duplicating Workroom - (48.13 SQM)	● Office (12)	
B00A - R0025 - Special Programs Room - (70.82 SQM)	● Student Space (32)	
B00A - R0026 - Practical Activities - (52.7 SQM)	● Student Space (24)	
B00A - R0036 - Movement - (5.22 SQM)	Not Applicable	Circulation or storage space.
B00A - R0037 - Movement - (324.95 SQM)	Not Applicable	Circulation or storage space.
B00B - R0003 - Canteen - (54.01 SQM)	Not Applicable	Circulation or storage space.
B00B - R0009 - Home Base - (47.71 SQM) - Teaching Space: 1	● Student Space (22)	
B00B - R0011 - Home Base - (47.98 SQM) - Teaching Space: 1	● Student Space (22)	
B00B - R0013 - Home Base - (47.88 SQM) - Teaching Space: 1	● Student Space (22)	
B00B - R0014 - Movement - (212.94 SQM)	Not Applicable	Circulation or storage space.
B00B - R0018 - Movement - (19.78 SQM)	Not Applicable	Circulation or storage space.
B00B - R1003 - Interview - (13 SQM)	● Office (3)	
B00B - R1006 - Staff Room - (82.74 SQM)	● Office (20)	
B00B - R1008 - Home Base - (52.54 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R1009 - Home Base - (52.47 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R1010 - Home Base - (47.94 SQM) - Teaching Space: 1	● Student Space (22)	
B00B - R1011 - Special Programs Room - (16.11 SQM)	● Student Space (7)	
B00B - R1014 - Movement - (135.89 SQM)	Not Applicable	Circulation or storage space.
B00C - R0001 - Movement - (77.68 SQM)	Not Applicable	Circulation or storage space.
B00C - R0002 - Home Base - (92.31 SQM) - Teaching Space: 1	● Student Space (42)	
B00C - R0005 - Special Programs Room - (64.81 SQM)	● Student Space (30)	
B00C - R0008 - Special Programs Room - (20.1 SQM)	● Student Space (9)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00C - R0009 - Special Programs Room - (92.61 SQM)	Student Space (42)	
B00C - R0010 - Staff Room - (39.08 SQM)	Office (9)	
B00C - R0011 - Special Programs Room - (92.31 SQM)	Student Space (42)	
B00C - R0013 - Staff Room - (16.45 SQM)	Office (4)	
B00C - R0018 - Movement - (117.56 SQM)	Not Applicable	Circulation or storage space.
B00C - R0019 - Special Programs Room - (92.4 SQM)	Student Space (42)	
B00C - R0020 - Special Programs Room - (92.4 SQM)	Student Space (42)	
B00C - R0021 - Movement - (5.35 SQM)	Not Applicable	Circulation or storage space.
B00C - R0022 - Movement - (5.43 SQM)	Not Applicable	Circulation or storage space.
B00D - R0001 - Movement - (14.32 SQM)	Not Applicable	Circulation or storage space.
B00D - R0003 - Raised Platform - (33.05 SQM)	Not Applicable	Circulation or storage space.
B00D - R0005 - Special Programs Room - (124.89 SQM)	Student Space (57)	
B00D - R0015 - Movement - (81.2 SQM)	Not Applicable	Circulation or storage space.
B00E - R0001 - Movement - (68.82 SQM)	Not Applicable	Circulation or storage space.
B00E - R0004 - Special Programs Room - (23.59 SQM)	Student Space (10)	
B00E - R0005 - Home Base - (48.07 SQM) - Teaching Space: 1	Student Space (22)	
B00E - R0006 - Home Base - (49.53 SQM) - Teaching Space: 1	Student Space (22)	
B00E - R0007 - Special Programs Room - (329.69 SQM)	Student Space (152)	
B00E - R0009 - Seminar/Study - (13.04 SQM)	Office (3)	
B00E - R0010 - Seminar/Study - (13.01 SQM)	Office (3)	
B00E - R0011 - Seminar/Study - (13.04 SQM)	Office (3)	
B00E - R0012 - Duplicating Workroom - (35.1 SQM)	Office (8)	
B00F - R0001 - Special Programs Room - (79.15 SQM)	Student Space (36)	
B00F - R0002 - Special Programs Room - (33.34 SQM)	Student Space (15)	
B00F - R0003 - Seminar/Study - (41.75 SQM)	Office (10)	
B00F - R0004 - Special Programs Room - (79.34 SQM)	Student Space (36)	
B00G - R0001 - Movement - (98.78 SQM)	Not Applicable	Circulation or storage space.
B00G - R0002 - Staff Room - (44.82 SQM)	Office (11)	
B00G - R0005 - Interview - (12.15 SQM)	Office (3)	
B00G - R0006 - Special Programs Room - (73.9 SQM)	Student Space (34)	
B00G - R0008 - Seminar/Study - (15.88 SQM)	Office (3)	
B00G - R0009 - Special Programs Room - (73.72 SQM)	Student Space (34)	
B00H - R0001 - Movement - (44.4 SQM)	Not Applicable	Circulation or storage space.
B00H - R0002 - Special Programs Room - (175.33 SQM)	Student Space (81)	
B00H - R0003 - Special Programs Room - (28.29 SQM)	Student Space (13)	
B00H - R0004 - Special Programs Room - (175.22 SQM)	Student Space (81)	
B00H - R0005 - Special Programs Room - (43.47 SQM)	Student Space (20)	
B00H - R0009 - Special Programs Room - (76.79 SQM)	Student Space (35)	
B00I - R0001 - Movement - (98.59 SQM)	Not Applicable	Circulation or storage space.
B00I - R0002 - Home Base - (65.71 SQM) - Teaching Space: 1	Student Space (30)	
B00I - R0003 - Home Base - (73.81 SQM) - Teaching Space: 1	Student Space (34)	
B00I - R0004 - Seminar/Study - (13.96 SQM)	Office (3)	
B00I - R0006 - Special Programs Room - (73.72 SQM)	Student Space (34)	
B00K - R0002 - Staff Room - (146 SQM)	Office (36)	
B00K - R0003 - Interview - (11.89 SQM)	Office (2)	
B00S - R0001 - Special Programs Room - (177.76 SQM)	Student Space (82)	
B010 - R0003 - Raised Platform - (49.82 SQM)	Not Applicable	Circulation or storage space.
B010 - R0006 - Communal Space - (195.51 SQM)	Student Space (90)	
B010 - R0009 - Movement - (129.93 SQM)	Not Applicable	Circulation or storage space.

