

VENTILATION AUDIT REPORT

SCHOOL:	St George Girls High School (8136)
AMU REGION:	Sydney
STATE ELECTORATE:	Kogarah
LOCAL GOVERNMENT AREA:	Georges River

8136 - St George Girls High School
Site Plan (12090)



1:1,194














Printed: 15-Jun-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - M0001 - Senior Study - (27.69 SQM)	Office (6)	
B00A - R0004 - General Learning Space - (49.49 SQM) - Teaching Space: 1	Student Space (22)	
B00A - R0005 - General Learning Space - (50.96 SQM) - Teaching Space: 1	Student Space (23)	
B00A - R0007 - General Learning Space - (44.27 SQM) - Teaching Space: 1	Student Space (20)	
B00A - R0009 - Movement - (6.65 SQM)	Not Applicable	Circulation or storage space.
B00A - R0010 - Principal Office - (20.6 SQM)	Office (5)	
B00A - R0013 - Interview/Office - Type 1 - (17.29 SQM)	Office (4)	
B00A - R0015 - Public Entry - (16.67 SQM)	Not Applicable	Circulation or storage space.
B00A - R0016 - Administration - Clerical - (28.13 SQM)	Office (7)	
B00A - R0017 - Administration - Clerical - (29.26 SQM)	Office (7)	
B00A - R0018 - Duplicating Workroom - (18.06 SQM)	Office (4)	
B00A - R0020 - Clinic - Girls - (17.26 SQM)	Office (4)	
B00A - R0021 - Staff Study - (17.6 SQM)	Office (4)	
B00A - R0022 - Movement - (5.73 SQM)	Not Applicable	Circulation or storage space.
B00A - R0024 - Staff Study - (66.74 SQM)	Office (16)	
B00A - R0025 - General Learning Space - (48.63 SQM) - Teaching Space: 1	Student Space (22)	
B00A - R0026 - General Learning Space - (48.56 SQM) - Teaching Space: 1	Student Space (22)	
B00A - R0027 - General Assistants - (11.81 SQM)	Office (2)	
B00A - R0028 - Computer Learning Space - (50.93 SQM) - Teaching Space: 1	Student Space (23)	
B00A - R0029 - Computer Learning Space - (61.17 SQM) - Teaching Space: 1	Student Space (28)	
B00A - R0032 - Movement - (270.85 SQM)	Not Applicable	Circulation or storage space.
B00A - R0034 - Movement - (6.17 SQM)	Not Applicable	Circulation or storage space.
B00A - R0035 - Duplicating Workroom - (15.33 SQM)	Office (3)	
B00A - R0036 - Leading Teacher - (10.43 SQM)	Office (2)	
B00A - R0037 - Administration - Clerical - (6.75 SQM)	Office (1)	
B00A - R0038 - Commonroom - (109.88 SQM)	Office (27)	
B00A - R0040 - Movement - (6.02 SQM)	Not Applicable	Circulation or storage space.
B00A - R0044 - Staff Study - (9.62 SQM)	Office (2)	
B00A - R0045 - Study Space - (36.59 SQM)	Not Applicable	Circulation or storage space.
B00A - R0048 - Senior Study - (46.78 SQM)	Office (11)	
B00A - R0049 - General Learning Space - (49.09 SQM) - Teaching Space: 1	Student Space (22)	
B00A - R0051 - Preparation - (24.54 SQM)	Not Applicable	Circulation or storage space.
B00A - R0053 - Laboratory L.S. - (91.98 SQM) - Teaching Space: 1	Student Space (42)	
B00A - R0054 - Ancillary Staff - (9.21 SQM)	Office (2)	
B00A - R0055 - Preparation - (24.13 SQM)	Not Applicable	Circulation or storage space.
B00A - R0056 - Laboratory L.S. - (96.69 SQM) - Teaching Space: 1	Student Space (44)	
B00A - R0057 - Movement - (50.15 SQM)	Not Applicable	Circulation or storage space.
B00A - R0062 - Deputy Principal Office - (15.14 SQM)	Office (3)	
B00A - R1001 - General Learning Space - (65.49 SQM) - Teaching Space: 1	Student Space (30)	
B00A - R1002 - Staff Study - (17.53 SQM)	Office (4)	
B00A - R1004 - General Learning Space - (52.19 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1006 - General Learning Space - (47.61 SQM) - Teaching Space: 1	Student Space (22)	
B00A - R1007 - General Learning Space - (47.72 SQM) - Teaching Space: 1	Student Space (22)	
B00A - R1009 - Study Space - (30.14 SQM)	Not Applicable	Circulation or storage space.
B00A - R1010 - Staff Study - (29.89 SQM)	Office (7)	
B00A - R1011 - General Learning Space - (51.56 SQM) - Teaching Space: 1	Student Space (23)	
B00A - R1012 - General Learning Space - (47.19 SQM) - Teaching Space: 1	Student Space (21)	
B00A - R1013 - Movement - (269.99 SQM)	Not Applicable	Circulation or storage space.
B00A - R1015 - General Learning Space - (56.83 SQM) - Teaching Space: 1	Student Space (26)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R1017 - General Learning Space - (49.72 SQM) - Teaching Space: 1	● Student Space (23)	
B00A - R1018 - General Learning Space - (50.33 SQM) - Teaching Space: 1	● Student Space (23)	
B00A - R1020 - Interview/Office - Type 1 - (16.87 SQM)	● Office (4)	
B00A - R1021 - Preparation - (16.82 SQM)	Not Applicable	Circulation or storage space.
B00A - R1022 - Laboratory L.S. - (83.85 SQM) - Teaching Space: 1	● Student Space (38)	
B00A - R1023 - General Learning Space - (51.7 SQM) - Teaching Space: 1	● Student Space (23)	
B00A - R1026 - General Learning Space - (52.27 SQM) - Teaching Space: 1	● Student Space (24)	
B00A - R1027 - General Learning Space - (52.27 SQM) - Teaching Space: 1	● Student Space (24)	
B00A - R1028 - Staff Study - (45.84 SQM)	● Office (11)	
B00A - R1032 - General Learning Space - (65.37 SQM) - Teaching Space: 1	● Student Space (30)	
B00A - R1033 - Movement - (43.16 SQM)	Not Applicable	Circulation or storage space.
B00A - R1035 - Movement - (6.27 SQM)	Not Applicable	Circulation or storage space.
B00A - R1043 - Movement - (10.98 SQM)	Not Applicable	Circulation or storage space.
B00B - M0004 - Movement - (6.25 SQM)	Not Applicable	Circulation or storage space.
B00B - R0001 - Multi-Purpose Space - (324.85 SQM)	● Student Space (150)	
B00B - R0003 - Movement - (17.01 SQM)	Not Applicable	Circulation or storage space.
B00B - R0007 - Staff Kitchen - (10.24 SQM)	● Office (2)	
B00B - R0008 - Public Entry - (44.41 SQM)	Not Applicable	Circulation or storage space.
B00B - R0012 - Movement - (57.53 SQM)	Not Applicable	Circulation or storage space.
B00B - R0013 - Food Technology L.S. - (119.3 SQM) - Teaching Space: 1	● Student Space (55)	
B00B - R0014 - Food/Research Space - (30.2 SQM)	Not Applicable	Circulation or storage space.
B00B - R0015 - Food Technology L.S. - (64.26 SQM) - Teaching Space: 1	● Student Space (29)	
B00B - R0017 - Movement - (30.79 SQM)	Not Applicable	Circulation or storage space.
B00B - R0018 - Staff Study - (17.47 SQM)	● Office (4)	
B00B - R0021 - Staff Study - (26.42 SQM)	● Office (6)	
B00B - R0024 - Multi-Purpose Space - (395.04 SQM)	● Student Space (183)	
B00B - R0025 - Stage - (111.41 SQM)	Not Applicable	Circulation or storage space.
B00B - R0028 - Staff Study - (12.52 SQM)	● Office (3)	
B00B - R0034 - Laboratory L.S. - (92.76 SQM) - Teaching Space: 1	● Student Space (43)	
B00B - R0035 - Preparation - (28.84 SQM)	Not Applicable	Circulation or storage space.
B00B - R0036 - Preparation - (9.68 SQM)	Not Applicable	Circulation or storage space.
B00B - R0037 - Laboratory L.S. - (90.79 SQM) - Teaching Space: 1	● Student Space (42)	
B00B - R0051 - Staff Study - (25.75 SQM)	● Office (6)	
B00B - R0059 - Student Canteen - (49.36 SQM)	Not Applicable	Circulation or storage space.
B00B - R1001 - Movement - (82.02 SQM)	Not Applicable	Circulation or storage space.
B00B - R1004 - General Learning Space - (50.07 SQM) - Teaching Space: 1	● Student Space (23)	
B00B - R1005 - General Learning Space - (52.56 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R1006 - General Learning Space - (52.56 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R1007 - General Learning Space - (52.12 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R1008 - Design L.S. - (68.85 SQM) - Teaching Space: 1	● Student Space (31)	
B00B - R1010 - Design L.S. - (64.1 SQM) - Teaching Space: 1	● Student Space (29)	
B00B - R1014 - Design L.S. - (52.56 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R1017 - Staff Study - (26.65 SQM)	● Office (6)	
B00B - R1018 - Music Learning Space - (65.24 SQM) - Teaching Space: 1	● Student Space (30)	
B00B - R1019 - Practice/Seminar - (25.78 SQM)	Not Applicable	Circulation or storage space.
B00B - R1020 - Practice/Seminar - (18.36 SQM)	Not Applicable	Circulation or storage space.
B00B - R1022 - Music Learning Space - (73.36 SQM) - Teaching Space: 1	● Student Space (34)	
B00B - R1028 - Preparation - (19.44 SQM)	Not Applicable	Circulation or storage space.
B00B - R1029 - Preparation - (7.73 SQM)	Not Applicable	Circulation or storage space.
B00B - R1030 - Laboratory L.S. - (86.72 SQM) - Teaching Space: 1	● Student Space (40)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00C - R0001 - Performance Workspace - (75.84 SQM) - Teaching Space: 1	 Student Space (35)	
B00D - R0001 - Workroom - (42.85 SQM)	 Office (10)	
B00D - R0002 - Public Entry - (14.62 SQM)	Not Applicable	Circulation or storage space.
B00D - R0006 - Main Area - (400.8 SQM)	Not Applicable	Circulation or storage space.
B00D - R0007 - Seminar - (12.11 SQM)	 Office (3)	
B00D - R0008 - Seminar - (12.25 SQM)	 Office (3)	
B00D - R0009 - Seminar - (12.11 SQM)	 Office (3)	
B00D - R0010 - Audio Visual Workroom - (41.98 SQM)	 Student Space (19)	
B00E - R0001 - Workshop - (67.7 SQM)	 Student Space (31)	
B00E - R0003 - Movement - (29.09 SQM)	Not Applicable	Circulation or storage space.
B00F - R0001 - Staff Study - (22.47 SQM)	 Office (5)	
B00F - R0004 - Art Learning Space - (62.89 SQM) - Teaching Space: 1	 Student Space (29)	
B00F - R0005 - Movement - (9.22 SQM)	Not Applicable	Circulation or storage space.
B00F - R0006 - Art Learning Space - (54.68 SQM) - Teaching Space: 1	 Student Space (25)	
B00H - R0001 - Gymnasium - (623.23 SQM)	 Student Space (289)	
NS 200 12290 - NS 200 12290 - Art Learning Space/Workshop/Bulk Store - (95 SQM)	Not Applicable	Circulation or storage space.
NS 200 16321 - NS 200 16321 - Art Learning Space/Workshop/Bulk Store - (95 SQM)	Not Applicable	Circulation or storage space.
OS 601 10018 - OS 601 10018 - Learning Unit - Standard/Withdrawal - (76 SQM)	 Student Space (35)	
OS 601 11455 - OS 601 11455 - Learning Unit - Standard/Withdrawal - (76 SQM)	 Student Space (35)	