

VENTILATION AUDIT REPORT

SCHOOL:	St Ives North Public School (4293)
AMU REGION:	Northern Sydney
STATE ELECTORATE:	Davidson
LOCAL GOVERNMENT AREA:	Ku-Ring-Gai

4293 - St Ives North Public School
Site Plan (11121)



1.930

Printed: 30-Sep-2021



























Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Home Base - (57.3 SQM)	● Student Space (26)	
B00A - R0006 - Home Base - (57.3 SQM)	● Student Space (26)	
B00B - R0004 - Home Base - (57.98 SQM) - Teaching Space: 1	● Student Space (26)	
B00B - R0008 - Home Base - (56.23 SQM) - Teaching Space: 1	● Student Space (26)	
B00B - R0009 - Home Base - (57.02 SQM) - Teaching Space: 1	● Student Space (26)	
B00B - R0011 - Movement - (14.27 SQM)	Not Applicable	Circulation or storage space.
B00B - R0013 - Home Base - (57.5 SQM) - Teaching Space: 1	● Student Space (26)	
B00B - R0017 - Staff Room Annexe - (31.23 SQM)	● Office (7)	
B00B - R0020 - Movement - (13.63 SQM)	Not Applicable	Circulation or storage space.
B00B - R0023 - Movement - (12.15 SQM)	Not Applicable	Circulation or storage space.
B00B - R1002 - Movement - (9.53 SQM)	Not Applicable	Circulation or storage space.
B00B - R1003 - Home Base - (57.98 SQM) - Teaching Space: 1	● Student Space (26)	
B00B - R1007 - Home Base - (57.03 SQM) - Teaching Space: 1	● Student Space (26)	
B00B - R1008 - Home Base - (56.86 SQM) - Teaching Space: 1	● Student Space (26)	
B00B - R1012 - Home Base - (57.98 SQM) - Teaching Space: 1	● Student Space (26)	
B00B - R1013 - Movement - (12.17 SQM)	Not Applicable	Circulation or storage space.
B00B - R1014 - Staff Room Annexe - (21.52 SQM)	● Office (5)	
B00B - R9001 - Movement - (101.2 SQM)	Not Applicable	Circulation or storage space.
B00B - R9002 - Movement - (29.54 SQM)	Not Applicable	Circulation or storage space.
B00B - R9005 - Movement - (12.53 SQM)	Not Applicable	Circulation or storage space.
B00C - R0002 - Staff Room Annexe - (17.53 SQM)	● Office (4)	
B00C - R0004 - Deputy Principal - (16.08 SQM)	● Office (4)	
B00C - R0007 - Movement - (19.7 SQM)	Not Applicable	Circulation or storage space.
B00C - R0008 - Home Base - (56.61 SQM) - Teaching Space: 1	● Student Space (26)	
B00C - R0010 - Movement - (6.48 SQM)	Not Applicable	Circulation or storage space.
B00C - R0013 - Home Base - (57.31 SQM) - Teaching Space: 1	● Student Space (26)	
B00C - R0014 - Home Base - (57 SQM) - Teaching Space: 1	● Student Space (26)	
B00C - R0016 - Movement - (6.39 SQM)	Not Applicable	Circulation or storage space.
B00C - R0020 - Home Base - (57.08 SQM) - Teaching Space: 1	● Student Space (26)	
B00C - R0021 - Staff Room - (30.01 SQM)	● Office (7)	
B00C - R0022 - Staff Kitchen - (8.8 SQM)	● Office (2)	
B00C - R0024 - Movement - (18.28 SQM)	Not Applicable	Circulation or storage space.
B00D - R0006 - Home Base - (84.9 SQM)	● Student Space (39)	
B00D - R0007 - Movement - (68.38 SQM)	Not Applicable	Circulation or storage space.
B00D - R0008 - Home Base - (55.84 SQM)	● Student Space (25)	
B00D - R0010 - Special Programs Room - (21.41 SQM)	● Student Space (9)	
B00D - R0012 - Movement - (6.04 SQM)	Not Applicable	Circulation or storage space.
B00D - R0014 - Home Base - (84.19 SQM) - Teaching Space: 1	● Student Space (39)	
B00D - R0015 - Home Base - (72.86 SQM) - Teaching Space: 1	● Student Space (33)	
B00D - R0016 - Practical Activities - (8.85 SQM)	● Student Space (4)	
B00E - R0006 - Home Base - (85.94 SQM)	● Student Space (39)	
B00E - R0007 - Home Base - (70.02 SQM)	● Student Space (32)	
B00F - R0001 - Staff Room - (57.07 SQM)	● Office (14)	
B00F - R0004 - Duplicating Workroom - (21.29 SQM)	● Office (5)	
B00F - R0007 - Principal - (17.66 SQM)	● Office (4)	
B00F - R0008 - Movement - (16.66 SQM)	Not Applicable	Circulation or storage space.
B00F - R0010 - Entry Vestibule - (24.98 SQM)	Not Applicable	Circulation or storage space.
B00F - R0018 - Movement - (11.5 SQM)	Not Applicable	Circulation or storage space.
B00F - R0024 - Movement - (6.25 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00F - R0028 - Special Programs Room - (56.83 SQM)	● Student Space (26)	
B00F - R0031 - Staff Room Annexe - (16.09 SQM)	● Office (4)	
B00F - R0033 - Movement - (9.36 SQM)	Not Applicable	Circulation or storage space.
B00F - R0035 - Clerical Office - (22.83 SQM)	● Office (5)	
B00F - R0037 - Home Base - (51.81 SQM)	● Student Space (24)	
B00F - R0038 - Withdrawal Space - 1hb - (8.22 SQM)	● Student Space (3)	
B00F - R0040 - Deputy Principal - (18.73 SQM)	● Office (4)	
B00F - R0045 - Practical Activities - 1hb - (5.08 SQM)	● Student Space (2)	
B00F - R0046 - Home Base - (52.18 SQM)	● Student Space (24)	
B00H - R0009 - Movement - (5.31 SQM)	Not Applicable	Circulation or storage space.
B00H - R0011 - Raised Platform - (37.8 SQM)	Not Applicable	Circulation or storage space.
B00H - R0015 - Communal Space - (210.12 SQM)	● Student Space (97)	
B00I - R0003 - Canteen - (46.5 SQM)	Not Applicable	Circulation or storage space.
B00K - R0001 - Reading Area - (231.08 SQM)	● Student Space (107)	
B00K - R1001 - Home Base - (58.46 SQM) - Teaching Space: 1	● Student Space (27)	
B00K - R1002 - Practical Activities - 1hb - (20.64 SQM)	● Student Space (9)	
B00K - R1004 - Withdrawal Space - 1hb - (9.14 SQM)	● Student Space (4)	
B00K - R1005 - Home Base - (60.92 SQM) - Teaching Space: 1	● Student Space (28)	
B00K - R1006 - Practical Activities - 1hb - (19.78 SQM)	● Student Space (9)	
B00K - R1008 - Withdrawal Space - 2hb - (11.67 SQM)	● Student Space (5)	
B00K - R1009 - Home Base - (60.71 SQM) - Teaching Space: 1	● Student Space (28)	
B00K - R1010 - Practical Activities - 1hb - (19.35 SQM)	● Student Space (8)	
B00L - R0001 - Entry Vestibule - (23.12 SQM)	Not Applicable	Circulation or storage space.
B00L - R0003 - Interview - (12.8 SQM)	● Office (3)	
B00L - R0004 - Clerical Office - (45.38 SQM)	● Office (11)	
B00L - R0005 - Interview - (12.18 SQM)	● Office (3)	
B00L - R0006 - Sick Bay - (8.93 SQM)	● Student Space (4)	
B00L - R0007 - Entry Vestibule - (12.78 SQM)	Not Applicable	Circulation or storage space.
B00L - R0010 - Duplicating Workroom - (14.04 SQM)	● Office (3)	
B00L - R0011 - Principal - (17.29 SQM)	● Office (4)	
B00L - R0012 - Deputy Principal - Type 2 - (26.52 SQM)	● Office (6)	
B00L - R0013 - Interview - (17.1 SQM)	● Office (4)	
B00L - R0015 - Deputy Principal - (14.08 SQM)	● Office (3)	
B00L - R0017 - Movement - (29.17 SQM)	Not Applicable	Circulation or storage space.
B00L - R0018 - Movement - (50.5 SQM)	Not Applicable	Circulation or storage space.
B00L - R0020 - Movement - (12.69 SQM)	Not Applicable	Circulation or storage space.
B00L - R0029 - Staff Room - (82.87 SQM)	● Office (20)	
B00L - R0030 - Staff Room Annexe - (46.66 SQM)	● Office (11)	
B00L - R0031 - Collaboration Space - (71.1 SQM)	● Student Space (32)	
B00L - R0032 - Practical Activities - 3hb - (8.05 SQM)	● Student Space (3)	
B00L - R0033 - Withdrawal Space - 2hb - (11.88 SQM)	● Student Space (5)	
B00L - R0034 - Home Base - (69.84 SQM) - Teaching Space: 1	● Student Space (32)	
B00L - R0035 - Home Base - (71.58 SQM) - Teaching Space: 1	● Student Space (33)	
B00L - R0037 - Home Base - (68.62 SQM) - Teaching Space: 1	● Student Space (31)	
B00L - R0038 - Withdrawal Space - 1hb - (9.72 SQM)	● Student Space (4)	
B00L - R0056 - Canteen - (51.2 SQM)	Not Applicable	Circulation or storage space.
B00L - R0063 - Staff Kitchen - (14 SQM)	● Office (3)	
B00L - R1001 - Movement - (15.01 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00L - R1004 - Home Base - (68.23 SQM) - Teaching Space: 1	Student Space (31)	
B00L - R1005 - Home Base - (69.27 SQM) - Teaching Space: 1	Student Space (32)	
B00L - R1006 - Practical Activities/Movement - 2hb - (15.24 SQM)	Student Space (7)	
B00L - R1007 - Withdrawal Space - 2hb - (11.88 SQM)	Student Space (5)	
B00L - R1008 - Withdrawal Space - 2hb - (8.92 SQM)	Student Space (4)	
B00L - R1009 - Home Base - (70.58 SQM) - Teaching Space: 1	Student Space (32)	
B00L - R1010 - Withdrawal Space - 2hb - (11.48 SQM)	Student Space (5)	
B00L - R1011 - Home Base - (70.61 SQM) - Teaching Space: 1	Student Space (32)	
B00L - R1012 - Home Base - (64.9 SQM) - Teaching Space: 1	Student Space (30)	
B00L - R1013 - Practical Activities - 2hb - (37.7 SQM)	Student Space (17)	
B00L - R1014 - Outdoor Learning Area - (48.88 SQM)	Not Applicable	Circulation or storage space.
B00L - R1015 - Practical Activities/Movement - 2hb - (64.6 SQM)	Student Space (29)	
B00L - R1016 - Home Base - (68.65 SQM) - Teaching Space: 1	Student Space (31)	
B00L - R1017 - Home Base - (67.21 SQM) - Teaching Space: 1	Student Space (31)	
B00L - R1018 - Withdrawal Space - 2hb - (12.26 SQM)	Student Space (5)	
B00L - R1019 - Home Base - (66.2 SQM) - Teaching Space: 1	Student Space (30)	
B00L - R1024 - Practical Activities - 2hb - (21.31 SQM)	Student Space (9)	
B00L - R1025 - Withdrawal Space - 2hb - (12.17 SQM)	Student Space (5)	
B00L - R1026 - Home Base - (68.85 SQM) - Teaching Space: 1	Student Space (31)	
B00L - R1027 - Home Base - (68.7 SQM) - Teaching Space: 1	Student Space (31)	
B00L - R1028 - Home Base - (69.71 SQM) - Teaching Space: 1	Student Space (32)	
B00L - R1029 - Practical Activities/Movement - 2hb - (26.95 SQM)	Student Space (12)	
B00L - R1030 - Withdrawal Space - 2hb - (11.9 SQM)	Student Space (5)	
B00L - R1032 - Practical Activities - 2hb - (19.65 SQM)	Student Space (9)	
B00L - R1033 - Home Base - (67.31 SQM) - Teaching Space: 1	Student Space (31)	
B00L - R1034 - Home Base - (66.79 SQM) - Teaching Space: 1	Student Space (30)	
B00L - R1035 - Withdrawal Space - 1hb - (12.18 SQM)	Student Space (5)	
B00L - R1042 - Movement - (199.08 SQM)	Not Applicable	Circulation or storage space.
B00L - R1043 - Movement - (41.65 SQM)	Not Applicable	Circulation or storage space.
B00L - R1048 - Movement - (61.08 SQM)	Not Applicable	Circulation or storage space.
B00L - R2001 - Movement - (14.67 SQM)	Not Applicable	Circulation or storage space.
B00L - R2004 - Home Base - (67.82 SQM) - Teaching Space: 1	Student Space (31)	
B00L - R2005 - Home Base - (68.69 SQM) - Teaching Space: 1	Student Space (31)	
B00L - R2006 - Practical Activities - 2hb - (15.72 SQM)	Student Space (7)	
B00L - R2007 - Withdrawal Space - 2hb - (11.87 SQM)	Student Space (5)	
B00L - R2008 - Withdrawal Space - 2hb - (8.82 SQM)	Student Space (4)	
B00L - R2009 - Home Base - (70.64 SQM) - Teaching Space: 1	Student Space (32)	
B00L - R2010 - Withdrawal Space - 2hb - (11.48 SQM)	Student Space (5)	
B00L - R2011 - Home Base - (70.75 SQM) - Teaching Space: 1	Student Space (32)	
B00L - R2012 - Home Base - (64.92 SQM) - Teaching Space: 1	Student Space (30)	
B00L - R2013 - Practical Activities - 2hb - (41.72 SQM)	Student Space (19)	
B00L - R2014 - Outdoor Learning Area - (48.88 SQM)	Not Applicable	Circulation or storage space.
B00L - R2015 - Practical Activities - 2hb - (65.56 SQM)	Student Space (30)	
B00L - R2016 - Home Base - (68.71 SQM) - Teaching Space: 1	Student Space (31)	
B00L - R2017 - Home Base - (67.31 SQM) - Teaching Space: 1	Student Space (31)	
B00L - R2018 - Withdrawal Space - 2hb - (12.21 SQM)	Student Space (5)	
B00L - R2019 - Home Base - (67.33 SQM) - Teaching Space: 1	Student Space (31)	
B00L - R2025 - Withdrawal Space - 2hb - (13.81 SQM)	Student Space (6)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00L - R2026 - Home Base - (69.92 SQM) - Teaching Space: 1	 Student Space (32)	
B00L - R2028 - Practical Activities - P - 2hb - (49.14 SQM)	 Student Space (22)	
B00L - R2031 - Movement - (54.84 SQM)	Not Applicable	Circulation or storage space.
B00L - R2032 - Movement - (62.03 SQM)	Not Applicable	Circulation or storage space.
B00L - R2033 - Movement - (37.07 SQM)	Not Applicable	Circulation or storage space.
OS 523 10642 - OS 523 10642 - Staff Study With Toilets - (76 SQM)	 Office (19)	
OS 602 12452 - OS 602 12452 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 602 13061 - OS 602 13061 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 602 13632 - OS 602 13632 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 602 14566 - OS 602 14566 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 602 14721 - OS 602 14721 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 602 15137 - OS 602 15137 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 602 15327 - OS 602 15327 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 602 16299 - OS 602 16299 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 602 17915 - OS 602 17915 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 603 12595 - OS 603 12595 - Learning Unit - Standard With P.A.A. A/C - (76 SQM)	 Student Space (35)	
OS 603 14418 - OS 603 14418 - Learning Unit - Standard With P.A.A. A/C - (76 SQM)	 Student Space (35)	
OS 606 10594 - OS 606 10594 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	 Student Space (35)	
OS 606 11382 - OS 606 11382 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	 Student Space (35)	
OS 606 14648 - OS 606 14648 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	 Student Space (35)	
OS 606 18240 - OS 606 18240 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	 Student Space (35)	
OS 606 19030 - OS 606 19030 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	 Student Space (35)	
OS 606 19094 - OS 606 19094 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	 Student Space (35)	
OS 606 19244 - OS 606 19244 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	 Student Space (35)	
OS 606 19580 - OS 606 19580 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	 Student Space (35)	
OS 606 19597 - OS 606 19597 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	 Student Space (35)	
OS 606 19598 - OS 606 19598 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	 Student Space (35)	
OS 606 19611 - OS 606 19611 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	 Student Space (35)	
OS 606 19662 - OS 606 19662 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	 Student Space (35)	
OS 801 14226 - OS 801 14226 - FSU - (57 SQM)	Not Applicable	Circulation or storage space.