

VENTILATION AUDIT REPORT

SCHOOL:	St Johns Park Public School (3029)
AMU REGION:	South Western Sydney
STATE ELECTORATE:	Cabramatta
LOCAL GOVERNMENT AREA:	Fairfield

3029 - St Johns Park Public School
Site Plan (11267)



1:1,405

Printed: 21-Mar-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Movement - (6.83 SQM)	Not Applicable	Circulation or storage space.
B00A - R0002 - Outdoor Learning Area - (55.56 SQM)	Not Applicable	Circulation or storage space.
B00A - R0003 - Special Programs Room - (16.8 SQM)	● Student Space (7)	
B00A - R0004 - Movement - (33.82 SQM)	Not Applicable	Circulation or storage space.
B00A - R0006 - Movement - (26.92 SQM)	Not Applicable	Circulation or storage space.
B00A - R0009 - Home Base - (56.33 SQM) - Teaching Space: 1	● Student Space (26)	
B00A - R0010 - Practical Activities - 1hb - (10.47 SQM)	● Student Space (4)	
B00A - R0011 - Home Base - (56.02 SQM) - Teaching Space: 1	● Student Space (25)	
B00A - R0012 - Practical Activities - 1hb - (21.88 SQM)	● Student Space (10)	
B00A - R0013 - Home Base - (56.02 SQM) - Teaching Space: 1	● Student Space (25)	
B00A - R0014 - Movement - (23.05 SQM)	Not Applicable	Circulation or storage space.
B00A - R0015 - Practical Activities - 1hb - (11.13 SQM)	● Student Space (5)	
B00A - R0016 - Home Base - (56.88 SQM) - Teaching Space: 1	● Student Space (26)	
B00A - R0018 - Movement - (42.68 SQM)	Not Applicable	Circulation or storage space.
B00A - R0019 - Home Base - (56.63 SQM) - Teaching Space: 1	● Student Space (26)	
B00A - R0020 - Practical Activities - 1hb - (24.29 SQM)	● Student Space (11)	
B00A - R0023 - Home Base - (56.39 SQM) - Teaching Space: 1	● Student Space (26)	
B00A - R0024 - Practical Activities - 1hb - (28.08 SQM)	● Student Space (13)	
B00A - R0025 - Movement - (8.46 SQM)	Not Applicable	Circulation or storage space.
B00A - R0026 - Home Base - (57.25 SQM) - Teaching Space: 1	● Student Space (26)	
B00A - R0028 - Movement - (60.02 SQM)	Not Applicable	Circulation or storage space.
B00B - M0002 - Movement - (27.74 SQM)	Not Applicable	Circulation or storage space.
B00B - M0004 - Special Programs Room - (12.96 SQM)	● Student Space (6)	
B00B - R0003 - Movement - (9.56 SQM)	Not Applicable	Circulation or storage space.
B00B - R0006 - Practical Activities - 1hb - (60.62 SQM)	● Student Space (28)	
B00B - R0008 - Home Base - (61.43 SQM) - Teaching Space: 1	● Student Space (28)	
B00B - R0009 - Movement - (20.25 SQM)	Not Applicable	Circulation or storage space.
B00B - R0010 - Movement - (21.28 SQM)	Not Applicable	Circulation or storage space.
B00B - R0012 - Withdrawal Space - 1hb - (10.47 SQM)	● Student Space (4)	
B00B - R0013 - Home Base - (61.24 SQM) - Teaching Space: 1	● Student Space (28)	
B00B - R0015 - Withdrawal Space - 1hb - (11.66 SQM)	● Student Space (5)	
B00B - R0017 - Movement - (15.33 SQM)	Not Applicable	Circulation or storage space.
B00B - R0018 - Home Base - (61.57 SQM) - Teaching Space: 1	● Student Space (28)	
B00B - R0020 - Staff Room Annexe - (10.58 SQM)	● Office (2)	
B00B - R0021 - Movement - (10.01 SQM)	Not Applicable	Circulation or storage space.
B00B - R0022 - Interview - (10.63 SQM)	● Office (2)	
B00B - R0024 - Practical Activities - 1hb - (68.97 SQM)	● Student Space (31)	
B00B - R0025 - Movement - (50.06 SQM)	Not Applicable	Circulation or storage space.
B00B - R0026 - Home Base - (66.25 SQM) - Teaching Space: 1	● Student Space (30)	
B00B - R0028 - Withdrawal Space - 1hb - (9.91 SQM)	● Student Space (4)	
B00B - R0029 - Home Base - (61.49 SQM) - Teaching Space: 1	● Student Space (28)	
B00B - R0031 - Special Programs Room - (51.15 SQM)	● Student Space (23)	
B00B - R0035 - Reading Area - (249.43 SQM)	● Student Space (115)	
B00B - R0041 - Movement - (98.27 SQM)	Not Applicable	Circulation or storage space.
B00B - R1001 - Reading Area - (40.48 SQM)	● Student Space (18)	
B00C - R0001 - Practical Activities - 1hb - (77.49 SQM)	● Student Space (35)	
B00C - R0004 - Home Base - (61.32 SQM) - Teaching Space: 1	● Student Space (28)	
B00C - R0005 - Movement - (16.46 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00C - R0008 - Withdrawal Space - 1hb - (12.03 SQM)	● Student Space (5)	
B00C - R0011 - Home Base - (61.36 SQM) - Teaching Space: 1	● Student Space (28)	
B00C - R0012 - Withdrawal Space - 1hb - (10.68 SQM)	● Student Space (4)	
B00C - R0013 - Home Base - (69.83 SQM) - Teaching Space: 1	● Student Space (32)	
B00C - R0021 - Movement - (102.63 SQM)	Not Applicable	Circulation or storage space.
B00C - R0023 - Home Base - (61.58 SQM) - Teaching Space: 1	● Student Space (28)	
B00C - R0027 - Staff Room Annexe - (10.61 SQM)	● Office (2)	
B00C - R0028 - Practical Activities - 1hb - (66.73 SQM)	● Student Space (30)	
B00C - R0029 - Home Base - (61.15 SQM) - Teaching Space: 1	● Student Space (28)	
B00C - R0031 - Withdrawal Space - 1hb - (10.67 SQM)	● Student Space (4)	
B00C - R0032 - Home Base - (61.35 SQM) - Teaching Space: 1	● Student Space (28)	
B00C - R0034 - Withdrawal Space - 1hb - (10.7 SQM)	● Student Space (4)	
B00C - R0040 - Withdrawal Space - 1hb - (48.32 SQM)	● Student Space (22)	
B00C - R0043 - Movement - (7.05 SQM)	Not Applicable	Circulation or storage space.
B00C - R0044 - Movement - (217.46 SQM)	Not Applicable	Circulation or storage space.
B00D - R0001 - Staff Room Annexe - (10.51 SQM)	● Office (2)	
B00D - R0002 - Practical Activities - 1hb - (72.4 SQM)	● Student Space (33)	
B00D - R0003 - Home Base - (61.09 SQM) - Teaching Space: 1	● Student Space (28)	
B00D - R0005 - Withdrawal Space - 1hb - (10.56 SQM)	● Student Space (4)	
B00D - R0006 - Movement - (15.38 SQM)	Not Applicable	Circulation or storage space.
B00D - R0007 - Movement - (5.75 SQM)	Not Applicable	Circulation or storage space.
B00D - R0008 - Home Base - (63.83 SQM) - Teaching Space: 1	● Student Space (29)	
B00D - R0010 - Withdrawal Space - 1hb - (10.72 SQM)	● Student Space (4)	
B00D - R0011 - Home Base - (61.09 SQM) - Teaching Space: 1	● Student Space (28)	
B00D - R0015 - Movement - (99.03 SQM)	Not Applicable	Circulation or storage space.
B00E - R0003 - Movement - (25.06 SQM)	Not Applicable	Circulation or storage space.
B00E - R0007 - Communal Space - (240.05 SQM)	● Student Space (111)	
B00E - R0008 - Raised Platform - (37.79 SQM)	Not Applicable	Circulation or storage space.
B00E - R0014 - Movement - (231.31 SQM)	Not Applicable	Circulation or storage space.
B00E - R0018 - Canteen - (38.21 SQM)	Not Applicable	Circulation or storage space.
B00F - R0001 - Movement - (21.74 SQM)	Not Applicable	Circulation or storage space.
B00F - R0002 - Staff Room - (66.64 SQM)	● Office (16)	
B00F - R0003 - Principal - (21.91 SQM)	● Office (5)	
B00F - R0004 - Movement - (15.99 SQM)	Not Applicable	Circulation or storage space.
B00F - R0009 - Deputy Principal - (16.22 SQM)	● Office (4)	
B00F - R0010 - Staff Room Annexe - (16.31 SQM)	● Office (4)	
B00F - R0011 - Movement - (33.43 SQM)	Not Applicable	Circulation or storage space.
B00F - R0014 - Movement - (7.88 SQM)	Not Applicable	Circulation or storage space.
B00F - R0015 - Movement - (55.18 SQM)	Not Applicable	Circulation or storage space.
B00F - R0016 - Entry Vestibule - (49.69 SQM)	Not Applicable	Circulation or storage space.
B00F - R0017 - Movement - (10.46 SQM)	Not Applicable	Circulation or storage space.
B00F - R0019 - Sick Bay - (16.3 SQM)	● Student Space (7)	
B00F - R0021 - Clerical Office/Workroom - (16.37 SQM)	● Office (4)	
B00F - R0022 - Duplicating Workroom - (34.7 SQM)	● Office (8)	
B00F - R0023 - Clerical Office - (12.18 SQM)	● Office (3)	
B00H - R0001 - Staff Room Annexe - (22.27 SQM)	● Office (5)	
B00H - R0002 - Home Base - (52.36 SQM) - Teaching Space: 1	● Student Space (24)	
B00H - R0003 - Home Base - (52.36 SQM) - Teaching Space: 1	● Student Space (24)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00H - R0004 - Special Programs Room - (10.8 SQM)	● Student Space (5)	
B00H - R0005 - Special Programs Room - (11.1 SQM)	● Student Space (5)	
B00H - R0006 - Home Base - (52.06 SQM) - Teaching Space: 1	● Student Space (24)	
B00H - R0007 - Home Base - (52.06 SQM) - Teaching Space: 1	● Student Space (24)	
B00H - R0008 - Movement - (88.22 SQM)	Not Applicable	Circulation or storage space.
B00I - R0002 - Entry Vestibule - (13.89 SQM)	Not Applicable	Circulation or storage space.
B00I - R0005 - Home Base - Pre - (68.97 SQM) - Teaching Space: 1	● Student Space (31)	
B00I - R0006 - Practical Activities - Pre - (46.31 SQM)	● Student Space (21)	
B00I - R0015 - Movement - (69.36 SQM)	Not Applicable	Circulation or storage space.
B00M - R0002 - Movement - (11.79 SQM)	Not Applicable	Circulation or storage space.
B00M - R0003 - Clerical Office - (9.86 SQM)	● Office (2)	
B00N - R0001 - Movement - (38.49 SQM)	Not Applicable	Circulation or storage space.
B00N - R0002 - Practical Activities - 1hb - (19.4 SQM)	● Student Space (9)	
B00N - R0004 - Home Base - (59.22 SQM) - Teaching Space: 1	● Student Space (27)	
B00N - R0005 - Withdrawal Space - 2hb - (11.36 SQM)	● Student Space (5)	
B00N - R0006 - Home Base - (59.21 SQM) - Teaching Space: 1	● Student Space (27)	
B00N - R0008 - Practical Activities - 1hb - (19.42 SQM)	● Student Space (9)	
B00O - R0001 - Practical Activities - 1hb - (19.17 SQM)	● Student Space (8)	
B00O - R0002 - Home Base - (59.46 SQM) - Teaching Space: 1	● Student Space (27)	
B00O - R0004 - Withdrawal Space - 1hb - (7.66 SQM)	● Student Space (3)	
B00O - R0005 - Practical Activities - 1hb - (18.56 SQM)	● Student Space (8)	
B00O - R0006 - Home Base - (61.25 SQM) - Teaching Space: 1	● Student Space (28)	
B00O - R0008 - Withdrawal Space - 2hb - (11.78 SQM)	● Student Space (5)	
B00O - R0009 - Practical Activities - 1hb - (19.21 SQM)	● Student Space (8)	
B00O - R0010 - Home Base - (61.31 SQM) - Teaching Space: 1	● Student Space (28)	
B00P - R0001 - Practical Activities - 1hb - (19.17 SQM)	● Student Space (8)	
B00P - R0002 - Home Base - (59.46 SQM) - Teaching Space: 1	● Student Space (27)	
B00P - R0004 - Withdrawal Space - 1hb - (7.66 SQM)	● Student Space (3)	
B00P - R0005 - Practical Activities - 1hb - (18.56 SQM)	● Student Space (8)	
B00P - R0006 - Home Base - (61.25 SQM) - Teaching Space: 1	● Student Space (28)	
B00P - R0008 - Withdrawal Space - 2hb - (11.78 SQM)	● Student Space (5)	
B00P - R0009 - Practical Activities - 1hb - (19.21 SQM)	● Student Space (8)	
B00P - R0010 - Home Base - (61.31 SQM) - Teaching Space: 1	● Student Space (28)	
OS 602 10271 - OS 602 10271 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 18300 - OS 602 18300 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 606 15354 - OS 606 15354 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	● Student Space (35)	
OS 606 19032 - OS 606 19032 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	● Student Space (35)	
OS 614 14130 - OS 614 14130 - Learning Unit - Double Kindergarten - (190 SQM)	● Student Space (88)	