

# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>St Marys Senior High School (8870)</b>
<b>AMU REGION:</b>	<b>Western Sydney</b>
<b>STATE ELECTORATE:</b>	<b>Londonderry</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Penrith</b>

8870 - St Marys Senior High School  
Site Plan (11270)



1:1,673

Printed: 21-Mar-2020













## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Ancillary Staff - (23.12 SQM)	Office (5)	
B00A - R0002 - Interview/Office - Type 1 - (12.71 SQM)	Office (3)	
B00A - R0003 - Deputy Principal Office - (12.72 SQM)	Office (3)	
B00A - R0004 - Administration - Clerical - (23.11 SQM)	Office (5)	
B00A - R0005 - Administration - Clerical - (48.47 SQM)	Office (12)	
B00A - R0008 - Duplicating Workroom - (25.54 SQM)	Office (6)	
B00A - R0009 - Public Entry - (71.5 SQM)	Not Applicable	Circulation or storage space.
B00A - R0010 - Pupil Entry - (36.45 SQM)	Not Applicable	Circulation or storage space.
B00A - R0011 - Deputy Principal Office - (15.94 SQM)	Office (3)	
B00A - R0012 - Clinic - Boys - (13.54 SQM)	Office (3)	
B00A - R0015 - Commonroom - (14.01 SQM)	Office (3)	
B00A - R0019 - Principal Office - (16.28 SQM)	Office (4)	
B00A - R0021 - Movement - (11.72 SQM)	Not Applicable	Circulation or storage space.
B00A - R0022 - Staff Study - (43.46 SQM)	Office (10)	
B00A - R0025 - Interview/Office - Type 1 - (13.28 SQM)	Office (3)	
B00A - R0026 - Interview/Office - Type 1 - (12.71 SQM)	Office (3)	
B00A - R0027 - General Learning Space - (48.11 SQM) - Teaching Space: 1	Student Space (22)	
B00A - R0028 - General Learning Space - (44.39 SQM) - Teaching Space: 1	Student Space (20)	
B00A - R0033 - Movement - (413.82 SQM)	Not Applicable	Circulation or storage space.
B00A - R0034 - Movement - (11.65 SQM)	Not Applicable	Circulation or storage space.
B00A - R0035 - Staff Study - (43.46 SQM)	Office (10)	
B00A - R0038 - Interview/Office - Type 1 - (13.26 SQM)	Office (3)	
B00A - R0039 - Interview/Office - Type 1 - (12.71 SQM)	Office (3)	
B00A - R0040 - General Learning Space - (48.11 SQM) - Teaching Space: 1	Student Space (22)	
B00A - R0049 - Tiered Learning Area - (97.43 SQM)	Student Space (45)	
B00A - R0050 - Stage - (17.99 SQM)	Not Applicable	Circulation or storage space.
B00A - R0061 - General Learning Space - (47.63 SQM) - Teaching Space: 1	Student Space (22)	
B00A - R0062 - General Learning Space - (47.63 SQM) - Teaching Space: 1	Student Space (22)	
B00A - R0063 - General Learning Space - (47.08 SQM) - Teaching Space: 1	Student Space (21)	
B00A - R1001 - General Learning Space - (41.31 SQM) - Teaching Space: 1	Student Space (19)	
B00A - R1002 - Study Space - (14.8 SQM)	Not Applicable	Circulation or storage space.
B00A - R1003 - Study Space - (14.8 SQM)	Not Applicable	Circulation or storage space.
B00A - R1004 - General Learning Space - (41.32 SQM) - Teaching Space: 1	Student Space (19)	
B00A - R1007 - Movement - (67.22 SQM)	Not Applicable	Circulation or storage space.
B00A - R1012 - Darkroom Space - (27.4 SQM)	Office (6)	
B00A - R1015 - General Learning Space - (48.11 SQM) - Teaching Space: 1	Student Space (22)	
B00A - R1016 - General Learning Space - (48.11 SQM) - Teaching Space: 1	Student Space (22)	
B00A - R1020 - Staff Study - (43.81 SQM)	Office (10)	
B00A - R1021 - Commonroom - (108.62 SQM)	Office (27)	
B00A - R1024 - Movement - (403.64 SQM)	Not Applicable	Circulation or storage space.
B00A - R1027 - Staff Study - (24.76 SQM)	Office (6)	
B00A - R1028 - Interview/Office - Type 1 - (12.42 SQM)	Office (3)	
B00A - R1031 - General Learning Space - (48.1 SQM) - Teaching Space: 1	Student Space (22)	
B00A - R1032 - General Learning Space - (48.11 SQM) - Teaching Space: 1	Student Space (22)	
B00A - R1033 - Study Space - (24.18 SQM)	Not Applicable	Circulation or storage space.
B00A - R1034 - General Learning Space - (48.11 SQM) - Teaching Space: 1	Student Space (22)	
B00A - R1035 - General Learning Space - (48.1 SQM) - Teaching Space: 1	Student Space (22)	
B00A - R1044 - General Learning Space - (47.61 SQM) - Teaching Space: 1	Student Space (22)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R1045 - General Learning Space - (47.63 SQM) - Teaching Space: 1	Student Space (22)	
B00A - R1046 - General Learning Space - (46.91 SQM) - Teaching Space: 1	Student Space (21)	
B00B - R0007 - Movement - (42.67 SQM)	Not Applicable	Circulation or storage space.
B00B - R0008 - Materials Technology L.S. - (65.77 SQM) - Teaching Space: 1	Student Space (30)	
B00B - R0009 - Wood Technology Bay - (20.1 SQM)	Not Applicable	Circulation or storage space.
B00B - R0013 - Workshop Area - (62.16 SQM)	Student Space (28)	
B00B - R0014 - Welding Area - (9.46 SQM)	Not Applicable	Circulation or storage space.
B00B - R0016 - Design/Technology L.S. - (95.73 SQM) - Teaching Space: 1	Student Space (44)	
B00B - R0018 - Movement - (17.62 SQM)	Not Applicable	Circulation or storage space.
B00B - R0020 - Metal Technology Bay - (21.68 SQM)	Not Applicable	Circulation or storage space.
B00B - R0021 - Art Learning Space - (40.65 SQM) - Teaching Space: 1	Student Space (18)	
B00B - R0022 - Movement - (6.14 SQM)	Not Applicable	Circulation or storage space.
B00B - R0025 - Darkroom Space - (29.64 SQM)	Office (7)	
B00B - R0026 - Movement - (23.82 SQM)	Not Applicable	Circulation or storage space.
B00B - R1001 - Staff Study - (52.81 SQM)	Office (13)	
B00B - R1003 - Design L.S. - (32.72 SQM) - Teaching Space: 1	Student Space (15)	
B00B - R1004 - General Learning Space - (52.81 SQM) - Teaching Space: 1	Student Space (24)	
B00B - R1008 - Design L.S. - (81.93 SQM) - Teaching Space: 1	Student Space (38)	
B00B - R1011 - Design L.S. - (81.93 SQM) - Teaching Space: 1	Student Space (38)	
B00B - R1012 - Movement - (59.81 SQM)	Not Applicable	Circulation or storage space.
B00B - R1013 - Movement - (23.82 SQM)	Not Applicable	Circulation or storage space.
B00C - R0001 - Movement - (291.72 SQM)	Not Applicable	Circulation or storage space.
B00C - R0003 - Administration - Clerical - (7.7 SQM)	Office (1)	
B00C - R0008 - Student Canteen - (50.59 SQM)	Not Applicable	Circulation or storage space.
B00C - R0012 - Movement - (12.48 SQM)	Not Applicable	Circulation or storage space.
B00C - R0016 - Food Technology L.S. - (99.28 SQM) - Teaching Space: 1	Student Space (46)	
B00C - R0019 - Movement - (8.83 SQM)	Not Applicable	Circulation or storage space.
B00E - R0001 - Movement - (20.58 SQM)	Not Applicable	Circulation or storage space.
B00E - R0002 - General Learning Space - (50.34 SQM) - Teaching Space: 1	Student Space (23)	
B00E - R0003 - Staff Study - (39.06 SQM)	Office (9)	
B00E - R0005 - Staff Study - (12.61 SQM)	Office (3)	
B00E - R0008 - General Learning Space - (39.22 SQM) - Teaching Space: 1	Student Space (18)	
B00E - R0009 - Staff Study - (50.55 SQM)	Office (12)	
B00E - R0010 - Movement - (22.21 SQM)	Not Applicable	Circulation or storage space.
B00E - R0013 - Laboratory L.S. - (91.96 SQM) - Teaching Space: 1	Student Space (42)	
B00E - R0014 - Preparation - (71.17 SQM)	Not Applicable	Circulation or storage space.
B00E - R0015 - Laboratory L.S. - (91.96 SQM) - Teaching Space: 1	Student Space (42)	
B00E - R0020 - Movement - (145.62 SQM)	Not Applicable	Circulation or storage space.
B00E - R0021 - Laboratory L.S. - (93.15 SQM) - Teaching Space: 1	Student Space (43)	
B00E - R0023 - Laboratory L.S. - (93.16 SQM) - Teaching Space: 1	Student Space (43)	
B00E - R0024 - Movement - (45.92 SQM)	Not Applicable	Circulation or storage space.
B00E - R1001 - General Learning Space - (50.44 SQM) - Teaching Space: 1	Student Space (23)	
B00E - R1002 - Movement - (8.42 SQM)	Not Applicable	Circulation or storage space.
B00E - R1003 - General Learning Space - (50.43 SQM) - Teaching Space: 1	Student Space (23)	
B00E - R1004 - Study Space - (21.47 SQM)	Not Applicable	Circulation or storage space.
B00E - R1008 - General Learning Space - (60.8 SQM) - Teaching Space: 1	Student Space (28)	
B00E - R1012 - General Learning Space - (50.58 SQM) - Teaching Space: 1	Student Space (23)	
B00E - R1013 - General Learning Space - (49.7 SQM) - Teaching Space: 1	Student Space (23)	
B00E - R1014 - General Learning Space - (51.86 SQM) - Teaching Space: 1	Student Space (24)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00E - R1016 - Staff Study - (41.38 SQM)	Office (10)	
B00E - R1018 - General Learning Space - (51.75 SQM) - Teaching Space: 1	Student Space (24)	
B00E - R1019 - Movement - (185.2 SQM)	Not Applicable	Circulation or storage space.
B00H - R0002 - Movement - (11.7 SQM)	Not Applicable	Circulation or storage space.
B00H - R0003 - Movement - (12.09 SQM)	Not Applicable	Circulation or storage space.
B00H - R0008 - Stage - (106.76 SQM)	Not Applicable	Circulation or storage space.
B00H - R0014 - Movement - (12.09 SQM)	Not Applicable	Circulation or storage space.
B00H - R0015 - Movement - (11.69 SQM)	Not Applicable	Circulation or storage space.
B00H - R0019 - Staff Kitchen - (23.61 SQM)	Office (5)	
B00H - R0020 - Movement - (23.45 SQM)	Not Applicable	Circulation or storage space.
B00H - R0021 - Movement - (19.21 SQM)	Not Applicable	Circulation or storage space.
B00H - R0023 - Multi-Purpose Space - (628.77 SQM)	Student Space (291)	
B00H - R0027 - Movement - (8.41 SQM)	Not Applicable	Circulation or storage space.
B00H - R0028 - Movement - (8.41 SQM)	Not Applicable	Circulation or storage space.
B00H - R1006 - Movement - (254.4 SQM)	Not Applicable	Circulation or storage space.
B00L - R0005 - Seminar - (15.2 SQM)	Office (3)	
B00L - R0006 - Seminar - (15.2 SQM)	Office (3)	
B00L - R0007 - Seminar - (15.2 SQM)	Office (3)	
B00L - R0008 - Seminar - (15.2 SQM)	Office (3)	
B00L - R0009 - Seminar - (15.2 SQM)	Office (3)	
B00L - R0010 - Seminar - (15.2 SQM)	Office (3)	
B00L - R0011 - Seminar - (44.12 SQM)	Office (11)	
B00L - R0012 - Main Area - (658.59 SQM)	Not Applicable	Circulation or storage space.
B00L - R0013 - Entry - (36.36 SQM)	Not Applicable	Circulation or storage space.
B00L - R0014 - Workroom - (50.5 SQM)	Office (12)	
B00L - R0016 - Audio Visual Workroom - (58.33 SQM)	Student Space (27)	
B00L - R0017 - Senior Study - (155.56 SQM)	Office (38)	
B00L - R0018 - Movement - (9.72 SQM)	Not Applicable	Circulation or storage space.
B00L - R0020 - Interview/Office - Type 1 - (13.9 SQM)	Office (3)	
B00L - R0021 - Interview/Office - Type 1 - (13.51 SQM)	Office (3)	
B00L - R0022 - Interview/Office - Type 1 - (13.51 SQM)	Office (3)	
B00L - R0023 - Interview/Office - Type 1 - (17.4 SQM)	Office (4)	
B00L - R0024 - Interview/Office - Type 1 - (15.86 SQM)	Office (3)	
B00L - R0025 - Interview/Office - Type 1 - (37.56 SQM)	Office (9)	
B00L - R0027 - Commonroom - (74.87 SQM)	Office (18)	
B00L - R0028 - Movement - (249.02 SQM)	Not Applicable	Circulation or storage space.
B00V - R0001 - Music Learning Space - (81.93 SQM) - Teaching Space: 1	Student Space (38)	
B00V - R0002 - Preparation - (31.51 SQM)	Not Applicable	Circulation or storage space.
B00V - R0003 - Food Technology L.S. - (81.04 SQM) - Teaching Space: 1	Student Space (37)	
B00V - R0008 - Practice/Seminar - (22.68 SQM)	Not Applicable	Circulation or storage space.
B00V - R0009 - Practice/Seminar - (26.64 SQM)	Not Applicable	Circulation or storage space.
B00V - R0010 - Music Learning Space - (63.16 SQM) - Teaching Space: 1	Student Space (29)	
B00V - R0016 - Staff Study - (38.08 SQM)	Office (9)	
B00V - R0018 - Movement - (87.45 SQM)	Not Applicable	Circulation or storage space.
B00V - R0019 - Movement - (24.29 SQM)	Not Applicable	Circulation or storage space.
B00V - R1001 - Art Learning Space - (135.2 SQM) - Teaching Space: 1	Student Space (62)	
B00V - R1005 - Performance Workspace - (130.56 SQM) - Teaching Space: 1	Student Space (60)	
B00V - R1006 - Art Learning Space - (114.08 SQM) - Teaching Space: 1	Student Space (52)	
B00V - R1009 - Movement - (71.31 SQM)	Not Applicable	Circulation or storage space.
B00V - R1012 - Movement - (22.47 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
BOCT - M1002 - Study Space - (15.2 SQM)	Not Applicable	Circulation or storage space.
BOCT - M1005 - Seminar - (37.6 SQM)	 Office (9)	
BOCT - M1007 - General Learning Space - (46.96 SQM) - Teaching Space: 1	 Student Space (21)	
BOCT - M1008 - Movement - (20.08 SQM)	Not Applicable	Circulation or storage space.
BOCT - R0001 - Laboratory L.S. - (91.24 SQM) - Teaching Space: 1	 Student Space (42)	
BOCT - R0005 - Laboratory L.S. - (91.24 SQM) - Teaching Space: 1	 Student Space (42)	
BOCT - R0008 - Laboratory L.S. - (91.23 SQM) - Teaching Space: 1	 Student Space (42)	
BOCT - R0009 - Preparation - (31.49 SQM)	Not Applicable	Circulation or storage space.
BOCT - R0012 - Performance Workspace - (91.23 SQM) - Teaching Space: 1	 Student Space (42)	
BOCT - R0015 - Movement - (40.39 SQM)	Not Applicable	Circulation or storage space.
BOCT - R0016 - Preparation - Science - (48.8 SQM)	Not Applicable	Circulation or storage space.
BOCT - R0018 - Preparation - Science - (5.9 SQM)	Not Applicable	Circulation or storage space.
BOCT - R1001 - Computer Learning Space - (70.74 SQM) - Teaching Space: 1	 Student Space (32)	
BOCT - R1002 - Computer Learning Space - (104 SQM) - Teaching Space: 1	 Student Space (48)	
BOCT - R1008 - Computer Learning Space - (67.8 SQM) - Teaching Space: 1	 Student Space (31)	
BOCT - R1009 - Computer Learning Space - (69.84 SQM) - Teaching Space: 1	 Student Space (32)	
BOCT - R1010 - Staff Study - (28.6 SQM)	 Office (7)	
BOCT - R1012 - Staff Study - (29.18 SQM)	 Office (7)	
BOCT - R1016 - Movement - (100.06 SQM)	Not Applicable	Circulation or storage space.