

# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>St Peters Public School (3032)</b>
<b>AMU REGION:</b>	<b>Sydney</b>
<b>STATE ELECTORATE:</b>	<b>Heffron</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Inner West</b>

3032 - St Peters Public School  
Site Plan (11271)



## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - M0001 - Reading Area - (89.54 SQM)	● Student Space (41)	
B00A - R0001 - Staff Room Annexe - (13.96 SQM)	● Office (3)	
B00A - R0007 - Interview - (10.49 SQM)	● Office (2)	
B00A - R0008 - Principal - (23.21 SQM)	● Office (5)	
B00A - R0009 - Entry Vestibule - (22.7 SQM)	Not Applicable	Circulation or storage space.
B00A - R0012 - Movement - (12.44 SQM)	Not Applicable	Circulation or storage space.
B00A - R0013 - Movement - (14.44 SQM)	Not Applicable	Circulation or storage space.
B00A - R0017 - Seminar/Study - (44.34 SQM)	● Office (11)	
B00A - R0021 - Reading Area - (25.05 SQM)	● Student Space (11)	
B00A - R0022 - Movement - (16.49 SQM)	Not Applicable	Circulation or storage space.
B00A - R0023 - Movement - (6.08 SQM)	Not Applicable	Circulation or storage space.
B00A - R0042 - Movement - (6.91 SQM)	Not Applicable	Circulation or storage space.
B00A - R0048 - Duplicating Workroom - (12.49 SQM)	● Office (3)	
B00A - R0052 - Movement - (6.93 SQM)	Not Applicable	Circulation or storage space.
B00A - R0053 - Clerical Office - (9.49 SQM)	● Office (2)	
B00A - R0056 - Movement - (47.74 SQM)	Not Applicable	Circulation or storage space.
B00A - R0057 - Movement - (13.13 SQM)	Not Applicable	Circulation or storage space.
B00A - R0058 - Home Base - (64.93 SQM) - Teaching Space: 1	● Student Space (30)	
B00A - R0059 - Staff Kitchen - (5.32 SQM)	● Office (1)	
B00A - R0060 - Staff Room - (40.27 SQM)	● Office (10)	
B00B - R0016 - Communal Space - (174.3 SQM)	● Student Space (80)	
B00B - R0017 - Movement - (8.84 SQM)	Not Applicable	Circulation or storage space.
B00B - R0018 - Movement - (21.36 SQM)	Not Applicable	Circulation or storage space.
B00B - R0019 - Raised Platform - (36.81 SQM)	Not Applicable	Circulation or storage space.
B00B - R0020 - Canteen - (33.83 SQM)	Not Applicable	Circulation or storage space.
B00B - R0022 - Movement - (5.92 SQM)	Not Applicable	Circulation or storage space.
B00B - R0035 - Movement - (12.22 SQM)	Not Applicable	Circulation or storage space.
B00B - R0038 - Movement - (20.63 SQM)	Not Applicable	Circulation or storage space.
B00B - R0046 - Movement - (17.56 SQM)	Not Applicable	Circulation or storage space.
B00B - R0052 - Movement - (8.77 SQM)	Not Applicable	Circulation or storage space.
B00B - R0055 - Movement - (31.15 SQM)	Not Applicable	Circulation or storage space.
B00B - R0057 - Movement - (52.57 SQM)	Not Applicable	Circulation or storage space.
B00B - R1001 - Practical Activities - 1hb - (19.62 SQM)	● Student Space (9)	
B00B - R1002 - Home Base - (49.88 SQM) - Teaching Space: 1	● Student Space (23)	
B00B - R1003 - Home Base - (52.76 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R1004 - Practical Activities - 1hb - (18.66 SQM)	● Student Space (8)	
B00B - R1008 - Practical Activities - 1hb - (19.5 SQM)	● Student Space (9)	
B00B - R1009 - Home Base - (51.09 SQM) - Teaching Space: 1	● Student Space (23)	
B00B - R1010 - Home Base - (51 SQM) - Teaching Space: 1	● Student Space (23)	
B00B - R1011 - Practical Activities - 1hb - (18.77 SQM)	● Student Space (8)	
B00B - R1012 - Practical Activities - 1hb - (19.67 SQM)	● Student Space (9)	
B00B - R1013 - Home Base - (51.49 SQM) - Teaching Space: 1	● Student Space (23)	
B00B - R1014 - Home Base - (51.33 SQM) - Teaching Space: 1	● Student Space (23)	
B00B - R1015 - Practical Activities - 1hb - (19.69 SQM)	● Student Space (9)	
B00B - R1020 - Movement - (19.47 SQM)	Not Applicable	Circulation or storage space.
B00B - R1029 - Movement - (125.05 SQM)	Not Applicable	Circulation or storage space.