

# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Stewart House School (5515)</b>
<b>AMU REGION:</b>	<b>Northern Sydney</b>
<b>STATE ELECTORATE:</b>	<b>Manly</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Northern Beaches</b>



5515 - Stewart House School  
Site Plan (11316)



1:639

Printed: 15-Aug-2020

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0002 - Clerical Office - (15.41 SQM)	Office (3)	
B00A - R0004 - Dental Clinic - (17.95 SQM)	Office (4)	
B00A - R0005 - Movement - (42.92 SQM)	Not Applicable	Circulation or storage space.
B00A - R0006 - Movement - (21.82 SQM)	Not Applicable	Circulation or storage space.
B00A - R0009 - Movement - (7.29 SQM)	Not Applicable	Circulation or storage space.
B00A - R0010 - Movement - (55.82 SQM)	Not Applicable	Circulation or storage space.
B00A - R0011 - Movement - (11.43 SQM)	Not Applicable	Circulation or storage space.
B00A - R0016 - Practical Activities - 1hb - (31.33 SQM)	Student Space (14)	
B00A - R0021 - Movement - (21.82 SQM)	Not Applicable	Circulation or storage space.
B00A - R0022 - Movement - (42.76 SQM)	Not Applicable	Circulation or storage space.
B00A - R0023 - Home Base - (69.74 SQM)	Student Space (32)	
B00A - R0024 - Home Base - (67.98 SQM)	Student Space (31)	
B00A - R0027 - Special Programs Room - (23.28 SQM)	Student Space (10)	
B00A - R0028 - Movement - (20.58 SQM)	Not Applicable	Circulation or storage space.
B00A - R0030 - Home Base - (38.03 SQM) - Teaching Space: 1	Student Space (17)	
B00A - R0033 - Sick Bay - (9.67 SQM)	Student Space (4)	
B00A - R0034 - Movement - (63.01 SQM)	Not Applicable	Circulation or storage space.
B00A - R0035 - Home Base - (43.25 SQM) - Teaching Space: 1	Student Space (20)	
B00A - R0036 - Home Base - (43.68 SQM) - Teaching Space: 1	Student Space (20)	
B00A - R0037 - Movement - (65.23 SQM)	Not Applicable	Circulation or storage space.
B00A - R1001 - Staff Room - (12.68 SQM)	Office (3)	
B00A - R1005 - Movement - (25.79 SQM)	Not Applicable	Circulation or storage space.
B00A - R1006 - Communal Space - (99.37 SQM)	Student Space (46)	
B00A - R1007 - Movement - (12.1 SQM)	Not Applicable	Circulation or storage space.
B00A - R1011 - Deputy Principal - (12.11 SQM)	Office (3)	
B00A - R1015 - Staff Room - (32.74 SQM)	Office (8)	
B00A - R1016 - Practical Activities - 1hb - (15.73 SQM)	Student Space (7)	
B00A - R1017 - Special Programs Room - (43.82 SQM)	Student Space (20)	
B00A - R1020 - Home Base - (66.16 SQM)	Student Space (30)	
B00A - R1021 - Movement - (64.84 SQM)	Not Applicable	Circulation or storage space.
B00A - R1022 - Movement - (59.07 SQM)	Not Applicable	Circulation or storage space.
B00A - R1023 - Movement - (15 SQM)	Not Applicable	Circulation or storage space.
B00A - R1025 - Special Programs Room - Type 2 - (45.97 SQM)	Student Space (21)	
B00A - R1026 - Special Programs Room - (15.4 SQM)	Student Space (7)	
B00A - R1027 - Clerical Office - (12.31 SQM)	Office (3)	
B00A - R1028 - Duplicating Workroom - (14.51 SQM)	Office (3)	
B00A - R1029 - Staff Kitchen - (9.2 SQM)	Office (2)	
B00A - R1030 - Principal - (18.81 SQM)	Office (4)	
B00A - R1031 - Movement - (35.02 SQM)	Not Applicable	Circulation or storage space.
B00A - R1032 - Home Base - (42.91 SQM) - Teaching Space: 1	Student Space (19)	
B00A - R1033 - Home Base - (43.4 SQM) - Teaching Space: 1	Student Space (20)	
B00A - R9005 - Movement - (64.52 SQM)	Not Applicable	Circulation or storage space.
B00B - R0001 - Communal Space - (115.25 SQM)	Student Space (53)	
B00B - R0005 - Movement - (33.65 SQM)	Not Applicable	Circulation or storage space.
B00B - R0006 - Movement - (26.6 SQM)	Not Applicable	Circulation or storage space.
B00B - R0007 - Special Programs Room - (19.3 SQM)	Student Space (8)	