


VENTILATION AUDIT REPORT










SCHOOL:	Stockinbingal Public School (3109)
AMU REGION:	Southern NSW
STATE ELECTORATE:	Cootamundra
LOCAL GOVERNMENT AREA:	Cootamundra-Gundagai

3109 - Stockinbingal Public School
Site Plan (12434)



Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0002 - Reading Area - (44.04 SQM)	 Student Space (20)	
B00A - R0003 - Movement - (14.04 SQM)	Not Applicable	Circulation or storage space.
B00B - R0001 - Withdrawal Space - 1hb - (5.47 SQM)	 Student Space (2)	
B00B - R0003 - Home Base - (40.48 SQM) - Teaching Space: 1	 Student Space (18)	
B00B - R0004 - Practical Activities - 1hb - (10.47 SQM)	 Student Space (4)	
B00B - R0005 - Movement - (18.77 SQM)	Not Applicable	Circulation or storage space.
B00D - R0001 - Clerical Office - (14.63 SQM)	 Office (3)	
B00D - R0002 - Movement - (7.94 SQM)	Not Applicable	Circulation or storage space.
B00D - R0005 - Home Base - (73.3 SQM) - Teaching Space: 1	 Student Space (34)	
B00D - R0006 - Principal - (7.69 SQM)	 Office (1)	
B00D - R0007 - Movement - (11.3 SQM)	Not Applicable	Circulation or storage space.
B00G - R0001 - Reading Area - (59.86 SQM)	 Student Space (27)	
OS 505 12676 - OS 505 12676 - Admin Staff/Principal/Secure Store - (76 SQM)	 Office (19)	