


# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Strathfield Girls High School (8169)</b>
<b>AMU REGION:</b>	<b>South Western Sydney</b>
<b>STATE ELECTORATE:</b>	<b>Strathfield</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Strathfield</b>

8169 - Strathfield Girls High School  
Site Plan (11879)














## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0003 - Interview/Office - Type 1 - (12.69 SQM)	Office (3)	
B00A - R0004 - Clinic - Girls - (11.4 SQM)	Office (2)	
B00A - R0005 - Administration - Clerical - (40.41 SQM)	Office (10)	
B00A - R0006 - Interview/Office - Type 1 - (11.76 SQM)	Office (2)	
B00A - R0010 - Duplicating Workroom - (21.22 SQM)	Office (5)	
B00A - R0011 - General Learning Space - (45.28 SQM) - Teaching Space: 1	Student Space (21)	
B00A - R0012 - General Learning Space - (51.02 SQM) - Teaching Space: 1	Student Space (23)	
B00A - R0013 - Staff Study - (28.53 SQM)	Office (7)	
B00A - R0018 - General Learning Space - (49.41 SQM) - Teaching Space: 1	Student Space (22)	
B00A - R0019 - General Learning Space - (49.68 SQM) - Teaching Space: 1	Student Space (23)	
B00A - R0025 - Computer Learning Space - (49.69 SQM) - Teaching Space: 1	Student Space (23)	
B00A - R0026 - General Learning Space - (49.69 SQM) - Teaching Space: 1	Student Space (23)	
B00A - R0028 - General Assistants - (13.89 SQM)	Office (3)	
B00A - R0038 - Commonroom - (18.23 SQM)	Office (4)	
B00A - R0039 - Staff Study - (24.87 SQM)	Office (6)	
B00A - R0040 - Staff Kitchen - (15.68 SQM)	Office (3)	
B00A - R0042 - Commonroom - (91.54 SQM)	Office (22)	
B00A - R0044 - Interview/Office - Type 1 - (14.3 SQM)	Office (3)	
B00A - R0045 - Deputy Principal Office - (15.41 SQM)	Office (3)	
B00A - R0046 - Principal Office - (15.95 SQM)	Office (3)	
B00A - R0049 - Staff Kitchen - (15.04 SQM)	Office (3)	
B00A - R0058 - Movement - (9.23 SQM)	Not Applicable	Circulation or storage space.
B00A - R0065 - Movement - (16.06 SQM)	Not Applicable	Circulation or storage space.
B00A - R0066 - Movement - (12.62 SQM)	Not Applicable	Circulation or storage space.
B00A - R0067 - Public Entry - (60.93 SQM)	Not Applicable	Circulation or storage space.
B00A - R0068 - Movement - (27.99 SQM)	Not Applicable	Circulation or storage space.
B00A - R0069 - Movement - (373 SQM)	Not Applicable	Circulation or storage space.
B00A - R0070 - General Learning Space - (40.13 SQM) - Teaching Space: 1	Student Space (18)	
B00A - R1001 - General Learning Space - (57.29 SQM) - Teaching Space: 1	Student Space (26)	
B00A - R1003 - General Learning Space - (56.32 SQM) - Teaching Space: 1	Student Space (26)	
B00A - R1004 - Staff Study - (34.74 SQM)	Office (8)	
B00A - R1005 - General Learning Space - (49.05 SQM) - Teaching Space: 1	Student Space (22)	
B00A - R1006 - General Learning Space - (51.42 SQM) - Teaching Space: 1	Student Space (23)	
B00A - R1007 - General Learning Space - (55.56 SQM) - Teaching Space: 1	Student Space (25)	
B00A - R1008 - General Learning Space - (52.91 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1009 - General Learning Space - (47.26 SQM) - Teaching Space: 1	Student Space (21)	
B00A - R1010 - Movement - (410.4 SQM)	Not Applicable	Circulation or storage space.
B00A - R1013 - Staff Study - (20.86 SQM)	Office (5)	
B00A - R1016 - Staff Study - (36.82 SQM)	Office (9)	
B00A - R1020 - General Learning Space - (49.46 SQM) - Teaching Space: 1	Student Space (22)	
B00A - R1021 - General Learning Space - (49.47 SQM) - Teaching Space: 1	Student Space (22)	
B00A - R1025 - General Learning Space - (49.95 SQM) - Teaching Space: 1	Student Space (23)	
B00A - R1026 - General Learning Space - (49.42 SQM) - Teaching Space: 1	Student Space (22)	
B00A - R1027 - General Learning Space - (49.61 SQM) - Teaching Space: 1	Student Space (23)	
B00B - R0001 - Design L.S. - (67.7 SQM) - Teaching Space: 1	Student Space (31)	
B00B - R0004 - Design L.S. - (62.3 SQM) - Teaching Space: 1	Student Space (28)	
B00B - R0006 - Movement - (109.62 SQM)	Not Applicable	Circulation or storage space.
B00B - R0007 - Food/Research Space - (13.02 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00B - R0008 - Food/Research Space - (7.8 SQM)	Not Applicable	Circulation or storage space.
B00B - R0009 - Food Technology L.S. - (75.3 SQM) - Teaching Space: 1	● Student Space (34)	
B00B - R0011 - Design L.S. - (66.03 SQM) - Teaching Space: 1	● Student Space (30)	
B00B - R0012 - Study Space - (19.37 SQM)	Not Applicable	Circulation or storage space.
B00B - R0016 - Staff Study - (22.83 SQM)	○ Office (5)	
B00B - R0017 - Staff Kitchen - (10.41 SQM)	○ Office (2)	
B00B - R0020 - Food Technology L.S. - (66.04 SQM) - Teaching Space: 1	● Student Space (30)	
B00B - R0021 - Food/Research Space - (12.86 SQM)	Not Applicable	Circulation or storage space.
B00B - R0023 - Food Technology L.S. - (67.94 SQM) - Teaching Space: 1	● Student Space (31)	
B00B - R0024 - Movement - (7.54 SQM)	Not Applicable	Circulation or storage space.
B00B - R0025 - Movement - (21.23 SQM)	Not Applicable	Circulation or storage space.
B00C - M2001 - Seminar - (20.13 SQM)	○ Office (5)	
B00C - M2002 - Seminar - (18.49 SQM)	○ Office (4)	
B00C - M2006 - Study Space - (126.63 SQM)	Not Applicable	Circulation or storage space.
B00C - R0003 - Laboratory L.S. - (89.33 SQM) - Teaching Space: 1	● Student Space (41)	
B00C - R0006 - Laboratory L.S. - (89.34 SQM) - Teaching Space: 1	● Student Space (41)	
B00C - R0012 - Preparation - (48.4 SQM)	Not Applicable	Circulation or storage space.
B00C - R0013 - Laboratory L.S. - (89.33 SQM) - Teaching Space: 1	● Student Space (41)	
B00C - R0014 - Movement - (55.73 SQM)	Not Applicable	Circulation or storage space.
B00C - R0019 - Preparation - Science - (38.44 SQM)	Not Applicable	Circulation or storage space.
B00C - R0024 - Laboratory L.S. - (89.51 SQM) - Teaching Space: 1	● Student Space (41)	
B00C - R1002 - Laboratory L.S. - (89.22 SQM) - Teaching Space: 1	● Student Space (41)	
B00C - R1003 - Preparation - (47.72 SQM)	Not Applicable	Circulation or storage space.
B00C - R1004 - Laboratory L.S. - (89.6 SQM) - Teaching Space: 1	● Student Space (41)	
B00C - R1008 - Movement - (55.87 SQM)	Not Applicable	Circulation or storage space.
B00C - R1010 - Computer Learning Space - (73.18 SQM) - Teaching Space: 1	● Student Space (33)	
B00C - R1011 - General Learning Space - (64.99 SQM) - Teaching Space: 1	● Student Space (30)	
B00C - R1016 - Staff Study - (60.44 SQM)	○ Office (15)	
B00C - R1017 - Staff Kitchen - (10.5 SQM)	○ Office (2)	
B00C - R2001 - Seminar - (12.88 SQM)	○ Office (3)	
B00C - R2002 - Seminar - (12.84 SQM)	○ Office (3)	
B00C - R2007 - Workroom - (18.84 SQM)	○ Office (4)	
B00C - R2009 - Audio Visual Workroom - (29.63 SQM)	● Student Space (13)	
B00C - R2013 - Seminar - (12.21 SQM)	○ Office (3)	
B00C - R2022 - Seminar - (23.7 SQM)	○ Office (5)	
B00C - R2023 - Main Area - (375.85 SQM)	Not Applicable	Circulation or storage space.
B00D - R0002 - General Learning Space - (54.11 SQM) - Teaching Space: 1	● Student Space (25)	
B00D - R0003 - General Learning Space - (53.76 SQM) - Teaching Space: 1	● Student Space (24)	
B00D - R0005 - General Learning Space - (53.6 SQM) - Teaching Space: 1	● Student Space (24)	
B00D - R0006 - General Learning Space - (53.75 SQM) - Teaching Space: 1	● Student Space (24)	
B00E - R0001 - Gymnasium - (458.91 SQM)	● Student Space (212)	
B00E - R0002 - Movement - (8.69 SQM)	Not Applicable	Circulation or storage space.
B00E - R0005 - Staff Study - (16.03 SQM)	○ Office (4)	
B00E - R0007 - Movement - (8.81 SQM)	Not Applicable	Circulation or storage space.
B00E - R0008 - Movement - (8.43 SQM)	Not Applicable	Circulation or storage space.
B00E - R0012 - Movement - (8.43 SQM)	Not Applicable	Circulation or storage space.
B00F - R0006 - Art Learning Space - (59.41 SQM) - Teaching Space: 1	● Student Space (27)	
B00F - R0007 - Workshop - (52.29 SQM)	● Student Space (24)	
B00F - R0009 - Art Learning Space - (57.53 SQM) - Teaching Space: 1	● Student Space (26)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00F - R0011 - Art Learning Space - (58.89 SQM) - Teaching Space: 1	● Student Space (27)	
B00F - R0012 - Staff Study - (18.74 SQM)	● Office (4)	
B00F - R0013 - Movement - (124.33 SQM)	Not Applicable	Circulation or storage space.
B00F - R1001 - Senior Study - (60.67 SQM)	● Office (15)	
B00F - R1005 - Practice/Seminar - (24.47 SQM)	Not Applicable	Circulation or storage space.
B00F - R1006 - Music Learning Space - (59.03 SQM) - Teaching Space: 1	● Student Space (27)	
B00F - R1007 - Music Learning Space - (79.6 SQM) - Teaching Space: 1	● Student Space (36)	
B00F - R1009 - Darkroom Space - (26.74 SQM)	● Office (6)	
B00F - R1010 - Art Learning Space - (59.09 SQM) - Teaching Space: 1	● Student Space (27)	
B00F - R1011 - Staff Study - (18.67 SQM)	● Office (4)	
B00F - R1012 - Movement - (110.23 SQM)	Not Applicable	Circulation or storage space.
B00G - R0003 - Public Entry - (52.62 SQM)	Not Applicable	Circulation or storage space.
B00G - R0005 - Multi-Purpose Space - (257.78 SQM)	● Student Space (119)	
B00G - R0006 - Movement - (6.71 SQM)	Not Applicable	Circulation or storage space.
B00G - R0008 - Stage - (75.27 SQM)	Not Applicable	Circulation or storage space.
B00G - R0019 - Staff Kitchen - (18.12 SQM)	● Office (4)	
B00H - R0001 - General Learning Space - (47.08 SQM) - Teaching Space: 1	● Student Space (21)	
B00H - R0002 - Movement - (26.18 SQM)	Not Applicable	Circulation or storage space.
B00H - R0003 - General Learning Space - (47.4 SQM) - Teaching Space: 1	● Student Space (21)	
B00J - R0001 - Movement - (36.31 SQM)	Not Applicable	Circulation or storage space.
B00J - R0005 - General Learning Space - Type 1 - (59.05 SQM) - Teaching Space: 1	● Student Space (27)	
B00J - R0006 - Movement - (42.33 SQM)	Not Applicable	Circulation or storage space.
B00J - R0007 - General Learning Space - Type 1 - (59.28 SQM) - Teaching Space: 1	● Student Space (27)	
B00J - R0008 - Seminar - Type 1 - (24.15 SQM)	● Office (6)	
B00J - R0009 - Shared Learning Space - (49.64 SQM)	● Student Space (23)	
B00J - R0010 - General Learning Space - Type 1 - (59.68 SQM) - Teaching Space: 1	● Student Space (27)	
B00J - R0011 - General Learning Space - Type 1 - (59.6 SQM) - Teaching Space: 1	● Student Space (27)	
B00J - R0012 - Practical Activity Area - (47.19 SQM)	● Student Space (21)	
B00J - R0014 - Movement - (18.09 SQM)	Not Applicable	Circulation or storage space.
B00J - R0017 - General Learning Space - Type 2 - (63.74 SQM) - Teaching Space: 1	● Student Space (29)	
B00J - R0020 - General Learning Space - Type 2 - (63.66 SQM) - Teaching Space: 1	● Student Space (29)	
B00J - R0021 - Performance Workshop - (59.59 SQM)	● Student Space (27)	
B00J - R0022 - Performance Workshop - (59.67 SQM)	● Student Space (27)	
B00J - R0023 - Shared Learning Space - (49.48 SQM)	● Student Space (22)	
B00J - R0024 - Staff Study - (59.27 SQM)	● Office (14)	
B00J - R0025 - Movement - (47.05 SQM)	Not Applicable	Circulation or storage space.
B00J - R0026 - Seminar - Type 1 - (24.35 SQM)	● Office (6)	
B00J - R0029 - General Learning Space - Type 1 - (59.39 SQM) - Teaching Space: 1	● Student Space (27)	
B00J - R0031 - Student Canteen - (55.84 SQM)	Not Applicable	Circulation or storage space.
B00J - R1001 - Movement - (29.07 SQM)	Not Applicable	Circulation or storage space.
B00J - R1002 - General Learning Space - Type 1 - (63.7 SQM) - Teaching Space: 1	● Student Space (29)	
B00J - R1003 - Shared Learning Space - (23.64 SQM)	● Student Space (10)	
B00J - R1004 - Movement - (41.86 SQM)	Not Applicable	Circulation or storage space.
B00J - R1005 - Staff Study - (59.28 SQM)	● Office (14)	
B00J - R1006 - General Learning Space - Type 1 - (59.05 SQM) - Teaching Space: 1	● Student Space (27)	
B00J - R1007 - Seminar - Type 1 - (24.15 SQM)	● Office (6)	
B00J - R1008 - Shared Learning Space - (49.64 SQM)	● Student Space (23)	
B00J - R1009 - General Learning Space - Type 1 - (59.68 SQM) - Teaching Space: 1	● Student Space (27)	
B00J - R1010 - General Learning Space - Type 1 - (59.6 SQM) - Teaching Space: 1	● Student Space (27)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00J - R1011 - Practical Activity Area - (48.28 SQM)	 Student Space (22)	
B00J - R1012 - Movement - (18.98 SQM)	Not Applicable	Circulation or storage space.
B00J - R1014 - General Learning Space - Type 2 - (63.93 SQM) - Teaching Space: 1	 Student Space (29)	
B00J - R1017 - General Learning Space - Type 2 - (63.86 SQM) - Teaching Space: 1	 Student Space (29)	
B00J - R1018 - General Learning Space - Type 1 - (59.59 SQM) - Teaching Space: 1	 Student Space (27)	
B00J - R1019 - General Learning Space - Type 1 - (59.67 SQM) - Teaching Space: 1	 Student Space (27)	
B00J - R1020 - Shared Learning Space - (49.48 SQM)	 Student Space (22)	
B00J - R1021 - Seminar - Type 1 - (24.35 SQM)	 Office (6)	
B00J - R1022 - General Learning Space - Type 1 - (59.27 SQM) - Teaching Space: 1	 Student Space (27)	
B00J - R1023 - Movement - (47.19 SQM)	Not Applicable	Circulation or storage space.
B00J - R1025 - General Learning Space - Type 1 - (59.39 SQM) - Teaching Space: 1	 Student Space (27)	
B00J - R1027 - General Learning Space - Type 1 - (59.25 SQM) - Teaching Space: 1	 Student Space (27)	
B00J - R1028 - General Learning Space - Type 1 - (57.66 SQM) - Teaching Space: 1	 Student Space (26)	