

VENTILATION AUDIT REPORT

SCHOOL:	Strathfield North Public School (3123)
AMU REGION:	South Western Sydney
STATE ELECTORATE:	Drummoyne
LOCAL GOVERNMENT AREA:	Canada Bay

3123 - Strathfield North Public School
Site Plan (10779)



1:765

Printed: 09-Dec-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Movement - (117.44 SQM)	Not Applicable	Circulation or storage space.
B00A - R0002 - Principal - (19.53 SQM)	Office (4)	
B00A - R0003 - Entry Vestibule - (24.11 SQM)	Not Applicable	Circulation or storage space.
B00A - R0004 - Clerical Office/Workroom - (16.23 SQM)	Office (4)	
B00A - R0005 - Duplicating Workroom - (16.01 SQM)	Office (4)	
B00A - R0008 - Movement - (22.22 SQM)	Not Applicable	Circulation or storage space.
B00A - R0013 - Sick Bay - (12.32 SQM)	Student Space (5)	
B00A - R0015 - Deputy Principal - (12.6 SQM)	Office (3)	
B00A - R0020 - Entry Vestibule - (11.2 SQM)	Not Applicable	Circulation or storage space.
B00A - R0021 - Deputy Principal - (19.9 SQM)	Office (4)	
B00A - R0022 - Principal - (26.92 SQM)	Office (6)	
B00A - R1001 - Reading Area - (185.71 SQM)	Student Space (86)	
B00A - R1002 - Home Base - (52.56 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1003 - Movement - (23.83 SQM)	Not Applicable	Circulation or storage space.
B00A - R1006 - Movement - (25.76 SQM)	Not Applicable	Circulation or storage space.
B00A - R1013 - Clerical Office/Workroom - (25.9 SQM)	Office (6)	
B00B - R0002 - Withdrawal Space - 1hb - (9.05 SQM)	Student Space (4)	
B00B - R0003 - Movement - (70.57 SQM)	Not Applicable	Circulation or storage space.
B00B - R0004 - Movement - (35.75 SQM)	Not Applicable	Circulation or storage space.
B00B - R0005 - Movement - (37.14 SQM)	Not Applicable	Circulation or storage space.
B00B - R0006 - Staff Room Annexe - (9.85 SQM)	Office (2)	
B00B - R0007 - Home Base - (47.38 SQM) - Teaching Space: 1	Student Space (21)	
B00B - R0008 - Home Base - (47.29 SQM) - Teaching Space: 1	Student Space (21)	
B00B - R0009 - Home Base - (51.56 SQM) - Teaching Space: 1	Student Space (23)	
B00B - R0012 - Movement - (77.23 SQM)	Not Applicable	Circulation or storage space.
B00B - R0013 - Special Programs Room - (43.05 SQM)	Student Space (19)	
B00B - R0015 - Movement - (5.81 SQM)	Not Applicable	Circulation or storage space.
B00B - R0021 - Home Base - (50.19 SQM) - Teaching Space: 1	Student Space (23)	
B00B - R0022 - Home Base - (47.62 SQM) - Teaching Space: 1	Student Space (22)	
B00B - R0023 - Home Base - (47.8 SQM) - Teaching Space: 1	Student Space (22)	
B00B - R0024 - Home Base - (47.56 SQM) - Teaching Space: 1	Student Space (22)	
B00B - R0025 - Home Base - (47.56 SQM) - Teaching Space: 1	Student Space (22)	
B00G - R0001 - Home Base - (36.79 SQM) - Teaching Space: 1	Student Space (17)	
B00G - R0002 - Home Base - (47.2 SQM) - Teaching Space: 1	Student Space (21)	
B00G - R0003 - Home Base - (50.5 SQM) - Teaching Space: 1	Student Space (23)	
B00G - R0004 - Practical Activities - 1hb - (10.19 SQM)	Student Space (4)	
B00G - R0007 - Staff Room Annexe - (12.08 SQM)	Office (3)	
B00G - R0013 - Practical Activities - 1hb - (10.51 SQM)	Student Space (4)	
B00G - R0015 - Movement - (34.01 SQM)	Not Applicable	Circulation or storage space.
B00G - R0016 - Movement - (54.39 SQM)	Not Applicable	Circulation or storage space.
B00G - R0018 - Staff Room - (49.29 SQM)	Office (12)	
B00G - R0019 - Staff Kitchen - (17.65 SQM)	Office (4)	
B00G - R1001 - Special Programs Room - (49.08 SQM)	Student Space (22)	
B00G - R1002 - Home Base - (48.99 SQM) - Teaching Space: 1	Student Space (22)	
B00G - R1003 - Home Base - (65.17 SQM) - Teaching Space: 1	Student Space (30)	
B00G - R1004 - Movement - (57.33 SQM)	Not Applicable	Circulation or storage space.
B00G - R1005 - Practical Activities - 1hb - (21.72 SQM)	Student Space (10)	
B00H - R0007 - Movement - (6.53 SQM)	Not Applicable	Circulation or storage space.
B00H - R0009 - Raised Platform - (52.77 SQM)	Not Applicable	Circulation or storage space.
B00H - R0022 - Canteen - (30.46 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00H - R0025 - Communal Space - (210.65 SQM)	● Student Space (97)	
B00I - R0001 - Movement - (38.48 SQM)	Not Applicable	Circulation or storage space.
B00I - R0002 - Practical Activities - 1hb - (19.39 SQM)	● Student Space (8)	
B00I - R0004 - Home Base - (59.2 SQM) - Teaching Space: 1	● Student Space (27)	
B00I - R0005 - Withdrawal Space - 2hb - (11.36 SQM)	● Student Space (5)	
B00I - R0006 - Home Base - (59.2 SQM) - Teaching Space: 1	● Student Space (27)	
B00I - R0008 - Practical Activities - 1hb - (19.4 SQM)	● Student Space (9)	
B00K - R0002 - Practical Activities - 1hb - (19.3 SQM)	● Student Space (8)	
B00K - R0003 - Home Base - (60.6 SQM) - Teaching Space: 1	● Student Space (28)	
B00K - R0005 - Withdrawal Space - 1hb - (11.7 SQM)	● Student Space (5)	
B00K - R0006 - Home Base - (60.6 SQM) - Teaching Space: 1	● Student Space (28)	
B00K - R0008 - Practical Activities - 2hb - (18.51 SQM)	● Student Space (8)	
B00K - R0016 - Practical Activities - 1hb - (18.2 SQM)	● Student Space (8)	
B00K - R0017 - Home Base - (56.14 SQM) - Teaching Space: 1	● Student Space (26)	
B00K - R0019 - Staff Room - (7.66 SQM)	● Office (1)	
B00K - R1002 - Practical Activities - (19.26 SQM)	● Student Space (8)	
B00K - R1003 - Home Base - (60.45 SQM) - Teaching Space: 1	● Student Space (28)	
B00K - R1005 - Withdrawal Space - 2hb - (11.78 SQM)	● Student Space (5)	
B00K - R1006 - Home Base - (60.67 SQM) - Teaching Space: 1	● Student Space (28)	
B00K - R1008 - Practical Activities - 4hb - (19.24 SQM)	● Student Space (8)	
B00K - R1009 - Practical Activities - 3hb - (18.62 SQM)	● Student Space (8)	
B00K - R1010 - Home Base - (58.47 SQM) - Teaching Space: 1	● Student Space (27)	
B00K - R1011 - Isolation Space - (7.66 SQM)	● Office (1)	
OS 601 12333 - OS 601 12333 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 13102 - OS 601 13102 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 14252 - OS 601 14252 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 602 12630 - OS 602 12630 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 14459 - OS 602 14459 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 603 14496 - OS 603 14496 - Learning Unit - Standard With P.A.A. A/C - (76 SQM)	● Student Space (35)	