

VENTILATION AUDIT REPORT

SCHOOL:	Stroud Public School (3125)
AMU REGION:	North Coast
STATE ELECTORATE:	Upper Hunter
LOCAL GOVERNMENT AREA:	Mid-Coast

3125 - Stroud Public School
Site Plan (11786)



Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0003 - Movement - (20.38 SQM)	Not Applicable	Circulation or storage space.
B00A - R0008 - Canteen - (19.01 SQM)	Not Applicable	Circulation or storage space.
B00B - R0002 - Home Base - (41.14 SQM) - Teaching Space: 1	● Student Space (19)	
B00B - R0003 - Raised Platform - (16.53 SQM)	Not Applicable	Circulation or storage space.
B00B - R0004 - Communal Space - (75.69 SQM)	● Student Space (35)	
B00B - R0008 - Practical Activities - 1hb - (22.02 SQM)	● Student Space (10)	
B00G - R0002 - Home Base - (53.15 SQM) - Teaching Space: 1	● Student Space (24)	
B00G - R0003 - Home Base - (53.37 SQM) - Teaching Space: 1	● Student Space (24)	
B00G - R0004 - Special Programs Room - (66.8 SQM)	● Student Space (30)	
B00G - R0005 - Staff Room - (26.68 SQM)	● Office (6)	
B00H - R0002 - Home Base - (57.88 SQM) - Teaching Space: 1	● Student Space (26)	
B00H - R0004 - Withdrawal Space - 1hb - (10.76 SQM)	● Student Space (4)	
B00H - R0005 - Movement - (7.81 SQM)	Not Applicable	Circulation or storage space.
B00H - R0006 - Home Base - (57.64 SQM) - Teaching Space: 1	● Student Space (26)	
B00H - R0008 - Entry Vestibule - (13.74 SQM)	Not Applicable	Circulation or storage space.
B00H - R0010 - Principal - (8.96 SQM)	● Office (2)	
B00H - R0011 - Clerical Office - (17.71 SQM)	● Office (4)	
B00K - R0002 - Clerical Office - (19.07 SQM)	● Office (4)	
B00K - R0004 - Sick Bay - (7.58 SQM)	● Student Space (3)	
B00K - R0006 - Movement - (5.4 SQM)	Not Applicable	Circulation or storage space.
B00K - R0008 - Staff Room - (21.38 SQM)	● Office (5)	
B00K - R0009 - Staff Kitchen - (5.19 SQM)	● Office (1)	
B00K - R0011 - Principal - (17.13 SQM)	● Office (4)	
B00K - R0012 - Reading Area - (71.83 SQM)	● Student Space (33)	