

# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Sturt Public School (4457)</b>
<b>AMU REGION:</b>	<b>Southern NSW</b>
<b>STATE ELECTORATE:</b>	<b>Wagga Wagga</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Wagga Wagga</b>

4457 - Sturt Public School  
Site Plan (11960)



1:1,168

Printed: 13-Apr-2021

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Movement - (154.37 SQM)	Not Applicable	Circulation or storage space.
B00A - R0002 - Staff Room - (85.47 SQM)	Office (21)	
B00A - R0006 - Deputy Principal - (17.46 SQM)	Office (4)	
B00A - R0007 - Principal - (27.56 SQM)	Office (6)	
B00A - R0008 - Staff Room Annexe - (12.11 SQM)	Office (3)	
B00A - R0010 - Clerical Office - (12.08 SQM)	Office (3)	
B00A - R0011 - Entry Vestibule - (10.67 SQM)	Not Applicable	Circulation or storage space.
B00A - R0012 - Interview - (19.24 SQM)	Office (4)	
B00A - R0017 - Staff Room Annexe - (12 SQM)	Office (3)	
B00A - R0020 - Movement - (49.57 SQM)	Not Applicable	Circulation or storage space.
B00A - R0022 - Duplicating Workroom - (19.78 SQM)	Office (4)	
B00B - R0001 - Movement - (178.98 SQM)	Not Applicable	Circulation or storage space.
B00B - R0002 - Home Base - (88.41 SQM) - Teaching Space: 1	Student Space (41)	
B00B - R0003 - Practical Activities - 1hb - (9.88 SQM)	Student Space (4)	
B00B - R0006 - Home Base - (59.2 SQM) - Teaching Space: 1	Student Space (27)	
B00B - R0007 - Practical Activities - 1hb - (12.49 SQM)	Student Space (5)	
B00B - R0008 - Movement - (15.81 SQM)	Not Applicable	Circulation or storage space.
B00B - R0014 - Home Base - (99.58 SQM) - Teaching Space: 1	Student Space (46)	
B00B - R0016 - Home Base - (98.83 SQM) - Teaching Space: 1	Student Space (45)	
B00B - R0018 - Movement - (45.51 SQM)	Not Applicable	Circulation or storage space.
B00B - R0023 - Movement - (16.14 SQM)	Not Applicable	Circulation or storage space.
B00C - R0001 - Movement - (364.39 SQM)	Not Applicable	Circulation or storage space.
B00C - R0002 - Home Base - (72.26 SQM) - Teaching Space: 1	Student Space (33)	
B00C - R0003 - Home Base - (72.92 SQM) - Teaching Space: 1	Student Space (33)	
B00C - R0004 - Movement - (21.96 SQM)	Not Applicable	Circulation or storage space.
B00C - R0011 - Practical Activities - 1hb - (14.82 SQM)	Student Space (6)	
B00C - R0012 - Home Base - (57.92 SQM) - Teaching Space: 1	Student Space (26)	
B00C - R0013 - Home Base - (57.67 SQM) - Teaching Space: 1	Student Space (26)	
B00C - R0014 - Practical Activities - 1hb - (14.35 SQM)	Student Space (6)	
B00C - R0015 - Movement - (28.97 SQM)	Not Applicable	Circulation or storage space.
B00C - R0021 - Movement - (21.89 SQM)	Not Applicable	Circulation or storage space.
B00C - R0022 - Practical Activities - 1hb - (13.38 SQM)	Student Space (6)	
B00C - R0023 - Home Base - (58.96 SQM) - Teaching Space: 1	Student Space (27)	
B00C - R0033 - Collaboration Space - (135.55 SQM)	Student Space (62)	
B00C - R0034 - Outdoor Learning Area - (159.87 SQM)	Not Applicable	Circulation or storage space.
B00D - R0001 - Movement - (154.71 SQM)	Not Applicable	Circulation or storage space.
B00D - R0002 - Practical Activities - 1hb - (17.35 SQM)	Student Space (8)	
B00D - R0003 - Home Base - (51.35 SQM) - Teaching Space: 1	Student Space (23)	
B00D - R0004 - Movement - (28.84 SQM)	Not Applicable	Circulation or storage space.
B00D - R0012 - Movement - (14.05 SQM)	Not Applicable	Circulation or storage space.
B00D - R0013 - Practical Activities - 1hb - (17.51 SQM)	Student Space (8)	
B00D - R0014 - Home Base - (52.28 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R0016 - Movement - (10.18 SQM)	Not Applicable	Circulation or storage space.
B00D - R0017 - Home Base - (52.2 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R0018 - Practical Activities - 1hb - (17.51 SQM)	Student Space (8)	
B00D - R0024 - Movement - (28.99 SQM)	Not Applicable	Circulation or storage space.
B00D - R0025 - Practical Activities - 1hb - (18.07 SQM)	Student Space (8)	
B00D - R0026 - Home Base - (50.6 SQM) - Teaching Space: 1	Student Space (23)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00D - R0029 - Collaboration Space - (115.93 SQM)	● Student Space (53)	
B00D - R0030 - Movement - (123.05 SQM)	Not Applicable	Circulation or storage space.
B00E - R0001 - Movement - (199.36 SQM)	Not Applicable	Circulation or storage space.
B00E - R0002 - Practical Activities - 1hb - (17.32 SQM)	● Student Space (8)	
B00E - R0003 - Home Base - (51.82 SQM) - Teaching Space: 1	● Student Space (24)	
B00E - R0009 - Withdrawal Space - 1hb - (10.66 SQM)	● Student Space (4)	
B00E - R0010 - Movement - (21.27 SQM)	Not Applicable	Circulation or storage space.
B00E - R0011 - Practical Activities - 1hb - (17.45 SQM)	● Student Space (8)	
B00E - R0012 - Home Base - (51.8 SQM) - Teaching Space: 1	● Student Space (24)	
B00E - R0013 - Home Base - (52.27 SQM) - Teaching Space: 1	● Student Space (24)	
B00E - R0014 - Practical Activities - 1hb - (17.53 SQM)	● Student Space (8)	
B00E - R0015 - Movement - (17.86 SQM)	Not Applicable	Circulation or storage space.
B00E - R0020 - Home Base - (51.81 SQM) - Teaching Space: 1	● Student Space (24)	
B00E - R0021 - Practical Activities - 1hb - (17.35 SQM)	● Student Space (8)	
B00E - R0031 - Collaboration Space - (103.22 SQM)	● Student Space (47)	
B00E - R0032 - Movement - (167.4 SQM)	Not Applicable	Circulation or storage space.
B00F - R0001 - Movement - (170.24 SQM)	Not Applicable	Circulation or storage space.
B00F - R0002 - Reading Area - (263.08 SQM)	● Student Space (122)	
B00F - R0003 - Movement - (12.05 SQM)	Not Applicable	Circulation or storage space.
B00F - R0011 - Seminar/Study - (13.02 SQM)	● Office (3)	
B00F - R0012 - Seminar/Study - (12.97 SQM)	● Office (3)	
B00G - R0001 - Movement - (189.56 SQM)	Not Applicable	Circulation or storage space.
B00G - R0002 - Communal Space - (236.58 SQM)	● Student Space (109)	
B00G - R0004 - Raised Platform - (81.22 SQM)	Not Applicable	Circulation or storage space.
B00G - R0010 - Canteen - (49.01 SQM)	Not Applicable	Circulation or storage space.
B00H - R0001 - Movement - (20.67 SQM)	Not Applicable	Circulation or storage space.
B00H - R0006 - Withdrawal Space - 1hb - (27.07 SQM)	● Student Space (12)	
B00H - R0009 - Movement - (16.2 SQM)	Not Applicable	Circulation or storage space.
B00I - R0001 - Special Programs Room - (32.36 SQM)	● Student Space (15)	