

# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Sussex Inlet Public School (3659)</b>
<b>AMU REGION:</b>	<b>Southern NSW</b>
<b>STATE ELECTORATE:</b>	<b>South Coast</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Shoalhaven</b>

3659 - Sussex Inlet Public School  
Site Plan (13490)











1:947

Printed: 21-Mar-2020

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Staff Room Annexe - (19.13 SQM)	Office (4)	
B00A - R0002 - Staff Room - (44.92 SQM)	Office (11)	
B00A - R0003 - Staff Room Annexe - (13.01 SQM)	Office (3)	
B00A - R0004 - Staff Room Annexe - (13.01 SQM)	Office (3)	
B00A - R0006 - Interview - (11.86 SQM)	Office (2)	
B00A - R0009 - Sick Bay - (8.49 SQM)	Student Space (3)	
B00A - R0010 - Clerical Office - (17.4 SQM)	Office (4)	
B00A - R0011 - Movement - (42.54 SQM)	Not Applicable	Circulation or storage space.
B00A - R0012 - Duplicating Workroom - (19.51 SQM)	Office (4)	
B00A - R0013 - Principal - (16.58 SQM)	Office (4)	
B00B - R0001 - Canteen - (26.41 SQM)	Not Applicable	Circulation or storage space.
B00B - R0015 - Communal Space - (153.67 SQM)	Student Space (71)	
B00B - R0016 - Raised Platform - (51.06 SQM)	Not Applicable	Circulation or storage space.
B00C - R0003 - Practical Activities - 1hb - (22.98 SQM)	Student Space (10)	
B00C - R0004 - Home Base - (54.72 SQM) - Teaching Space: 1	Student Space (25)	
B00C - R0006 - Withdrawal Space - 1hb - (5.31 SQM)	Student Space (2)	
B00C - R0009 - Practical Activities - 1hb - (22.97 SQM)	Student Space (10)	
B00C - R0010 - Home Base - (54.82 SQM) - Teaching Space: 1	Student Space (25)	
B00C - R0012 - Withdrawal Space - 1hb - (5.42 SQM)	Student Space (2)	
B00C - R0014 - Practical Activities - 1hb - (22.94 SQM)	Student Space (10)	
B00C - R0015 - Home Base - (54.76 SQM) - Teaching Space: 1	Student Space (25)	
B00C - R0017 - Withdrawal Space - 1hb - (5.44 SQM)	Student Space (2)	
B00C - R0019 - Practical Activities - 1hb - (23.06 SQM)	Student Space (10)	
B00C - R0020 - Home Base - (54.46 SQM) - Teaching Space: 1	Student Space (25)	
B00C - R0022 - Withdrawal Space - 1hb - (5.32 SQM)	Student Space (2)	
B00D - R0007 - Practical Activities - 1hb - (20.43 SQM)	Student Space (9)	
B00D - R0009 - Home Base - (55.15 SQM) - Teaching Space: 1	Student Space (25)	
B00D - R0011 - Withdrawal Space - 1hb - (5.36 SQM)	Student Space (2)	
B00D - R0014 - Practical Activities - 1hb - (22.27 SQM)	Student Space (10)	
B00D - R0015 - Home Base - (52.08 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R0018 - Withdrawal Space - 1hb - (5.43 SQM)	Student Space (2)	
B00D - R0020 - Practical Activities - 1hb - (22.84 SQM)	Student Space (10)	
B00D - R0021 - Home Base - (54.93 SQM) - Teaching Space: 1	Student Space (25)	
B00D - R0023 - Withdrawal Space - 1hb - (5.41 SQM)	Student Space (2)	
B00D - R0025 - Practical Activities - 1hb - (22.65 SQM)	Student Space (10)	
B00D - R0026 - Home Base - (54.87 SQM) - Teaching Space: 1	Student Space (25)	
B00D - R0028 - Withdrawal Space - 1hb - (5.43 SQM)	Student Space (2)	
B00D - R0030 - Practical Activities - 1hb - (22.37 SQM)	Student Space (10)	
B00D - R0031 - Home Base - (55.26 SQM) - Teaching Space: 1	Student Space (25)	
B00D - R0033 - Withdrawal Space - 1hb - (5.41 SQM)	Student Space (2)	
B00D - R0035 - Practical Activities - 1hb - (22.31 SQM)	Student Space (10)	
B00D - R0036 - Home Base - (55.22 SQM) - Teaching Space: 1	Student Space (25)	
B00D - R0038 - Withdrawal Space - 1hb - (5.26 SQM)	Student Space (2)	
B00E - R0001 - Reading Area - (139.87 SQM)	Student Space (64)	
B00E - R0012 - Special Programs Room - (101.09 SQM)	Student Space (46)	
B00E - R0014 - Seminar/Study - (11.12 SQM)	Office (2)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00E - R0015 - Seminar/Study - (10.79 SQM)	 Office (2)	
B00G - R0001 - Special Programs Room - (81.08 SQM)	 Student Space (37)	
B00H - R0004 - Special Programs Room - (33.77 SQM)	 Student Space (15)	
B00H - R0005 - Movement - (5.58 SQM)	Not Applicable	Circulation or storage space.
B00H - R0006 - Practical Activities - 1hb - (19.03 SQM)	 Student Space (8)	
B00H - R0008 - Home Base - (60.87 SQM) - Teaching Space: 1	 Student Space (28)	
B00H - R0009 - Withdrawal Space - 2hb - (11.78 SQM)	 Student Space (5)	
B00H - R0010 - Home Base - (60.77 SQM) - Teaching Space: 1	 Student Space (28)	
B00H - R0012 - Practical Activities - 1hb - (19.15 SQM)	 Student Space (8)	