

VENTILATION AUDIT REPORT

SCHOOL:	Sutherland North Public School (3822)
AMU REGION:	Sydney
STATE ELECTORATE:	Heathcote
LOCAL GOVERNMENT AREA:	Sutherland

3822 - Sutherland North Public School
Site Plan (11721)


























1:835

Printed: 21-Mar-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0004 - Home Base - (57.62 SQM) - Teaching Space: 1	 Student Space (26)	
B00A - R0011 - Home Base - (56.89 SQM) - Teaching Space: 1	 Student Space (26)	
B00A - R0015 - Home Base - (57.31 SQM) - Teaching Space: 1	 Student Space (26)	
B00B - R0002 - Home Base - (54.03 SQM) - Teaching Space: 1	 Student Space (25)	
B00B - R0003 - Home Base - (54.04 SQM) - Teaching Space: 1	 Student Space (25)	
B00B - R0004 - Movement - (29.04 SQM)	Not Applicable	Circulation or storage space.
B00C - R0002 - Home Base - (50.47 SQM) - Teaching Space: 1	 Student Space (23)	
B00C - R0003 - Home Base - (52.57 SQM) - Teaching Space: 1	 Student Space (24)	
B00D - R0002 - Home Base - (91.46 SQM) - Teaching Space: 1	 Student Space (42)	
B00D - R0004 - Staff Room Annexe - (17.09 SQM)	 Office (4)	
B00D - R0017 - Sick Bay - (13.55 SQM)	 Student Space (6)	
B00D - R0019 - Movement - (26.96 SQM)	Not Applicable	Circulation or storage space.
B00E - R0002 - Practical Activities - 1hb - (12.7 SQM)	 Student Space (5)	
B00E - R0003 - Home Base - (47.25 SQM) - Teaching Space: 1	 Student Space (21)	
B00E - R0004 - Home Base - (46.92 SQM) - Teaching Space: 1	 Student Space (21)	
B00E - R0005 - Movement - (12.7 SQM)	Not Applicable	Circulation or storage space.
B00F - R0002 - Reading Area - (158.86 SQM)	 Student Space (73)	
B00Y - R0001 - Raised Platform - (60.12 SQM)	Not Applicable	Circulation or storage space.
B00Y - R0002 - Communal Space - (147.16 SQM)	 Student Space (68)	
B00Y - R0015 - Movement - (12.64 SQM)	Not Applicable	Circulation or storage space.
B00Y - R0017 - Movement - (10.94 SQM)	Not Applicable	Circulation or storage space.
B00Y - R0018 - Movement - (6.42 SQM)	Not Applicable	Circulation or storage space.
B00Z - R0007 - Home Base - (56.97 SQM) - Teaching Space: 1	 Student Space (26)	
B00Z - R0008 - Home Base - (56.98 SQM) - Teaching Space: 1	 Student Space (26)	
B00Z - R0017 - Clerical Office - (14.55 SQM)	 Office (3)	
B00Z - R0018 - Clerical Office - (6.64 SQM)	 Office (1)	
B00Z - R0019 - Staff Room - (31.74 SQM)	 Office (7)	
B00Z - R0020 - Staff Kitchen - (11.86 SQM)	 Office (2)	
B00Z - R0025 - Movement - (11.66 SQM)	Not Applicable	Circulation or storage space.
B00Z - R0026 - Clerical/Printing - (11.34 SQM)	Not Applicable	Circulation or storage space.
B00Z - R0027 - Entry Vestibule - (13.58 SQM)	Not Applicable	Circulation or storage space.
B00Z - R0028 - Sick Bay - (6.5 SQM)	 Student Space (3)	
B00Z - R0029 - Clerical Office - (21.21 SQM)	 Office (5)	