

VENTILATION AUDIT REPORT

SCHOOL:	Sutherland Public School (3136)
AMU REGION:	Sydney
STATE ELECTORATE:	Heathcote
LOCAL GOVERNMENT AREA:	Sutherland

3136 - Sutherland Public School
Site Plan (11321)



1:766

Printed: 21-Mar-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0008 - Communal Space - (113.68 SQM)	● Student Space (52)	
B00A - R0009 - Raised Platform - (21.39 SQM)	Not Applicable	Circulation or storage space.
B00A - R0010 - Duplicating Workroom - (7.97 SQM)	● Office (1)	
B00A - R0021 - Deputy Principal - (10.44 SQM)	● Office (2)	
B00A - R0022 - Clerical/Printing - (47.09 SQM)	Not Applicable	Circulation or storage space.
B00A - R0023 - Staff Kitchen - (8.83 SQM)	● Office (2)	
B00A - R0024 - Staff Room - (37.81 SQM)	● Office (9)	
B00A - R0025 - Special Programs Room - (47.09 SQM)	● Student Space (21)	
B00A - R0026 - Home Base - (47.09 SQM) - Teaching Space: 1	● Student Space (21)	
B00A - R0027 - Home Base - (47.6 SQM) - Teaching Space: 1	● Student Space (22)	
B00A - R0028 - Movement - (63.02 SQM)	Not Applicable	Circulation or storage space.
B00A - R0029 - Movement - (38.05 SQM)	Not Applicable	Circulation or storage space.
B00A - R0031 - Principal - (15.35 SQM)	● Office (3)	
B00A - R1008 - Staff Room Annexe - (20.48 SQM)	● Office (5)	
B00A - R1015 - Home Base - (49.75 SQM) - Teaching Space: 1	● Student Space (23)	
B00A - R1016 - Home Base - (49.15 SQM) - Teaching Space: 1	● Student Space (22)	
B00A - R1017 - Home Base - (49.15 SQM) - Teaching Space: 1	● Student Space (22)	
B00A - R1018 - Home Base - (77.55 SQM) - Teaching Space: 1	● Student Space (35)	
B00A - R1020 - Movement - (90.17 SQM)	Not Applicable	Circulation or storage space.
B00A - R1022 - Practical Activity Area - (28.39 SQM)	● Student Space (13)	
B00A - R9003 - Movement - (19.36 SQM)	Not Applicable	Circulation or storage space.
B00B - R0001 - Home Base - (46.89 SQM) - Teaching Space: 1	● Student Space (21)	
B00B - R0002 - Home Base - (46.02 SQM) - Teaching Space: 1	● Student Space (21)	
B00B - R0003 - Home Base - (45.69 SQM) - Teaching Space: 1	● Student Space (21)	
B00B - R0004 - Home Base - (46.55 SQM) - Teaching Space: 1	● Student Space (21)	
B00B - R0005 - Reading Area - (46.55 SQM)	● Student Space (21)	
B00B - R0010 - Movement - (59.73 SQM)	Not Applicable	Circulation or storage space.
B00B - R0013 - Movement - (73.15 SQM)	Not Applicable	Circulation or storage space.
B00B - R0014 - Home Base - (51.92 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R0015 - Home Base - (52.26 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R0016 - Staff Room Annexe - (12.63 SQM)	● Office (3)	
B00B - R0022 - Reading Area - (142.06 SQM)	● Student Space (65)	
B00D - R0006 - Practical Activities - 1hb - (19.01 SQM)	● Student Space (8)	
B00D - R0007 - Withdrawal Space - 1hb - (27.39 SQM)	● Student Space (12)	
B00D - R0008 - Home Base - (46.53 SQM) - Teaching Space: 1	● Student Space (21)	
B00E - R0003 - Practical Activities - 1hb - (19.01 SQM)	● Student Space (8)	
B00E - R0004 - Home Base - (75.19 SQM) - Teaching Space: 1	● Student Space (34)	
B00J - R0001 - Movement - (13.54 SQM)	Not Applicable	Circulation or storage space.
B00J - R0004 - Canteen - (17.47 SQM)	Not Applicable	Circulation or storage space.