

VENTILATION AUDIT REPORT

SCHOOL:	Swansea High School (8389)
AMU REGION:	Hunter/Central Coast
STATE ELECTORATE:	Swansea
LOCAL GOVERNMENT AREA:	Lake Macquarie

8389 - Swansea High School
Site Plan (10926)



1:1,797
















Printed: 21-Mar-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0007 - Administration - Clerical - (9.14 SQM)	Office (2)	
B00A - R0008 - Duplicating Workroom - (19.43 SQM)	Office (4)	
B00A - R0009 - Seminar - (13.21 SQM)	Office (3)	
B00A - R0013 - Administration - Clerical - (9.55 SQM)	Office (2)	
B00A - R0016 - Principal Office - (21.2 SQM)	Office (5)	
B00A - R0017 - Administration - Clerical - (27.83 SQM)	Office (6)	
B00A - R0020 - Deputy Principal Office - (19.01 SQM)	Office (4)	
B00A - R0029 - Staff Study - (20.17 SQM)	Office (5)	
B00A - R0031 - Food Technology L.S. - (78.89 SQM) - Teaching Space: 1	Student Space (36)	
B00A - R0033 - Food Technology L.S. - (66.11 SQM) - Teaching Space: 1	Student Space (30)	
B00A - R0037 - Art Learning Space - (66.26 SQM) - Teaching Space: 1	Student Space (30)	
B00A - R0039 - Clinic - Boys - (19.5 SQM)	Office (4)	
B00A - R0040 - Movement - (143.6 SQM)	Not Applicable	Circulation or storage space.
B00A - R0043 - Staff Study - (26.29 SQM)	Office (6)	
B00A - R0044 - Staff Study - (25.8 SQM)	Office (6)	
B00A - R0045 - Staff Study - (25.9 SQM)	Office (6)	
B00A - R0046 - General Learning Space - (60.02 SQM) - Teaching Space: 1	Student Space (27)	
B00A - R0047 - Staff Study - (12.34 SQM)	Office (3)	
B00A - R0048 - Staff Study - (12.3 SQM)	Office (3)	
B00A - R0049 - Computer Learning Space - (87.99 SQM) - Teaching Space: 1	Student Space (40)	
B00A - R0050 - Movement - (5.38 SQM)	Not Applicable	Circulation or storage space.
B00A - R0052 - General Learning Space - (59.46 SQM) - Teaching Space: 1	Student Space (27)	
B00A - R0054 - Design L.S. - (52.82 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R0057 - Design L.S. - (66.44 SQM) - Teaching Space: 1	Student Space (30)	
B00A - R0060 - Movement - (5.48 SQM)	Not Applicable	Circulation or storage space.
B00A - R0062 - Movement - (160.38 SQM)	Not Applicable	Circulation or storage space.
B00A - R0066 - Staff Study - (33.29 SQM)	Office (8)	
B00A - R0067 - Laboratory L.S. - (79.12 SQM) - Teaching Space: 1	Student Space (36)	
B00A - R0068 - Preparation - (18.85 SQM)	Not Applicable	Circulation or storage space.
B00A - R0069 - Workroom - (52.52 SQM)	Office (13)	
B00A - R0070 - Workroom - (52.53 SQM)	Office (13)	
B00A - R0072 - Administration - Clerical - (24.69 SQM)	Office (6)	
B00A - R0074 - Public Reception - (28.52 SQM)	Not Applicable	Circulation or storage space.
B00A - R0075 - Movement - (50.06 SQM)	Not Applicable	Circulation or storage space.
B00A - R0084 - Movement - (8.65 SQM)	Not Applicable	Circulation or storage space.
B00A - R1004 - Staff Study - (26.45 SQM)	Office (6)	
B00A - R1009 - General Learning Space - (52.82 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1010 - General Learning Space - (52.35 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1011 - General Learning Space - (52.74 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1012 - General Learning Space - (52.66 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1013 - Staff Study - (26.45 SQM)	Office (6)	
B00A - R1019 - General Learning Space - (53.03 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1020 - General Learning Space - (52.82 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1028 - Staff Study - (26.15 SQM)	Office (6)	
B00A - R1029 - General Learning Space - (52.67 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1030 - General Learning Space - (52.68 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1039 - General Learning Space - (54.14 SQM) - Teaching Space: 1	Student Space (25)	
B00A - R1040 - General Learning Space - (52.68 SQM) - Teaching Space: 1	Student Space (24)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R1041 - General Learning Space - (52.68 SQM) - Teaching Space: 1	● Student Space (24)	
B00A - R1042 - Computer Learning Space - (54.5 SQM) - Teaching Space: 1	● Student Space (25)	
B00A - R1047 - Commonroom - (101.19 SQM)	● Office (25)	
B00A - R1048 - Staff Study - (52.74 SQM)	● Office (13)	
B00A - R1049 - Staff Study - (54.27 SQM)	● Office (13)	
B00A - R1050 - Workroom - (52.53 SQM)	● Office (13)	
B00A - R1051 - Movement - (9.12 SQM)	Not Applicable	Circulation or storage space.
B00A - R1053 - General Learning Space - (54.03 SQM) - Teaching Space: 1	● Student Space (25)	
B00A - R1056 - Movement - (15.9 SQM)	Not Applicable	Circulation or storage space.
B00A - R1058 - Movement - (163.59 SQM)	Not Applicable	Circulation or storage space.
B00A - R1064 - Movement - (16.05 SQM)	Not Applicable	Circulation or storage space.
B00A - R1065 - Performance Workshop - (117.47 SQM)	● Student Space (54)	
B00A - R1066 - Movement - (40.8 SQM)	Not Applicable	Circulation or storage space.
B00A - R1067 - Movement - (101.11 SQM)	Not Applicable	Circulation or storage space.
B00A - R9001 - Darkroom Space - (20.91 SQM)	● Office (5)	
B00B - R0006 - Materials Technology L.S. - (79.55 SQM) - Teaching Space: 1	● Student Space (36)	
B00B - R0011 - Workshop - (71.57 SQM)	● Student Space (33)	
B00B - R0013 - Darkroom Space - (31.49 SQM)	● Office (7)	
B00B - R0017 - Art Learning Space - (83.2 SQM) - Teaching Space: 1	● Student Space (38)	
B00B - R0019 - Design L.S. - (53.04 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R0025 - Staff Study - (42.72 SQM)	● Office (10)	
B00B - R0029 - Movement - (138.28 SQM)	Not Applicable	Circulation or storage space.
B00B - R0038 - Materials Technology L.S. - (107.9 SQM) - Teaching Space: 1	● Student Space (50)	
B00B - R0040 - Movement - (11.33 SQM)	Not Applicable	Circulation or storage space.
B00B - R0045 - Wood Technology Bay - (43.53 SQM)	Not Applicable	Circulation or storage space.
B00B - R0047 - Materials Technology L.S. - (68.01 SQM) - Teaching Space: 1	● Student Space (31)	
B00B - R0049 - Design L.S. - (85.24 SQM) - Teaching Space: 1	● Student Space (39)	
B00B - R0050 - Workshop Area - (25.42 SQM)	● Student Space (11)	
B00B - R0053 - Metal Technology Bay - (53.57 SQM)	Not Applicable	Circulation or storage space.
B00B - R0054 - Wood Technology Bay - (141.83 SQM)	Not Applicable	Circulation or storage space.
B00C - R0005 - Student Canteen - (15.4 SQM)	Not Applicable	Circulation or storage space.
B00C - R0006 - Staff Study - (15.73 SQM)	● Office (3)	
B00C - R0014 - Movement - (67.47 SQM)	Not Applicable	Circulation or storage space.
B00C - R0015 - Multi-Purpose Space - (516.96 SQM)	● Student Space (239)	
B00D - R0006 - Student Canteen - (45.11 SQM)	Not Applicable	Circulation or storage space.
B00D - R0013 - Movement - (15.25 SQM)	Not Applicable	Circulation or storage space.
B00D - R0014 - Movement - (181.79 SQM)	Not Applicable	Circulation or storage space.
B00D - R0015 - Movement - (15.05 SQM)	Not Applicable	Circulation or storage space.
B00E - M1001 - Staff Study - (15.59 SQM)	● Office (3)	
B00E - M1002 - Study Space - (67.62 SQM)	Not Applicable	Circulation or storage space.
B00E - M1003 - Seminar - (38.88 SQM)	● Office (9)	
B00E - R0001 - Laboratory L.S. - (90.88 SQM) - Teaching Space: 1	● Student Space (42)	
B00E - R0002 - Preparation - (44.53 SQM)	Not Applicable	Circulation or storage space.
B00E - R0004 - Laboratory L.S. - (90.88 SQM) - Teaching Space: 1	● Student Space (42)	
B00E - R0005 - Laboratory L.S. - (90.88 SQM) - Teaching Space: 1	● Student Space (42)	
B00E - R0006 - Preparation - (44.55 SQM)	Not Applicable	Circulation or storage space.
B00E - R0008 - Laboratory L.S. - (90.88 SQM) - Teaching Space: 1	● Student Space (42)	
B00E - R0011 - Movement - (40.17 SQM)	Not Applicable	Circulation or storage space.
B00E - R1001 - Seminar - (11.74 SQM)	● Office (2)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00E - R1002 - Seminar - (12.18 SQM)	 Office (3)	
B00E - R1008 - Seminar - (11.75 SQM)	 Office (2)	
B00E - R1009 - Seminar - (12.24 SQM)	 Office (3)	
B00E - R1010 - Audio Visual Workroom - (28.04 SQM)	 Student Space (13)	
B00E - R1012 - Workroom - (18.36 SQM)	 Office (4)	
B00E - R1016 - Seminar - (71.26 SQM)	 Office (17)	
B00E - R1017 - Main Area - (322.7 SQM)	Not Applicable	Circulation or storage space.
B00E - R1019 - Movement - (39.98 SQM)	Not Applicable	Circulation or storage space.
B00G - R0001 - Gymnasium - (44.61 SQM)	 Student Space (20)	
B00G - R0002 - Entry - (10.97 SQM)	Not Applicable	Circulation or storage space.
B00G - R0005 - Multi-Purpose Space - (37.82 SQM)	 Student Space (17)	
B00G - R0006 - Multi-Purpose Space - (38.31 SQM)	 Student Space (17)	
B00G - R0007 - Multi-Purpose Space - (66.04 SQM)	 Student Space (30)	
B00G - R0008 - General Assistants - (53.37 SQM)	 Office (13)	
OS 601 11676 - OS 601 11676 - Learning Unit - Standard/Withdrawal - (76 SQM)	 Student Space (35)	
OS 601 15366 - OS 601 15366 - Learning Unit - Standard/Withdrawal - (76 SQM)	 Student Space (35)	
OS 601 19730 - OS 601 19730 - Learning Unit - Standard/Withdrawal - (76 SQM)	 Student Space (35)	
OS 621 19408 - OS 621 19408 - Learning Unit Single - PWD - (95 SQM)	 Student Space (44)	