


VENTILATION AUDIT REPORT

SCHOOL:	Swansea Public School (3141)
AMU REGION:	Hunter/Central Coast
STATE ELECTORATE:	Swansea
LOCAL GOVERNMENT AREA:	Lake Macquarie

3141 - Swansea Public School
Site Plan (12863)



1:632

Printed: 21-Mar-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Staff Room - (45.48 SQM)	Office (11)	
B00A - R0002 - Staff Room Annexe - (19.59 SQM)	Office (4)	
B00A - R0003 - Movement - (30.87 SQM)	Not Applicable	Circulation or storage space.
B00A - R0004 - Staff Room Annexe - (13.01 SQM)	Office (3)	
B00A - R0005 - Deputy Principal - (13.15 SQM)	Office (3)	
B00A - R0006 - Interview - (13.01 SQM)	Office (3)	
B00A - R0008 - Sick Bay - (8.56 SQM)	Student Space (3)	
B00A - R0009 - Clerical Office - (17.61 SQM)	Office (4)	
B00A - R0010 - Entry Vestibule - (24.05 SQM)	Not Applicable	Circulation or storage space.
B00A - R0011 - Movement - (16.23 SQM)	Not Applicable	Circulation or storage space.
B00A - R0012 - Duplicating Workroom - (20.01 SQM)	Office (5)	
B00A - R0013 - Principal - (16.74 SQM)	Office (4)	
B00B - R0010 - Reading Area - (157.39 SQM)	Student Space (73)	
B00B - R0014 - Special Programs Room - (39.32 SQM)	Student Space (18)	
B00C - R0002 - Home Base - (48.36 SQM) - Teaching Space: 1	Student Space (22)	
B00C - R0003 - Practical Activities - 1hb - (22.52 SQM)	Student Space (10)	
B00C - R0004 - Home Base - (48.36 SQM) - Teaching Space: 1	Student Space (22)	
B00C - R0005 - Practical Activities - 1hb - (16.55 SQM)	Student Space (7)	
B00C - R0006 - Home Base - (48.37 SQM) - Teaching Space: 1	Student Space (22)	
B00C - R0007 - Practical Activities - 1hb - (19.52 SQM)	Student Space (9)	
B00C - R0009 - Home Base - (64.88 SQM) - Teaching Space: 1	Student Space (30)	
B00C - R0010 - Practical Activities - 1hb - (26.07 SQM)	Student Space (12)	
B00C - R0011 - Movement - (13.27 SQM)	Not Applicable	Circulation or storage space.
B00C - R0013 - Home Base - (54.2 SQM) - Teaching Space: 1	Student Space (25)	
B00C - R0014 - Practical Activities - 1hb - (16.01 SQM)	Student Space (7)	
B00C - R0015 - Home Base - (61.44 SQM) - Teaching Space: 1	Student Space (28)	
B00C - R0016 - Practical Activities - 1hb - (18.24 SQM)	Student Space (8)	
B00C - R0018 - Movement - (22.98 SQM)	Not Applicable	Circulation or storage space.
B00C - R0019 - Home Base - (48.37 SQM) - Teaching Space: 1	Student Space (22)	
B00C - R0030 - Home Base - (87.13 SQM) - Teaching Space: 1	Student Space (40)	
B00C - R0031 - Practical Activities - 1hb - (32.73 SQM)	Student Space (15)	
B00C - R0035 - Practical Activities - 1hb - (20.62 SQM)	Student Space (9)	
B00C - R0037 - Home Base - (67.34 SQM) - Teaching Space: 1	Student Space (31)	
B00C - R0038 - Withdrawal Space - 2hb - (13.53 SQM)	Student Space (6)	
B00C - R0040 - Practical Activities - 1hb - (20.13 SQM)	Student Space (9)	
B00C - R0041 - Home Base - (67.64 SQM) - Teaching Space: 1	Student Space (31)	
B00D - R0002 - Practical Activities - 1hb - (9.89 SQM)	Student Space (4)	
B00D - R0003 - Home Base - (79.23 SQM) - Teaching Space: 1	Student Space (36)	
B00D - R0004 - Movement - (26.84 SQM)	Not Applicable	Circulation or storage space.
B00E - R0001 - Movement - (6.7 SQM)	Not Applicable	Circulation or storage space.
B00E - R0003 - Movement - (6.69 SQM)	Not Applicable	Circulation or storage space.
B00E - R0005 - Movement - (6.69 SQM)	Not Applicable	Circulation or storage space.
B00E - R0007 - Movement - (6.7 SQM)	Not Applicable	Circulation or storage space.
B00F - R0001 - Movement - (10.12 SQM)	Not Applicable	Circulation or storage space.
B00F - R0002 - Canteen - (37.44 SQM)	Not Applicable	Circulation or storage space.
B00G - R0001 - Communal Space - (73.58 SQM)	Student Space (34)	
B00G - R0002 - Raised Platform - (18.22 SQM)	Not Applicable	Circulation or storage space.
B00G - R0006 - Communal Space - (62.07 SQM)	Student Space (28)	
B00I - R0001 - Home Base - (46.43 SQM) - Teaching Space: 1	Student Space (21)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00I - R0004 - Special Programs Room - Type 2 - (39.06 SQM)	 Student Space (18)	
B00J - R0007 - Movement - (8.6 SQM)	Not Applicable	Circulation or storage space.