

# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Sydney Distance Education High School (8587)</b>
<b>AMU REGION:</b>	<b>Sydney</b>
<b>STATE ELECTORATE:</b>	<b>Sydney</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Sydney</b>

8587 - Sydney Distance Education High School  
Site Plan (10950)



1:552

Printed: 21-Mar-2020

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Principal Office - (27.48 SQM)	Office (6)	
B00A - R0002 - Interview/Office - Type 1 - (12.9 SQM)	Office (3)	
B00A - R0003 - Public Entry - (13.39 SQM)	Not Applicable	Circulation or storage space.
B00A - R0004 - Administration - Clerical - (13.11 SQM)	Office (3)	
B00A - R0005 - Administration - Clerical - (12.6 SQM)	Office (3)	
B00A - R0009 - Administration - Clerical - (13.07 SQM)	Office (3)	
B00A - R0011 - Administration - Clerical - (23.64 SQM)	Office (5)	
B00A - R0013 - Administration - Clerical - (12.89 SQM)	Office (3)	
B00A - R0014 - Administration - Clerical - (12.61 SQM)	Office (3)	
B00A - R0015 - Administration - Clerical - (12.53 SQM)	Office (3)	
B00A - R0017 - Movement - (15.68 SQM)	Not Applicable	Circulation or storage space.
B00A - R0019 - Staff Kitchen - (5.45 SQM)	Office (1)	
B00A - R1003 - Movement - (14.46 SQM)	Not Applicable	Circulation or storage space.
B00A - R1004 - Movement - (23.62 SQM)	Not Applicable	Circulation or storage space.
B00A - R1009 - Administration - Clerical - (6.27 SQM)	Office (1)	
B00A - R1011 - Movement - (6.13 SQM)	Not Applicable	Circulation or storage space.
B00A - R1013 - Movement - (8.22 SQM)	Not Applicable	Circulation or storage space.
B00A - R1014 - Staff Study - (24.22 SQM)	Office (6)	
B00A - R1018 - Movement - (26.87 SQM)	Not Applicable	Circulation or storage space.
B00A - R1019 - Movement - (9.48 SQM)	Not Applicable	Circulation or storage space.
B00A - R1020 - Study Space - (27.71 SQM)	Not Applicable	Circulation or storage space.
B00A - R1021 - Movement - (13.54 SQM)	Not Applicable	Circulation or storage space.
B00A - R1022 - Study Space - (13.91 SQM)	Not Applicable	Circulation or storage space.
B00A - R1025 - Interview/Office - Type 1 - (26.75 SQM)	Office (6)	
B00B - M0001 - Movement - (15.18 SQM)	Not Applicable	Circulation or storage space.
B00B - R0032 - Movement - (8.43 SQM)	Not Applicable	Circulation or storage space.
B00B - R0037 - General Assistants - (17.14 SQM)	Office (4)	
B00B - R0042 - General Assistants - (10.87 SQM)	Office (2)	
B00B - R0045 - Seminar - (21.06 SQM)	Office (5)	
B00B - R0046 - Seminar - (12.48 SQM)	Office (3)	
B00B - R0047 - Seminar - (12.87 SQM)	Office (3)	
B00B - R0048 - Audio Visual Workroom - (50.51 SQM)	Student Space (23)	
B00B - R0051 - Main Area - (268.63 SQM)	Not Applicable	Circulation or storage space.
B00B - R0054 - General Learning Space - (85.77 SQM) - Teaching Space: 1	Student Space (39)	
B00B - R0055 - Movement - (114.49 SQM)	Not Applicable	Circulation or storage space.
B00B - R0056 - Stage - (69.03 SQM)	Not Applicable	Circulation or storage space.
B00B - R0057 - Student Canteen - (32.45 SQM)	Not Applicable	Circulation or storage space.
B00B - R0058 - Student Canteen - (78.13 SQM)	Not Applicable	Circulation or storage space.
B00B - R0059 - Movement - (32.81 SQM)	Not Applicable	Circulation or storage space.
B00B - R1011 - Seminar - (14.17 SQM)	Office (3)	
B00B - R1019 - Movement - (93.41 SQM)	Not Applicable	Circulation or storage space.
B00B - R1020 - Staff Study - (362.19 SQM)	Office (90)	
B00B - R1021 - Interview/Meeting - (15.09 SQM)	Office (3)	
B00B - R1022 - Audio Visual Workroom - (15.3 SQM)	Student Space (7)	
B00B - R1023 - Audio Visual Workroom - (15.12 SQM)	Student Space (7)	
B00B - R1024 - Movement - (54.73 SQM)	Not Applicable	Circulation or storage space.
B00B - R1026 - General Learning Space - (59.68 SQM) - Teaching Space: 1	Student Space (27)	
B00B - R1027 - General Learning Space - (68.95 SQM) - Teaching Space: 1	Student Space (31)	
B00C - R1019 - Movement - (116.68 SQM)	Not Applicable	Circulation or storage space.
B00C - R1020 - Workroom - (23.11 SQM)	Office (5)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00C - R1021 - Seminar - Type 3 - (24.78 SQM)	Office (6)	
B00C - R1023 - Staff Study - (403.43 SQM)	Office (100)	
B00C - R1024 - General Learning Space - (37.13 SQM) - Teaching Space: 1	Student Space (17)	
B00D - R0010 - Movement - (10.92 SQM)	Not Applicable	Circulation or storage space.
B00D - R0011 - General Learning Space - (49.78 SQM) - Teaching Space: 1	Student Space (23)	
B00D - R0013 - Staff Study - (11.91 SQM)	Office (2)	
B00D - R0015 - Movement - (11.92 SQM)	Not Applicable	Circulation or storage space.
B00D - R0016 - General Learning Space - (50.7 SQM) - Teaching Space: 1	Student Space (23)	
B00D - R0019 - Staff Study - (12.28 SQM)	Office (3)	
B00D - R0020 - Administration - Clerical - (50.34 SQM)	Office (12)	
B00D - R0022 - Movement - (11.01 SQM)	Not Applicable	Circulation or storage space.
B00D - R0025 - Movement - (10.83 SQM)	Not Applicable	Circulation or storage space.
B00D - R0026 - Administration - Clerical - (51.48 SQM)	Office (12)	
B00D - R0028 - Movement - (16.11 SQM)	Not Applicable	Circulation or storage space.
B00D - R0029 - Tiered Learning Area - (47.58 SQM)	Student Space (22)	
B00D - R0032 - Movement - (17.89 SQM)	Not Applicable	Circulation or storage space.
B00D - R0033 - Movement - (43.09 SQM)	Not Applicable	Circulation or storage space.
B00D - R0035 - Movement - (38.89 SQM)	Not Applicable	Circulation or storage space.
B00D - R0037 - Movement - (43.48 SQM)	Not Applicable	Circulation or storage space.
B00D - R0038 - Movement - (35.1 SQM)	Not Applicable	Circulation or storage space.
B00D - R0042 - Movement - (7.41 SQM)	Not Applicable	Circulation or storage space.
B00D - R1008 - Staff Study - (56.01 SQM)	Office (14)	
B00D - R1009 - Seminar - Type 1 - (11.83 SQM)	Office (2)	
B00D - R1010 - Staff Study - (55.91 SQM)	Office (13)	
B00D - R1013 - Staff Study - (55.26 SQM)	Office (13)	
B00D - R1014 - Seminar - Type 1 - (12.36 SQM)	Office (3)	
B00D - R1018 - Movement - (17.82 SQM)	Not Applicable	Circulation or storage space.
B00D - R1019 - Movement - (34.27 SQM)	Not Applicable	Circulation or storage space.
B00D - R1020 - Movement - (52.56 SQM)	Not Applicable	Circulation or storage space.
B00D - R1021 - Movement - (31.46 SQM)	Not Applicable	Circulation or storage space.
B00D - R1022 - Movement - (35.56 SQM)	Not Applicable	Circulation or storage space.
B00D - R1025 - Movement - (6.58 SQM)	Not Applicable	Circulation or storage space.
B00D - R1027 - Movement - (22.83 SQM)	Not Applicable	Circulation or storage space.
B00D - R1028 - Movement - (7.61 SQM)	Not Applicable	Circulation or storage space.
B00D - R1030 - Staff Study - (75.76 SQM)	Office (18)	
B00E - R0012 - Practical Activities - (31.86 SQM)	Student Space (14)	
B00E - R0015 - Art Learning Space - (28.8 SQM) - Teaching Space: 1	Student Space (13)	
B00E - R1001 - General Learning Space - (28.33 SQM) - Teaching Space: 1	Student Space (13)	
B00E - R1003 - General Learning Space - (29.25 SQM) - Teaching Space: 1	Student Space (13)	
B00F - R0002 - Administration - Clerical - (13.11 SQM)	Office (3)	
B00F - R0003 - Administration - Clerical - (8.39 SQM)	Office (2)	
B00F - R0004 - Administration - Clerical - (13.11 SQM)	Office (3)	
B00F - R0005 - Administration - Clerical - (7.45 SQM)	Office (1)	
B00F - R1002 - Administration - Executive - (13.19 SQM)	Office (3)	
B00F - R1003 - Administration - Clerical - (6.52 SQM)	Office (1)	
B00F - R1004 - Administration - Clerical - (13.19 SQM)	Office (3)	
B00F - R1005 - Administration - Clerical - (8.86 SQM)	Office (2)	