


SCHOOL:	Sydney Distance Education Primary School (4586)
AMU REGION:	Sydney
STATE ELECTORATE:	Newtown
LOCAL GOVERNMENT AREA:	Sydney

4586 - Sydney Distance Education Primary School Site Plan (13409)



Ventilation Audit Key

Category	Description	
	Category A Operate this space in line with <u>COVID safe school operations</u> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.	
0	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces. The report details the number of people who can be accommodated safely in each of the identified spaces.	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Clerical Office - (5.73 SQM)	Office (1)	
B00A - R0002 - Entry Vestibule - (11.09 SQM)	Not Applicable	Circulation or storage space.
B00A - R0003 - Clerical Office - (11.37 SQM)	Office (2)	
B00A - R0005 - Movement - (11.19 SQM)	Not Applicable	Circulation or storage space.
B00A - R0006 - Duplicating Workroom - (12.59 SQM)	Office (3)	
B00A - R0007 - Principal - (10.93 SQM)	Office (2)	
B00A - R0013 - Staff Kitchen - (14.62 SQM)	Office (3)	
B00B - R0002 - Movement - (37.91 SQM)	Not Applicable	Circulation or storage space.
B00B - R0003 - Special Programs Room - (26.81 SQM)	Student Space (12)	
B00B - R0004 - Practical Activities - (11.67 SQM)	Student Space (5)	
B00B - R1002 - Movement - (24.64 SQM)	Not Applicable	Circulation or storage space.
B00B - R1003 - Home Base - (51.23 SQM) - Teaching Space: 1	Student Space (23)	
B00B - R1004 - Practical Activities - (7.37 SQM)	Student Space (3)	
B00B - R1007 - Special Programs Room - (13.1 SQM)	Student Space (6)	
B00E - R0001 - Interview - (12.37 SQM)	Office (3)	
B00E - R0004 - Special Programs Room - (29.99 SQM)	Student Space (13)	