


# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Sydney Secondary College Balmain Campus (8484)</b>
<b>AMU REGION:</b>	<b>Sydney</b>
<b>STATE ELECTORATE:</b>	<b>Balmain</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Inner West</b>

8484 - Sydney Secondary College Balmain Campus  
Site Plan (12302)



1:1,013

Printed: 04-Jul-2020

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Principal Office - (15.27 SQM)	Office (3)	
B00A - R0002 - Staff Study - (7.87 SQM)	Office (1)	
B00A - R0003 - Interview/Office - Type 1 - (15.23 SQM)	Office (3)	
B00A - R0004 - Staff Study - (28.83 SQM)	Office (7)	
B00A - R0006 - Interview/Meeting - (15.39 SQM)	Office (3)	
B00A - R0010 - Administration - Executive - (15.31 SQM)	Office (3)	
B00A - R0011 - Movement - (8.95 SQM)	Not Applicable	Circulation or storage space.
B00A - R0014 - Commonroom - (23.81 SQM)	Office (5)	
B00B - R0007 - Seminar - Type 1 - (40.9 SQM)	Office (10)	
B00C - R0007 - General Learning Space - (63.13 SQM) - Teaching Space: 1	Student Space (29)	
B00C - R0011 - Special Learning Space - (51.78 SQM) - Teaching Space: 1	Student Space (24)	
B00C - R0013 - Special Learning Space - (51.92 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R0018 - Interview/Office - Type 1 - (11.06 SQM)	Office (2)	
B00D - R0019 - Design/Technology L.S. - (66.49 SQM) - Teaching Space: 1	Student Space (30)	
B00D - R0021 - Staff Study - (84.58 SQM)	Office (21)	
B00D - R0022 - Tea Room - (6.97 SQM)	Not Applicable	Circulation or storage space.
B00D - R1004 - Art Learning Space - (52.58 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R1014 - Art Learning Space - (79.13 SQM) - Teaching Space: 1	Student Space (36)	
B00D - R2015 - Interview/Meeting - (11.67 SQM)	Office (2)	
B00D - R2016 - Interview/Meeting - (11.67 SQM)	Office (2)	
B00D - R2018 - Staff Study - (126.64 SQM)	Office (31)	
B00D - R2019 - Tea Room - (5.5 SQM)	Not Applicable	Circulation or storage space.
B00D - R3021 - General Learning Space - (66.34 SQM) - Teaching Space: 1	Student Space (30)	
B00D - R3022 - General Learning Space - (52.43 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R3026 - General Learning Space - (47.44 SQM) - Teaching Space: 1	Student Space (22)	
B00D - R3027 - General Learning Space - (61.45 SQM) - Teaching Space: 1	Student Space (28)	
B00E - R0004 - Workshop - (52.39 SQM)	Student Space (24)	
B00E - R0009 - General Learning Space - (64.9 SQM) - Teaching Space: 1	Student Space (30)	
B00E - R0014 - Materials Learning Space - Type 1 - (118.04 SQM) - Teaching Space: 1	Student Space (54)	
B00E - R0015 - Materials Learning Space - Type 1 - (116.03 SQM) - Teaching Space: 1	Student Space (53)	
B00E - R1014 - Performance Workshop - (117.57 SQM)	Student Space (54)	
B00E - R1015 - Music Learning Space - (65.34 SQM) - Teaching Space: 1	Student Space (30)	
B00E - R1017 - Practice/Seminar - (11.33 SQM)	Not Applicable	Circulation or storage space.
B00E - R1018 - Music Learning Space - (65.76 SQM) - Teaching Space: 1	Student Space (30)	
B00E - R1019 - Art Learning Space - (85.06 SQM) - Teaching Space: 1	Student Space (39)	
B00E - R1023 - Practice/Seminar - (10.57 SQM)	Not Applicable	Circulation or storage space.
B00E - R2013 - Design L.S. - (67.62 SQM) - Teaching Space: 1	Student Space (31)	
B00E - R2017 - Preparation - (20.97 SQM)	Not Applicable	Circulation or storage space.
B00E - R2020 - Food Technology L.S. - (112.46 SQM) - Teaching Space: 1	Student Space (52)	
B00E - R2021 - Food Technology L.S. - (83.99 SQM) - Teaching Space: 1	Student Space (38)	
B00F - R0001 - Movement - (6.25 SQM)	Not Applicable	Circulation or storage space.
B00F - R0007 - Movement - (38.2 SQM)	Not Applicable	Circulation or storage space.
B00F - R0012 - Movement - (11.31 SQM)	Not Applicable	Circulation or storage space.
B00F - R0015 - Movement - (10.15 SQM)	Not Applicable	Circulation or storage space.
B00F - R0017 - Student Canteen - (58.44 SQM)	Not Applicable	Circulation or storage space.
B00F - R0028 - Movement - (10.1 SQM)	Not Applicable	Circulation or storage space.
B00F - R0029 - Movement - (36.13 SQM)	Not Applicable	Circulation or storage space.
B00F - R0037 - Multi-Purpose Space - (341.42 SQM)	Student Space (158)	
B00F - R0042 - Stage - (95.11 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00F - R9002 - General Assistants - (9.98 SQM)	Office (2)	
B00F - R9014 - Fitness Laboratory - (68.46 SQM)	Student Space (31)	
B00G - R0001 - General Learning Space - (53.68 SQM) - Teaching Space: 1	Student Space (24)	
B00G - R0010 - General Learning Space - (50.95 SQM) - Teaching Space: 1	Student Space (23)	
B00G - R0011 - General Learning Space - (54.17 SQM) - Teaching Space: 1	Student Space (25)	
B00G - R0020 - Staff Study - (94.51 SQM)	Office (23)	
B00G - R1025 - Special Learning Space - (45.27 SQM) - Teaching Space: 1	Student Space (21)	
B00G - R1029 - General Learning Space - (53.02 SQM) - Teaching Space: 1	Student Space (24)	
B00G - R1031 - General Learning Space - (51.8 SQM) - Teaching Space: 1	Student Space (24)	
B00G - R1033 - General Learning Space - (48.5 SQM) - Teaching Space: 1	Student Space (22)	
B00G - R1036 - Interview/Office - Type 1 - (24.41 SQM)	Office (6)	
B00G - R2001 - General Learning Space - (52.8 SQM) - Teaching Space: 1	Student Space (24)	
B00G - R2002 - General Learning Space - (50.85 SQM) - Teaching Space: 1	Student Space (23)	
B00G - R2008 - General Learning Space - (49.91 SQM) - Teaching Space: 1	Student Space (23)	
B00G - R2009 - General Learning Space - (51.21 SQM) - Teaching Space: 1	Student Space (23)	
B00G - R2010 - General Learning Space - (53.02 SQM) - Teaching Space: 1	Student Space (24)	
B00G - R2015 - General Learning Space - (49.41 SQM) - Teaching Space: 1	Student Space (22)	
B00J - M3001 - Seminar - (77.74 SQM)	Office (19)	
B00J - R0002 - Computer Learning Space - (66 SQM) - Teaching Space: 1	Student Space (30)	
B00J - R0004 - Laboratory L.S. - (92.26 SQM) - Teaching Space: 1	Student Space (42)	
B00J - R0005 - Laboratory L.S. - (92.91 SQM) - Teaching Space: 1	Student Space (43)	
B00J - R0006 - Preparation - Science - (43.09 SQM)	Not Applicable	Circulation or storage space.
B00J - R0007 - Laboratory L.S. - (92.9 SQM) - Teaching Space: 1	Student Space (43)	
B00J - R0014 - Dark Room - (18.9 SQM)	Office (4)	
B00J - R0018 - Dark Room - (20.75 SQM)	Office (5)	
B00J - R1002 - Laboratory L.S. - (92.89 SQM) - Teaching Space: 1	Student Space (43)	
B00J - R1005 - Laboratory L.S. - (92.89 SQM) - Teaching Space: 1	Student Space (43)	
B00J - R1023 - Computer Learning Space - (92.7 SQM) - Teaching Space: 1	Student Space (43)	
B00J - R1026 - Preparation - (38.16 SQM)	Not Applicable	Circulation or storage space.
B00J - R1028 - General Learning Space - (60.64 SQM) - Teaching Space: 1	Student Space (28)	
B00J - R1029 - General Learning Space - (71.84 SQM) - Teaching Space: 1	Student Space (33)	
B00J - R2003 - Interview/Meeting - (12.27 SQM)	Office (3)	
B00J - R2010 - Clinic - (13.39 SQM)	Office (3)	
B00J - R2011 - Leading Teacher - (14.21 SQM)	Office (3)	
B00J - R2012 - Student Waiting - (11.66 SQM)	Not Applicable	Circulation or storage space.
B00J - R2013 - Deputy Principal Office - (13.35 SQM)	Office (3)	
B00J - R2015 - Deputy Principal Office - (21.23 SQM)	Office (5)	
B00J - R2016 - Commonroom - (124.01 SQM)	Office (31)	
B00J - R2017 - Principal Office - (40 SQM)	Office (10)	
B00J - R2021 - Administration - Clerical - (12.82 SQM)	Office (3)	
B00J - R2022 - Administration - Executive - (12.79 SQM)	Office (3)	
B00J - R2024 - Leading Teacher - (12.64 SQM)	Office (3)	
B00J - R2035 - Administration - Clerical - (63.91 SQM)	Office (15)	
B00J - R2036 - Movement - (102.15 SQM)	Not Applicable	Circulation or storage space.
B00J - R3005 - Seminar - Type 1 - (61.92 SQM)	Office (15)	
B00J - R3006 - Movement - (6.08 SQM)	Not Applicable	Circulation or storage space.
B00J - R3008 - Seminar - (15.35 SQM)	Office (3)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00J - R3009 - Seminar - (16.49 SQM)	Office (4)	
B00J - R3013 - Seminar - Type 1 - (9.21 SQM)	Office (2)	
B00J - R3014 - Audio Visual Workroom - (27.76 SQM)	Student Space (12)	
B00J - R3019 - Main Entry - (48.85 SQM)	Not Applicable	Circulation or storage space.
B00J - R3020 - Main Area - (314.78 SQM)	Not Applicable	Circulation or storage space.
OS 601 12875 - OS 601 12875 - Learning Unit - Standard/Withdrawal - (76 SQM)	Student Space (35)	
OS 601 13654 - OS 601 13654 - Learning Unit - Standard/Withdrawal - (76 SQM)	Student Space (35)	