

VENTILATION AUDIT REPORT

SCHOOL:	Sylvania High School (8463)
AMU REGION:	Sydney
STATE ELECTORATE:	Miranda
LOCAL GOVERNMENT AREA:	Sutherland

8463 - Sylvania High School
Site Plan (10777)



1:1,797

Printed: 14-Sep-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Deputy Principal Office - (16.29 SQM)	Office (4)	
B00A - R0002 - Administration - Clerical - (12.74 SQM)	Office (3)	
B00A - R0003 - Ancillary Staff - (13.75 SQM)	Office (3)	
B00A - R0006 - Principal Office - (16.21 SQM)	Office (4)	
B00A - R0007 - Administration - Clerical - (13.66 SQM)	Office (3)	
B00A - R0008 - Administration - Clerical - (27.87 SQM)	Office (6)	
B00A - R0009 - Clinic-Waiting - (11.2 SQM)	Office (2)	
B00A - R0012 - Interview/Office - Type 1 - (13.66 SQM)	Office (3)	
B00A - R0013 - Leading Teacher - (13.52 SQM)	Office (3)	
B00A - R0014 - Clinic - Boys - (13.65 SQM)	Office (3)	
B00A - R0020 - Clinic-Waiting - (6.54 SQM)	Office (1)	
B00A - R0021 - Movement - (5.95 SQM)	Not Applicable	Circulation or storage space.
B00A - R0023 - Movement - (75.64 SQM)	Not Applicable	Circulation or storage space.
B00D - R0002 - Movement - (86.74 SQM)	Not Applicable	Circulation or storage space.
B00D - R0003 - Food Technology L.S. - (83.01 SQM) - Teaching Space: 1	Student Space (38)	
B00D - R0004 - Food/Research Space - (14.31 SQM)	Not Applicable	Circulation or storage space.
B00D - R0005 - Food/Research Space - (15.49 SQM)	Not Applicable	Circulation or storage space.
B00D - R0006 - Food Technology L.S. - (81.39 SQM) - Teaching Space: 1	Student Space (37)	
B00D - R0012 - Commonroom - (65.58 SQM)	Office (16)	
B00D - R0013 - Staff Kitchen - (6.1 SQM)	Office (1)	
B00D - R0014 - Staff Study - (32.22 SQM)	Office (8)	
B00D - R0016 - Staff Study - (21.68 SQM)	Office (5)	
B00D - R0020 - Movement - (22.87 SQM)	Not Applicable	Circulation or storage space.
B00D - R0023 - Movement - (77.15 SQM)	Not Applicable	Circulation or storage space.
B00D - R1001 - Design L.S. - (65.34 SQM) - Teaching Space: 1	Student Space (30)	
B00D - R1003 - Design L.S. - (65.42 SQM) - Teaching Space: 1	Student Space (30)	
B00D - R1006 - Music Learning Space - (65.4 SQM) - Teaching Space: 1	Student Space (30)	
B00D - R1007 - Music Learning Space - (65.51 SQM) - Teaching Space: 1	Student Space (30)	
B00D - R1008 - Movement - (15.87 SQM)	Not Applicable	Circulation or storage space.
B00D - R1010 - Art Learning Space - (65.87 SQM) - Teaching Space: 1	Student Space (30)	
B00D - R1011 - Art Learning Space - (53.85 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R1012 - Darkroom Space - (11.33 SQM)	Office (2)	
B00D - R1015 - Movement - (78.32 SQM)	Not Applicable	Circulation or storage space.
B00D - R1018 - Movement - (84.63 SQM)	Not Applicable	Circulation or storage space.
B00M - R0005 - Art Learning Space - (78.71 SQM) - Teaching Space: 1	Student Space (36)	
B00M - R0008 - Movement - (20.28 SQM)	Not Applicable	Circulation or storage space.
B00M - R0014 - Workshop Area - (11.05 SQM)	Student Space (5)	
B00M - R0015 - Gymnasium - (66.92 SQM)	Student Space (31)	
B00M - R0019 - General Learning Space - (103.81 SQM) - Teaching Space: 1	Student Space (48)	
B00M - R0020 - General Learning Space - (81.2 SQM) - Teaching Space: 1	Student Space (37)	
B00M - R0021 - Movement - (21.37 SQM)	Not Applicable	Circulation or storage space.
B00M - R0022 - Movement - (33.54 SQM)	Not Applicable	Circulation or storage space.
B00M - R1001 - Materials Technology L.S. - (81.92 SQM) - Teaching Space: 1	Student Space (38)	
B00M - R1004 - Design L.S. - (51.62 SQM) - Teaching Space: 1	Student Space (23)	
B00M - R1005 - Movement - (66.88 SQM)	Not Applicable	Circulation or storage space.
B00M - R1006 - Staff Study - (25.42 SQM)	Office (6)	
B00M - R1007 - Design L.S. - (52.22 SQM) - Teaching Space: 1	Student Space (24)	
B00M - R1008 - Movement - (18.58 SQM)	Not Applicable	Circulation or storage space.
B00M - R1015 - General Learning Space - (113.77 SQM) - Teaching Space: 1	Student Space (52)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00P - R0001 - Performance Workspace - (75.51 SQM) - Teaching Space: 1	Student Space (35)	
B00P - R0003 - Performance Workspace - (134.96 SQM) - Teaching Space: 1	Student Space (62)	
B00P - R0004 - Staff Study - (11.76 SQM)	Office (2)	
B00P - R0006 - Staff Study - (11.83 SQM)	Office (2)	
B00P - R0007 - Movement - (41.81 SQM)	Not Applicable	Circulation or storage space.
B00S - R0001 - Multi-Purpose Space - (241.65 SQM)	Student Space (112)	
B00S - R0008 - Student Canteen - (48.62 SQM)	Not Applicable	Circulation or storage space.
B00S - R0010 - Stage - (67.2 SQM)	Not Applicable	Circulation or storage space.
B00S - R0014 - General Assistants - (29.4 SQM)	Office (7)	
B00S - R0015 - General Assistants - (9.99 SQM)	Office (2)	
B00S - R0016 - Movement - (96.83 SQM)	Not Applicable	Circulation or storage space.
B00S - R0019 - Movement - (78.56 SQM)	Not Applicable	Circulation or storage space.
B00S - R1001 - Movement - (69.8 SQM)	Not Applicable	Circulation or storage space.
B00S - R1003 - Staff Study - (10.73 SQM)	Office (2)	
B00S - R1008 - Staff Study - (11.17 SQM)	Office (2)	
B00S - R1011 - Movement - (48.37 SQM)	Not Applicable	Circulation or storage space.
B00T - R0002 - Music Learning Space - (101.38 SQM) - Teaching Space: 1	Student Space (47)	
B00T - R0005 - Practice/Seminar - (14.08 SQM)	Not Applicable	Circulation or storage space.
B00T - R0007 - Staff Study - (13.96 SQM)	Office (3)	
B00T - R0008 - Music Learning Space - (69.23 SQM) - Teaching Space: 1	Student Space (32)	
B00U - R0001 - Gymnasium - (624 SQM)	Student Space (289)	
B00U - R0002 - Stage - (106.52 SQM)	Not Applicable	Circulation or storage space.
B00U - R0003 - Movement - (8.9 SQM)	Not Applicable	Circulation or storage space.
B00U - R0005 - Movement - (14.64 SQM)	Not Applicable	Circulation or storage space.
B00W - R0001 - General Learning Space - (66.56 SQM) - Teaching Space: 1	Student Space (30)	
BOC1 - R0001 - General Learning Space - (52.94 SQM) - Teaching Space: 1	Student Space (24)	
BOC1 - R0002 - General Learning Space - (53.09 SQM) - Teaching Space: 1	Student Space (24)	
BOC1 - R0003 - Movement - (85 SQM)	Not Applicable	Circulation or storage space.
BOC1 - R0004 - Staff Study - (26 SQM)	Office (6)	
BOC1 - R0005 - General Learning Space - (52.87 SQM) - Teaching Space: 1	Student Space (24)	
BOC1 - R0007 - General Learning Space - (52.87 SQM) - Teaching Space: 1	Student Space (24)	
BOC1 - R0008 - General Learning Space - (53.09 SQM) - Teaching Space: 1	Student Space (24)	
BOC1 - R0014 - Leading Teacher - (10.98 SQM)	Office (2)	
BOC1 - R0020 - Staff Room Annexe - (21.82 SQM)	Office (5)	
BOC1 - R0021 - Staff Room - (26.9 SQM)	Office (6)	
BOC1 - R0022 - Movement - (82.74 SQM)	Not Applicable	Circulation or storage space.
BOC1 - R1001 - General Learning Space - (53.38 SQM) - Teaching Space: 1	Student Space (24)	
BOC1 - R1002 - General Learning Space - (53.52 SQM) - Teaching Space: 1	Student Space (24)	
BOC1 - R1003 - Staff Study - (19.43 SQM)	Office (4)	
BOC1 - R1004 - General Learning Space - (53.3 SQM) - Teaching Space: 1	Student Space (24)	
BOC1 - R1005 - General Learning Space - (53.52 SQM) - Teaching Space: 1	Student Space (24)	
BOC1 - R1007 - Computer Learning Space - (53.75 SQM) - Teaching Space: 1	Student Space (24)	
BOC1 - R1008 - Movement - (27.82 SQM)	Not Applicable	Circulation or storage space.
BOC1 - R1009 - Staff Study - (39.61 SQM)	Office (9)	
BOC1 - R1010 - Staff Study - (11.02 SQM)	Office (2)	
BOC1 - R1013 - General Learning Space - (53.3 SQM) - Teaching Space: 1	Student Space (24)	
BOC1 - R1014 - General Learning Space - (53.01 SQM) - Teaching Space: 1	Student Space (24)	
BOC1 - R1015 - Movement - (18.74 SQM)	Not Applicable	Circulation or storage space.
BOC1 - R1016 - Movement - (88.15 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
BOC3 - R0004 - Computer Learning Space - (52.86 SQM) - Teaching Space: 1	● Student Space (24)	
BOC3 - R0007 - General Learning Space - (53.16 SQM) - Teaching Space: 1	● Student Space (24)	
BOC3 - R0008 - Audio Visual Workroom - (18.97 SQM)	● Student Space (8)	
BOC3 - R0017 - Senior Seminar - (6.6 SQM)	○ Office (1)	
BOC3 - R0018 - Senior Study - (6.52 SQM)	○ Office (1)	
BOC3 - R0021 - Movement - (70.77 SQM)	Not Applicable	Circulation or storage space.
BOC3 - R0023 - Computer Learning Space - (53.45 SQM) - Teaching Space: 1	● Student Space (24)	
BOC3 - R0024 - Main Area - (220.92 SQM)	Not Applicable	Circulation or storage space.
BOC3 - R1001 - General Learning Space - (54.49 SQM) - Teaching Space: 1	● Student Space (25)	
BOC3 - R1002 - General Learning Space - (53.6 SQM) - Teaching Space: 1	● Student Space (24)	
BOC3 - R1003 - Staff Study - (19.01 SQM)	○ Office (4)	
BOC3 - R1006 - General Learning Space - (59.49 SQM) - Teaching Space: 1	● Student Space (27)	
BOC3 - R1007 - General Learning Space - (59.93 SQM) - Teaching Space: 1	● Student Space (27)	
BOC3 - R1008 - General Learning Space - (53.45 SQM) - Teaching Space: 1	● Student Space (24)	
BOC3 - R1009 - Movement - (17.98 SQM)	Not Applicable	Circulation or storage space.
BOC3 - R1010 - Staff Study - (39.66 SQM)	○ Office (9)	
BOC3 - R1013 - Staff Study - (17.77 SQM)	○ Office (4)	
BOC3 - R1014 - General Learning Space - (53.16 SQM) - Teaching Space: 1	● Student Space (24)	
BOC3 - R1015 - General Learning Space - (53.08 SQM) - Teaching Space: 1	● Student Space (24)	
BOC3 - R1016 - Movement - (20.73 SQM)	Not Applicable	Circulation or storage space.
BOL1 - R0008 - Movement - (55.86 SQM)	Not Applicable	Circulation or storage space.
BOL1 - R0012 - Movement - (8.75 SQM)	Not Applicable	Circulation or storage space.
BOL1 - R0014 - General Learning Space - (90.3 SQM) - Teaching Space: 1	● Student Space (41)	
BOL1 - R0015 - General Learning Space - (90.18 SQM) - Teaching Space: 1	● Student Space (41)	
BOL1 - R0019 - Preparation - (37.63 SQM)	Not Applicable	Circulation or storage space.
BOL1 - R1001 - General Learning Space - (91.53 SQM) - Teaching Space: 1	● Student Space (42)	
BOL1 - R1003 - Staff Study - (44.2 SQM)	○ Office (11)	
BOL1 - R1005 - General Learning Space - (91.14 SQM) - Teaching Space: 1	● Student Space (42)	
BOL1 - R1007 - Movement - (51.15 SQM)	Not Applicable	Circulation or storage space.
BOL2 - R0002 - Laboratory L.S. - (91.24 SQM) - Teaching Space: 1	● Student Space (42)	
BOL2 - R0004 - Preparation - (44.67 SQM)	Not Applicable	Circulation or storage space.
BOL2 - R0009 - General Assistants - (10.89 SQM)	○ Office (2)	
BOL2 - R0012 - Movement - (195.53 SQM)	Not Applicable	Circulation or storage space.
BOL2 - R0016 - Movement - (5.59 SQM)	Not Applicable	Circulation or storage space.
BOL2 - R0018 - General Learning Space - (89.98 SQM) - Teaching Space: 1	● Student Space (41)	
BOL2 - R1005 - Laboratory L.S. - (91.14 SQM) - Teaching Space: 1	● Student Space (42)	
BOL2 - R1010 - Laboratory L.S. - (91.13 SQM) - Teaching Space: 1	● Student Space (42)	
BOL2 - R1014 - Movement - (156.21 SQM)	Not Applicable	Circulation or storage space.
BOL2 - R1016 - Growing/Breeding - (8.15 SQM)	Not Applicable	Circulation or storage space.
BOL2 - R1017 - Movement - (5.59 SQM)	Not Applicable	Circulation or storage space.
BOL2 - R1019 - Preparation - (41.52 SQM)	Not Applicable	Circulation or storage space.