

VENTILATION AUDIT REPORT

SCHOOL:	Sylvania Public School (3143)
AMU REGION:	Sydney
STATE ELECTORATE:	Miranda
LOCAL GOVERNMENT AREA:	Sutherland

3143 - Sylvania Public School
Site Plan (12864)



1:694

Printed: 21-Mar-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Staff Kitchen - (17.27 SQM)	Office (4)	
B00A - R0002 - Staff Room - (24.76 SQM)	Office (6)	
B00A - R0003 - Staff Room Annexe - (10.48 SQM)	Office (2)	
B00A - R0004 - Duplicating Workroom - (10.46 SQM)	Office (2)	
B00A - R0005 - Clerical Office/Workroom - (14.29 SQM)	Office (3)	
B00A - R0007 - Principal - (17.37 SQM)	Office (4)	
B00A - R0008 - Entry Vestibule - (8.71 SQM)	Not Applicable	Circulation or storage space.
B00A - R0011 - Sick Bay - (8.49 SQM)	Student Space (3)	
B00A - R0012 - Movement - (11.98 SQM)	Not Applicable	Circulation or storage space.
B00A - R0015 - Movement - (8.74 SQM)	Not Applicable	Circulation or storage space.
B00B - R0002 - Reading Area - (95.11 SQM)	Student Space (44)	
B00C - R0001 - Communal Space - (211.64 SQM)	Student Space (98)	
B00C - R0005 - Canteen - (13.83 SQM)	Not Applicable	Circulation or storage space.
B00D - R0005 - Withdrawal Space - 1hb - (13.23 SQM)	Student Space (6)	
B00D - R0007 - Home Base - (67.24 SQM) - Teaching Space: 1	Student Space (31)	
B00D - R0008 - Practical Activities - 1hb - (20.27 SQM)	Student Space (9)	
B00E - R0001 - Practical Activities - 1hb - (18.45 SQM)	Student Space (8)	
B00E - R0003 - Home Base - (47.61 SQM) - Teaching Space: 1	Student Space (22)	
B00E - R0004 - Home Base - (48.46 SQM) - Teaching Space: 1	Student Space (22)	
B00E - R0006 - Practical Activities - 1hb - (18.8 SQM)	Student Space (8)	
B00F - R0002 - Practical Activities - 1hb - (9.65 SQM)	Student Space (4)	
B00F - R0003 - Practical Activities - 1hb - (11.74 SQM)	Student Space (5)	
B00F - R0005 - Home Base - (52.48 SQM) - Teaching Space: 1	Student Space (24)	
B00F - R0007 - Home Base - (52.63 SQM) - Teaching Space: 1	Student Space (24)	
B00G - R0001 - Home Base - (53.73 SQM) - Teaching Space: 1	Student Space (24)	
B00G - R0002 - Home Base - (53.95 SQM) - Teaching Space: 1	Student Space (25)	
B00G - R0003 - Practical Activities - 1hb - (22.35 SQM)	Student Space (10)	
B00I - R0001 - Home Base - (80.21 SQM) - Teaching Space: 1	Student Space (37)	
B00I - R0002 - Staff Kitchen - (11.04 SQM)	Office (2)	
B00I - R0007 - Clerical Office - (11.46 SQM)	Office (2)	
B00J - R0001 - Special Programs Room - (68.62 SQM)	Student Space (31)	
B00J - R0003 - Special Programs Room - (27.05 SQM)	Student Space (12)	
B00K - R0001 - Reading Area - (68.62 SQM)	Student Space (31)	