

VENTILATION AUDIT REPORT

SCHOOL:	Table Top Public School (3534)
AMU REGION:	Southern NSW
STATE ELECTORATE:	Albury
LOCAL GOVERNMENT AREA:	Albury

3534 - Table Top Public School
Site Plan (11325)












1:854

Printed: 16-Oct-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0002 - Reading Area - (38.89 SQM)	 Student Space (18)	
B00B - R0003 - Movement - (10.15 SQM)	Not Applicable	Circulation or storage space.
B00C - R0002 - Clerical Office - (12.8 SQM)	 Office (3)	
B00C - R0004 - Principal - (13.96 SQM)	 Office (3)	
B00C - R0006 - Home Base - (53.19 SQM) - Teaching Space: 1	 Student Space (24)	
B00C - R0007 - Home Base - (52.97 SQM) - Teaching Space: 1	 Student Space (24)	
B00C - R0008 - Staff Room - (22.24 SQM)	 Office (5)	
B00C - R0010 - Movement - (38.06 SQM)	Not Applicable	Circulation or storage space.
B00C - R0011 - Entry Vestibule - (14.85 SQM)	Not Applicable	Circulation or storage space.
B00G - R0005 - Reading Area - (90.15 SQM)	 Student Space (41)	
OS 601 11677 - OS 601 11677 - Learning Unit - Standard/Withdrawal - (76 SQM)	 Student Space (35)	
OS 603 17919 - OS 603 17919 - Learning Unit - Standard With P.A.A. A/C - (76 SQM)	 Student Space (35)	