


VENTILATION AUDIT REPORT

SCHOOL:	Tabulam Public School (3145)
AMU REGION:	North Coast
STATE ELECTORATE:	Lismore
LOCAL GOVERNMENT AREA:	Kyogle

3145 - Tabulam Public School
Site Plan (11810)



1:880

Printed: 21-Mar-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Home Base - (67.47 SQM) - Teaching Space: 1	● Student Space (31)	
B00A - R0002 - Sick Bay - (11.51 SQM)	● Student Space (5)	
B00A - R0005 - Movement - (40.54 SQM)	Not Applicable	Circulation or storage space.
B00A - R0006 - Canteen - (13.07 SQM)	Not Applicable	Circulation or storage space.
B00A - R0008 - Canteen - (7.97 SQM)	Not Applicable	Circulation or storage space.
B00A - R0009 - Movement - (27.15 SQM)	Not Applicable	Circulation or storage space.
B00A - R1001 - Staff Room - (53.58 SQM)	● Office (13)	
B00A - R1003 - Movement - (36.18 SQM)	Not Applicable	Circulation or storage space.
B00A - R1005 - Interview - (8.36 SQM)	● Office (2)	
B00A - R1006 - Principal - (15.57 SQM)	● Office (3)	
B00A - R1007 - Entry Vestibule - (15.44 SQM)	Not Applicable	Circulation or storage space.
B00A - R1008 - Clerical Office/Workroom - (22.25 SQM)	● Office (5)	
B00B - R0001 - Movement - (14.49 SQM)	Not Applicable	Circulation or storage space.
B00B - R0002 - Home Base - (59.91 SQM) - Teaching Space: 1	● Student Space (27)	
B00B - R0003 - Practical Activities - 1hb - (14.25 SQM)	● Student Space (6)	
B00B - R0005 - Movement - (32.81 SQM)	Not Applicable	Circulation or storage space.
B00B - R0007 - Withdrawal Space - 1hb - (11.56 SQM)	● Student Space (5)	
B00B - R0008 - Home Base - (59.76 SQM) - Teaching Space: 1	● Student Space (27)	
B00B - R0010 - Practical Activities - 1hb - (14.21 SQM)	● Student Space (6)	
B00B - R0011 - Movement - (14.49 SQM)	Not Applicable	Circulation or storage space.
B00C - R0004 - Movement - (14.58 SQM)	Not Applicable	Circulation or storage space.
B00D - R0002 - Home Base - (55.51 SQM) - Teaching Space: 1	● Student Space (25)	
B00D - R0003 - Practical Activities - 1hb - (19.3 SQM)	● Student Space (8)	
B00E - R0001 - Home Base - (41.46 SQM) - Teaching Space: 1	● Student Space (19)	
B00E - R0002 - Practical Activities - 1hb - (25.98 SQM)	● Student Space (12)	
B00E - R0003 - Movement - (25.12 SQM)	Not Applicable	Circulation or storage space.
B00F - R0001 - Practical Activities - 1hb - (15.01 SQM)	● Student Space (6)	
B00F - R0002 - Home Base - (71.66 SQM) - Teaching Space: 1	● Student Space (33)	
B00F - R0003 - Movement - (8.4 SQM)	Not Applicable	Circulation or storage space.
B00F - R0008 - Staff Room Annexe - (18.54 SQM)	● Office (4)	
B00F - R0009 - Movement - (50.96 SQM)	Not Applicable	Circulation or storage space.
B00H - R0002 - Clerical Office - (18.98 SQM)	● Office (4)	
B00H - R0004 - Sick Bay - (7.64 SQM)	● Student Space (3)	
B00H - R0007 - Movement - (19.55 SQM)	Not Applicable	Circulation or storage space.
B00H - R0008 - Staff Room - (21.02 SQM)	● Office (5)	
B00H - R0009 - Staff Kitchen - (5.49 SQM)	● Office (1)	
B00H - R0011 - Principal - (17.09 SQM)	● Office (4)	
B00H - R0012 - Reading Area - (71.61 SQM)	● Student Space (33)	